

2012 JUN 19 AM 9: 01

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORMLincoln Rural W/A Old Red Star
Public Water Supply Name430031
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
 On water bills
 Other _____

Date customers were informed: 6/12/12 *Notice on Bill Card that a copy of CCR can be picked up @ office or website*

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 1/1

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: DAILY LEADER

Date Published: 6/15/12

CCR was posted in public places. *(Attach list of locations)*

Date Posted: 1/1

CCR was posted on a publicly accessible internet site at the address: www.lincolnruralwater.com

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Tommy Cupal
Name/Title (President, Mayor, Owner, etc.)

6/15/12
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2012 JUN 19 AM 9: 01

Quality on Tap Report
Lincoln Rural Water Association
Old Red Star
PWS ID# 430031
June 1, 2012

Lincoln Rural Water is pleased to present to you, this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells pumping from the Miocene Aquifer. Lincoln Rural Water is pleased to report that our drinking water meets all federal and state requirements.

The following reports show our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact our office at 1536 Monticello Street, Brookhaven, MS 39602, 601-833-6449. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3rd Tuesday of each month at the above location at 7:00 P.M. and our annual meeting is held on the 3rd Monday of March at the Lincoln County Courthouse at 7:00 P.M.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detail information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Lincoln Rural Water have received a moderate and lower ranking in terms of susceptibility to contamination.

Lincoln Rural Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2011. All drinking water, including bottled drinking water may be reasonably expected to contain at least a small amount of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG'S allow for a margin of safety.

Additional information for Lead

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/sagewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$20.00 per sample. Please contact 601.576.7582 if you wish to have your water tested

MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclide's Rule, all community public water supplies were required to sample quarterly for Radionuclide's beginning January 2007-December 2007. Your public water supply completed sampling by the scheduled deadline; However, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

2012 JUN 19 AM 9: 01

Test Results

PSI:#430031

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL, TT, or MRDL</u>	<u>Your Water</u>	<u>Range Low High</u>	<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfection By-Products							
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)							
Chlorine (as Cl ₂) (ppm)	4	4	1.00	.90 1.00	2011	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	.03	NA	2007	No	By-product of drinking water chlorination
Inorganic Contaminants							
Nitrite [measured as Nitrogen] (ppm)	1	1	0.1	NA	2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic (ppm)	5	5	.003314	NA	2009	No	Erosion of natural deposits, runoff from metal refineries; Erosion of natural deposits
Barium (ppm)	2	2	0.062805	NA	2009	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.109	NA	2009	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Selenium (ppm)	5	5	.013206	NA	2009	No	Discharge from petroleum and metal refineries; erosion of natural deposits, discharge from mines
Copper - action level at consumer taps (ppm)	1.3	1.3	.1	2010	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	.1	2010	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have any questions.