

RECEIVED-WATER SUPPLY
2012 JUN 28 AM 9:41

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

City of Columbia

Public Water Supply Name

0460003

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 6/23/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Columbian - progress

Date Published: 6/23/12


- CCR was posted in public places. *(Attach list of locations)*

Date Posted: 6/24/12 City Hall

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.



Name/Title (President, Mayor, Owner, etc.)

6/23/12

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2011 Annual Drinking Water Quality Report 2012 JUN 25 AM 7:46
 City of Columbia
 PWS#: 0460003
 June 2012

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Columbia have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael McDaniel at 601.441.0368. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 4:00 PM at the City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants									
10. Barium	N	2010*	.04	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
16. Fluoride**	N	2011	1.31	.37 – 1.31	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
19. Nitrate (as Nitrogen)	N	2011	.22	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Disinfection By-Products									
Chlorine	N	2011	1.1	.78 – 1.26	ppm	0	MRDL = 4	Water additive used to control microbes	

* Most recent sample. No sample required for 2011.

Our system received a CCR violation for not getting the 2010 Consumer Confidence Report into the MSDH by the annual deadline of July 1st.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF COLUMBIA is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 90%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

******* A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING *******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The City of Columbia works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

2012 JUN 28 AM 9:41

THE STATE OF MISSISSIPPI
COUNTY OF MARION

Personally appeared before me, the undersigned Notary Public, in and for the County and State aforesaid, **Susan Amundson** who being by me and duly sworn, states on oath that she is Legal Clerk of the Columbian-Progress, a newspaper published in the City of Columbia, State and County, aforesaid, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 time(s), as follows:

In Vol. 110 No. 50 Date 23 day of June, 2012
In Vol. 110 No. _____ Date _____ day of _____, 2012
In Vol. 110 No. _____ Date _____ day of _____, 2012
In Vol. 110 No. _____ Date _____ day of _____, 2012

Signed Susan Amundson
Susan Amundson

Sworn to and subscribed before me, this 23 day of June, 2012.

Bonnie Hudson
Bonnie Hudson, Notary Public



(SEAL)

See attached.

3x14 @ \$10.50
No. words _____ at _____ Total \$ 441.⁰⁰
Proof of Publication \$3.00
Total Cost..... \$ 444.⁰⁰

20th Annual Drinking Water Quality Report WATER SUPPLY
 City of Columbia
 PWS ID: 460003 2012 JUN 28 AM 9:41
 June 2012

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. The information we provide is intended to help you understand the risks to your health from drinking water. Our water source is from wells drilled from the Missouri Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Columbia have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about the report or concerning your water safety, please contact Michael McDaniel at 601.441.0368. We want our valued customers to be informed about their water safety. If you need to learn more, please join us at any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 4:00 PM at the City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the processing of animals or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or other activities; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and lawn care; and radon, a radioactive gas that occurs naturally in some areas. Some of these substances, such as nitrates, which can be naturally occurring or the result of oil and gas production, and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production; and certain inorganic substances, such as arsenic, which are regulated by EPA. EPA regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water is naturally occurring or the result of oil and gas production. It is important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or if Samples Exceeding MCL/MCLG/MRDL	Unit	MCLG	MCL	MRDL	Likely Source of Contamination
Inorganic Contaminants									
10 Barium	N	2012	04	No Range	ppm	2	2		Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
16 Fluoride**	N	2011	1.31	37 - 1.31	ppm	4	4		Erosion of natural deposits, water additive which promotes sprouting, leach discharge from fertilizer and herbicide facilities
19 Nitrate (as Nitrogen)	N	2011	22	No Range	ppm	10	10		Runoff from fertilizer use, leaching from septic tanks, sewage, erosion of natural deposits
Disinfection By-Products									
Chlorine	N	2011	1.1	78 - 1.26	ppm	0	MRDL = 4		Water additive used to control microbes

* Most recent sample. No sample required for 2011.

Our system received a CCR violation for not getting the 2010 Consumer Confidence Report into the MSOH by the annual deadline of July 1st.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. In an effort to assure systems complete all monitoring requirements, MSOH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or <http://www.epa.gov/lead>. The Mississippi State Department of Health Public Health Laboratory also provides information on lead testing. Please contact 601.578.7562 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies," the CITY OF COLUMBIA is required to report certain results pertaining to fluoridation of our water system. The number of months at the previous calendar year that average fluoride concentration was within the optimal range of 0.7-1.2 ppm was 6. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 90%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by drinking water from the health care providers: EPA/CDC guidelines on appropriate means to lessen the risk of infection by drinking water from the health care providers: EPA/CDC guidelines on appropriate means to lessen the risk of infection by drinking water from the health care providers: EPA/CDC guidelines on appropriate means to lessen the risk of infection by drinking water from the health care providers. Please contact Melissa Patten, Deputy Director, at 601.578.7518 for more information.

A MESSAGE FROM MSOH CONCERNING RADIOLOGICAL SAMPLING

In accordance with the Radon in Drinking Water Act, all community public water supplies were required to sample quarterly for radon from beginning January 2007. December 2011. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of a violation by the public water supply, MSOH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirement. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2012. If you have any questions, please contact Melissa Patten, Deputy Director, at 601.578.7518.

The City of Columbia works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water resources, which are the heart of our community, our way of life and our children's future.