

2012 JUN 20 AM 10:33

BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

City of Louisville - Northeast
 Public Water Supply Name

PWS ID# 800005
 List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
 On water bills
 Other _____

Date customers were informed: 6 / 13 / 12

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Winston County Journal

Date Published: 6 / 13 / 12

CCR was posted in public places. *(Attach list of locations)* - Louisville Utility Office

Date Posted: 6 / 13 / 12

CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


 Name/Title (President, Mayor, Owner, etc.)

6-18-12

Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

*Annual Drinking Water Quality Report
City of Louisville -Northeast
PWS ID # 0800005
June, 2012*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Lower Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination.. The water supply for the City of Louisville-Northeast received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Wilson Webb at 662-773-7147. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at Louisville Utilities office at 8:00 a.m.

The City of Louisville-Northeast routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2010*	0.01	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
17. Lead	N	1/1/09 to 12/31/11	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2010*	0.8	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	N	Jan - Dec	1.10	0.88 - 1.30	ppm	4	4	Water additive used to control microbes
73. TTHM Total trihalo-methanes]	N		1.20	None	ppb	80	80	By-product of drinking water chlorination

* Most recent sample results available

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007-December 2007. Your public water supply completed the sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Louisville-Northeast is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested..

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

2012 JUN 20 AM 10: 34


PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI COUNTY WINSTON

Before the undersigned authority of said county and state personally appeared Chasatie Fisher, County of Winston, State of Mississippi, Winston County Journal, duly sworn, both depose and say that the publication of the notice hereto affixed has been made in said newspaper for 1 consecutive week(s), to-wit:

Vol 119, No. 24, on the 13 day of June, 2012
 Vol _____, No. _____, on the _____ day of _____, 2012
 Vol. _____, No. _____, on the _____ day of _____, 2012
 Vol. _____, No. _____, on the _____ day of _____, 2012
 Vol. _____, No. _____, on the _____ day of _____, 2012
 Vol. _____, No. _____, on the _____ day of _____, 2012

Sworn to and subscribed to this the 14 day of June 2012
me the undersigned Notary Public of said County and State.



By: Susan D. Adcock

Chasatie Fisher

Printer's fee 73.00

Annual Drinking Water Quality Report
City of Louisville-Northeast
PWS ID # 0800005
June, 2012

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Lower Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Louisville-Northeast received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Wilcox Webb at 662-772-7747. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at Louisville Utilities office at 8:00 a.m.

The City of Louisville-Northeast routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS									
Contaminant	Units	Obs. Value	Level Allowed	Stage of Disinfection or # of Disinfection Filtration	TT	MCLG	MCL	TT	Level of Contamination
Inorganic Constituents									
10. Arsenic	ppb	0.01	0.01	No Range	Yes	0	0	1	Discharge of drilling wastes, discharge from coal refuse, erosion of natural deposits
11. Lead	ppb	0.00	0.01	No Range	Yes	0	0	1	Corrosion of lead-based plumbing fixtures, erosion of natural deposits
18. Nitrate (as Nitrogen)	ppm	0.8	10	No Range	Yes	10	10	1	Runoff from fertilizer use, leaching from waste water, seepage from natural deposits
Disinfectants & Disinfection By-Products									
Chlorine or Chlorine Dioxide	ppm	1.0	0.83-1.50	Yes	Yes	4	4	1	Water additive used to control microbes
19. Total trihalomethanes	ppb	1.30	None	Yes	Yes	80	80	1	By-product of drinking water chlorination

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****
 In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007-December 2007. Your public water supply completed the sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead
 If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Louisville-Northeast is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions. Publish: 6/13 2012.

This bill is now due and payable. If unpaid 5 days after due date service may be discontinued.



**LOUISVILLE
ELECTRIC
SYSTEM**

P.O. BOX 849 · LOUISVILLE, MISSISSIPPI · 39339-0849
PHONE 662/773-7147 · FAX 662/773-7858

ACCOUNT NUMBER:	001-3821-1
CUSTOMER NAME:	WILSON WEBB
SERVICE ADDRESS:	124A MCCULLOUGH RD
METER READING DATE:	Jun 11 2012
DAYS BILLED:	32

SERVICE	PRESENT READING	PREVIOUS READING	AMOUNT USED	AMOUNT
ELECTRIC (KILOWATT HOURS)	5345	2801	2544	239.38
WATER (ONE UNIT = 100 GALLONS)	3328	3272	56	20.78
CROSS CONNECTION FEE				0.76
SEWER (ONE UNIT = 100 GALLONS)				23.25
SANITATION				15.00
TOTAL CURRENT CHARGES				299.17
BALANCE FORWARD (PAST DUE)				299.17

RECEIVED - WATER SUPPLY
2012 JUN 20 AM 10:31

AMOUNT FROM PREVIOUS BILL	LATE CHARGES ADDED	PAYMENTS & ADJUSTMENTS	OTHER DEBITS/CREDITS	BALANCE FORWARD (PAST DUE)	CURRENT CHARGES	NET AMOUNT DUE
286.45	0.00	286.45-	0.00	0.00	299.17	299.17

\$2.00 WILL BE ADDED TO THE PAST DUE AMOUNT IF A LATE NOTICE IS MAILED. PENALTIES AND LATE FEES WILL BE ADDED TO BILLS THAT ARE NOT PAID BY THE DUE DATE. A COPY OF THE 2011 CONSUMER CONFIDENCE REPORT IS AVAILABLE IN OUR OFFICE FOR YOUR REVIEW.

001-3821-1 SORT NINE

COMPARE YOUR USAGE

PERIOD	DAYS	ELECT KWH USED	DAILY AVG KWH	WATER GALS. USED	DAILY AVG GALS.
CURRENT	32	2544	80	5600	175
LAST MONTH	30	2493	83	4600	153
YEAR AGO	31	2624	85	4200	135

PLEASE DETACH AND RETURN THIS PORTION WITH PAYMENT



RETURN SERVICE REQUESTED

CUSTOMER ACCOUNT NO:	001-3821-1
NET AMOUNT DUE:	299.17
DUE DATE:	JUL 2 2012
LATE CHARGES:	14.96
AMOUNT AFTER DUE DATE:	314.13

000003



PL : 3
WILSON WEBB
124A MCCULLOUGH RD
LOUISVILLE MS 39339-9485

LOUISVILLE ELECTRIC SYSTEM
PO BOX 849
LOUISVILLE MS 39339-0849

