

RECEIVED-WATER SUPPLY
2012 JUN -5 AM 10:00

BUREAU OF PUBLIC WATER SUPPLY
CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

MORGANTOWN WATER ASSOCIATION
Public Water Supply Name

0460011
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 5/31/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:
Date Mailed/Distributed: 1/1
- CCR was published in _____

The results of our monitoring for the period of January 1, 2011 to December 31, 2011 will be available for customers at 35 Morgan Lane and 17 Circle Drive, Morgantown, MS. GIVEN WITH WATER BILL'S

CERTIFICATION
I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Charles E. Williams - President
Name/Title (President, Mayor, Owner, etc.)

5-31-12
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2012 SEP 13 AM 8:42

Annual Drinking Water Quality Report
Morgantown Water Association
PWS#: 0460011
May30, 2012

CORRECTED COPY

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is from one well pumping from Moicene Series Aquifer.

Our source water assessment is currently being conducted and is not available at this time. As soon as it is completed, you will be notified and copies of this assessment will be available at our office for you to view at 35 Morgan Lane and 17 Circle Drive, Morgantown, MS.

If you have any questions about this report or concerning your water utility, please contact Charles Williams at 601-736-0392. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. This meeting was held on May 26, 2012 at 1:30PM in the Morgantown Family Life Center.

The Morgantown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1, 2011 to December 31, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

The results of our monitoring for the period of January 1, 2011 to December 31, 2011 will be available for customers at 35 Morgan Lane and 17 Circle Drive, Morgantown, MS.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

We at the Morgantown Water Association work hard to provide each tap with quality water. We ask that all our customers help us protect our water sources, which are the heart of our community, or way of life and our children’s future.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Morgantown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact (601)-576-7582 if you wish to have your water tested.

********A Message From MSDH Concerning Radiological Sampling ********

In accordance with Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

| Type of test | MCLG | AL | Your Water | Sample Date | # sample exceeding AL | Exceed AL | Typical Sources |
|---------------------------------------|--|---------------------------|------------|-------------|-----------------------|-----------|--|
| Lead and Copper | Lead 0.0005- 0.0024 Copper 0.0046- 0.0068 | 2 ppm 0.1 ppm | 5 | 06-14-2011 | 0 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits |
| Nitrate Nitrite Nitrate/Nitrite | 0.08 0.02 0.1 | 10 ppm 1 ppm 10 ppm | 1 | 02-28-2011 | 0 | 0 | At the well head |

Sample Results

| ID | ANALYTE NAME | METHOD | RESULT | MCL |
|------|--------------|----------|-------------|------|
| 1010 | BARIUM | 200.8 | 0.008163ppm | 2ppm |
| 1025 | FLORIDE | 380-75WE | 0.137 ppm | 4ppm |

Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During July 2011 we did not monitor or test for Bacteriological contaminants nor chlorine and therefore, cannot be sure of the quality of our drinking water during that time. The number of samples required were 2, the number of samples taken were 0.

C.C.R. Report Corrected

2012 JUN -5 AM 10: 00

Annual Drinking Water Quality Report
Morgantown Water Association
PWS#: 0460011
May30, 2012

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is from one well pumping from Moicene Series Aquifer.

Our source water assessment is currently being conducted and is not available at this time. As soon as it is completed, you will be notified and copies of this assessment will be available at our office for you to view at 35 Morgan Lane and 17 Circle Drive, Morgantown, MS.

If you have any questions about this report or concerning your water utility, please contact Charles Williams at 601-736-0392. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. This meeting was held on May 26, 2012 at 1:30PM in the Morgantown Family Life Center.

The Morgantown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1, 2011 to December 31, 2011. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

The results of our monitoring for the period of January 1, 2011 to December 31, 2011 will be available for customers at 35 Morgan Lane and 17 Circle Drive, Morgantown, MS.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

We at the Morgantown Water Association work hard to provide each tap with quality water. We ask that all our customers help us protect our water sources, which are the heart of our community, or way of life and our children's future.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Morgantown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact (601)-576-7582 if you wish to have your water tested.

Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a primary disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection By-Products Rule. Our water system has not failed to complete these monitoring requirements in 2011. We did complete the monitoring requirements for bacteriological sampling that showed coliform present. In an effort to ensure systems complete all monitoring requirements, the MSDH now notifies systems of any missing samples prior to the end of a compliance period.

********A Message From MSDH Concerning Radiological Sampling ********

In accordance with Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice.

Although this was not result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements.

The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

Water Quality Data Table

| Type of test | MCLG | AL | Your Water | Sample Date | # sample exceeding AL | Exceed AL | Typical Sources |
|---------------------------------------|--|---------------------------|------------|-------------|-----------------------|-----------|--|
| Lead and Copper | Lead 0.0005- 0.0024 Copper 0.0046- 0.0068 | 0.015 ppm 1.3 ppm | 5 | 06-14-2011 | 0 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits |
| Nitrate Nitrite Nitrate/Nitrite | 0.08 0.02 0.1 | 10 ppm 1 ppm 10 ppm | 1 | 02-28-2011 | 0 | 0 | At the well head |

2012 JUN 19 PM 2: 23

FROM: MORGANTOWN WATER ASSOCIATION
C.C.R. REPORT.

THIS IS COPY OF WHAT WAS GIVEN TO
CUSTOMERS WHERE THEY COULD READ
THE RESULTS OF THE CCR REPORT, END-
ING DECEMBER 31, 2011.

THERE WAS SUPPOSE TO HAVE BEEN
ONE (1) OF THESE WITH THE CCR REPORT.
SRRRY FOR THE CONFUSION.

MORGANTOWN WATER ASSO.
CHARLES E. WILLIAMS

The results of our monitoring for the period of January 1, 2011 to December 31,
2011 will be available for customers at 35 Morgan Lane and 17 Circle Drive,
Morgantown, MS.

The results of our monitoring for the period of January 1, 2011 to December 31,
2011 will be available for customers at 35 Morgan Lane and 17 Circle Drive,
Morgantown, MS.

The Morgantown Water Association

Morgantown, Mississippi 39483

*C.C.R. REPORT CAN BE
SEEN @ 35 MORGAN RD
OR 17 CIRCLE DR.*

METER READINGS
 PRESENT 2402920
 PREVIOUS 2372720
 GAL. CONSUMED 30200

Charles Williams

NOTE:

All bills must be paid before the first of the month.
 There will be a service charge of \$25.00 for reconnection.

| | DOLLARS | CENTS |
|----------------------------------|---------|-------|
| CHARGES THIS MONTH | 77. | 50 |
| TAX EXEMPT | | |
| TOTAL THIS MONTH | | |
| OVERPAYMENT CREDIT OR ADJUSTMENT | | |
| PAST DUE CHARGES | | |
| TOTAL | | |
| AMOUNT PAID | | |
| BALANCE | 77. | 50 |
| DATE | | |
| 5/31/12 | | |

OFFICE COPY

7/6/11

MEMO

FROM: MELANIE'S DESK @ WATER SUPPLY
PHONE: 601-576-7518
FAX: 601-576-7800
SEPTEMBER 01, 2012

TO: Morgantown (0460011)
ATTN: Mr. Charles Williams
RE: required corrections to CCR

CORRECTION TO CCR REQUIRED BY 10/01/2012

- add Barium 0.008163 ppm detects
- add Fluoride 0.137 ppm
- change Lead to 2 and copper to .1
- add information regarding TCR monitoring violation for 7/11

DIRECTIONS

-
- 1.) Correct report & mail/fax a copy titled "CORRECTED CCR" to MSDH.
 - 2.) Notify customers on their next water bill as follows: "CORRECTED CCR AVAILABLE UPON REQUEST" (mail/fax MSDH a copy of this also).
 - 3.) Fax to the above fax number. Please call me if you have any questions.
- And thank you for your attention to this matter.

9/6 - spoke to Mr. W. again we will send Monday 9/11 mailed

46/11

5/20 - "will mail correction"

9/1 - CM. to wife of Mr. William to call

2011 CCR Contact Information

Date: 8/17/12 Time: _____

PWSID: 460011

MELANIE-WATER SUPPLY
PHONE - 601-576-7518
FAX- 601-576-7822

System Name: Morgantown

Needed Corrections

Lead/Copper Language

Chlorine Residual (MRDL) RAA

Fluoride

GWR

Radiological

Other

Violations(s) add - TCR monitoring violation for July 2011 left off
Lead 90th is 2
Copper 90th is .1

- ① Will Correct report & mail copy marked "Corrected copy" to MSDH ~~X~~
- ② Will notify customers of availability of corrected report on next monthly bill. ~~X (mail us a copy)~~

Corrections

Left off Barium 0.008163 ppm } detects
Left off Fluoride 0.137 ppm }

add - all detects and all violations ^{of} have to be reported.
Send us a corrected CCR

Spoke with mailed.

(Operator, Owner, Secretary)

~~* Only need to send customers a statement on your next bill "Corrected CCR available upon request."~~

Thanks!