

2012 JUN 22 PM 2:54

BUREAU OF PUBLIC WATER SUPPLY

**CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM**

Chalybeate Water Assn.
Public Water Supply Name

0700003
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper
 - On water bills
 - Other _____

Date customers were informed: 6/20/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:
Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
Name of Newspaper: Southern Sentinel
Date Published: 6/20/12

- CCR was posted in public places. *(Attach list of locations)* water office
Date Posted: 6/20/12

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Bobby Yalowitz President
Name/Title (President, Mayor, Owner, etc.)

6-20-12
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

WATER SUPPLY

2012 SEP 7 AM 8:29

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing from the Coffee Sand Aquifer.

Our source water assessment has been completed. Our wells have received a lower to moderate susceptibility rankings to contaminations. If you have any questions about this report or concerning your water utility, please contact Bobby Gatewood at 662-223-4940. We want our valued customer to be informed about their water utility. If you want to know more, please attend any of our meetings. They are held 3rd Friday each quarter-March, June, Sept. and Dec. at 7:00 pm. at the Chalybeate Water Office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2008, the table reflects the most recent results. As water travels over the land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum, and can also come from gas stations, urban storm-water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

Action level-the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT)-A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL)- The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)- is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Defects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2011	.143	.140-.149	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2011	.5	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

Corrected copy of C.C.R.

2012 SEP -7 AM 8:29
RECEIVED - WATER SUPPLY

Microbiological Contaminants								
1. Total Coliform Bacteria	Y	Feb 2011	TCR Routine	1	NA	0	Presence of coliform bacteria in 5% of monthly	Naturally present in the environment

15. Lead	N	2011	0.015	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	2011	.02	No Range	ppm	1	1	Removal from fertilizer use; leaching from septic tanks, sewer pipe; erosion of natural deposits.

Disinfection By-Products

Chlorine	N	2011	.29	.05 - 5	ppm	0	MREDL = 4	Water additive used to control microbes
----------	---	------	-----	---------	-----	---	-----------	---

Additional Information for Lead

If present levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Chalybeate Water Association is responsible for providing high quality water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure, flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007-December 2007. Your public water supply completed sampling by the scheduled deadline; however an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply at 601.576.7518.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you however, you may obtain a copy by calling 662-223-4940

Proof of Publication

The State of Mississippi

Tippah County

Personally appeared before me a Notary Public in and for said County and State, the undersigned

Tim Watson

who, after being duly sworn, deposes and says that he is the Publisher of the SOUTHERN SENTINEL, a newspaper published in the City of Ripley, in said County and State, and that the

LEGAL NOTICE

a true copy of which is hereto attached, was published for 1 consecutive weeks in said newspaper as follows:


VOLUME	NO.	DATE
<u>134</u>	<u>17</u>	<u>6/20/2012</u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

And further, that said newspaper has been published in Ripley, Tippah County, Mississippi for more than one year next preceding the first insertion of the above mentioned legal notice.




Tim Watson

Sworn to and subscribed before me this the
20 day of June 2012.



Notary Public, Tippah County, Mississippi
My Commission expires: **05/05/2013**



Printer's Fee \$ _____

Copy of Water Bill

CHALYBEATE WATER ASSOCIATION
2890 HWY 354
WALNUT MS 38683

00611 100000

First Class Mail
U.S. POSTAGE
Paid 1.00
PERMIT NO. 783

RETURN SERVICE REQUESTED

12390		00611 100000			
TYPE OF SERVICE	METER READING		USED	CHARGES	
	PRESENT	PREVIOUS			
WA	2817	2816	1	1200	
CORRECTED CCR AVAILABLE UPON REQUEST.					
METER READ	NET DUE	AFTER THIS DATE	PAY GROSS		
001512	1200	091512	1390		

001512 1200 1390

RETURN THIS PORTION WITH PAYMENT

12390

00611 100000
2890 HWY 100
WALNUT, MS 38683



Thanks
Bobby Yalwood
Chalybeate Water Assn.
0700003

70/03

SPEED MEMO

FROM: MELANIE'S DESK @ WATER SUPPLY

PHONE: 601-576-7518

FAX: 601-576-7822

AUGUST 17, 2012

TO: Chalybeate W/A

ATTN: Bobby Gatewood

RE: CCR Correction

CORRECTION TO CCR REQUIRED BY 10/01/2012

add monitoring violation info for coliform (CCR)
and also for chlorine
Lead - 4 (repeat whole #'s); Copper - 0

DIRECTIONS

- 1.) Correct report & mail/fax a copy titled "CORRECTED CCR" to MSDH.
 - 2.) Notify customers on their next water bill as follows: "CORRECTED CCR AVAILABLE UPON REQUEST" (mail/fax MSDH a copy of this also).
 - 3.) Fax to the above fax number. Please call me if you have any questions.
- And thank you for your attention to this matter.

9/4 spoke to B. Gatewood - putting in mail today ^{8/16} called "will send"