

2012 JUN 29 AM 10:39



MISSISSIPPI STATE DEPARTMENT OF HEALTH

**BUREAU OF PUBLIC WATER SUPPLY****CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

COUNTRY HAVEN MOBILE HOME PARK  
Public Water Supply Name

0170027 (C)  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

***Please Answer the Following Questions Regarding the Consumer Confidence Report***

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper

On water bills

Other \_\_\_\_\_

Date customers were informed: 6/28/12

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: 6/28/12

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_ / \_\_\_ / \_\_\_

CCR was posted in public places. *(Attach list of locations)*

Date Posted: 6/28/12

CCR was posted on a publicly accessible internet site at www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

*Ruby D. Ellard*  
Name/Title (President, Mayor, Owner, etc.)

6-27-12  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

570 East Woodrow Wilson - Post Office Box 1700 - Jackson, MS 39215-1700  
601-576-8090 - 1-866-HLTHY4U - www.HealthyMS.com

Equal Opportunity in Employment/Services

WATER SUPPLY  
2012 SEP 26 AM 10:18

# Country Haven Mobile Home Park

1151 Hwy 51 N • Nesbit, MS 38651

PWSID# 0170027

## Water Quality Report 2011 - Revised



Prepared by:

Mitchell Technical Services, Inc  
325 West McKnight  
Murfreesboro, TN 37129



**IS MY WATER SAFE ?**

Last year your tap water met all monitored U.S. Environmental Protection Agency (EPA) and state drinking water health standards. We vigilantly safeguard the water supply and we are proud to report that our system meets all monitored federal and state requirements.

**REPORT AVAILABILITY**

This report is not mailed to the residents, however, it is published annually in the local paper and is also posted in the central office on the bulletin board for review.

**DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**WHERE DOES MY WATER COME FROM?**

Our water comes from two wells over 200 feet deep, which draw ground water from the Sparta Sand Aquifer.

**SOURCE WATER ASSESSMENT AND ITS AVAILABILITY.**

Our source water assessment has been completed by the Mississippi State Department of Health. The results of the report are available at:

<http://landandwater.deq.ms.gov/swap/reports/report.aspx?id=0170027>

The susceptibility ranking of each of our wells was Moderate

**WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**HOW CAN I GET INVOLVED?**

We encourage all customers who have any concerns or questions to contact our office.

**OTHER INFORMATION:**

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address:

<http://www.msdh.state.us/watersupply/index.htm>.

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" may be obtained.

<b>Certified Operator:</b>	Ralph Augimeri	<b>Phone</b>	662-562-5314
<b>Operations Firm:</b>	MTS, Inc.	<b>Fax</b>	662-562-5314
<b>Emergency Contact :</b>	901-619-4739		

# Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

## Important Drinking Water Definitions:

**ND: Non-Detects:** Laboratory analysis indicates that the constituent is not present.

**MCLG: Maximum Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL: Maximum Contaminant Level:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**AL: Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

## Units Description:

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

**ppm:** parts per million, or **mg/l:** milligrams per liter

**ppb:** parts per billion, or **µg/l :** micrograms per liter

## Inorganic Chemicals

Contaminant	MCL	Your Water	Likely Source of Contaminant
Sample Date	MCLG	Violation Y/N	
Antimony (ppm) 07/27/11	0.006 0.006	< 0.0005 N	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppm) 07/27/11	0.010 n/a	< 0.0005 N	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm) 07/27/11	2.0 2.0	0.030555 N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppm) 07/27/11	0.004 0.004	< 0.0005 N	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppm) 07/27/11	0.005 0.005	<0.0005 N	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppm) 07/27/11	0.10 0.10	<0.0005 N	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppm) 07/27/11	0.20 0.20	<0.015 N	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride (ppm) 07/27/11	4.0 4.0	0.1 N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppm) 07/27/11	0.002 0.002	<0.0005 N	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Selenium (ppm) 07/27/11	0.05	<0.0025 N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium 07/27/11	0.002	<0.0005 N	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories

## Haloacetic Acids (HAA5)

Date	Your Water
09/17/08	No Regulated Haloacetic Acids Detected

## Total Trihalomethane

Date	Your Water
09/17/08	No TTHM'S Detected

## Nitrates

Contaminant Sample Date	MCL MCLG	Your Water Violation Y/N	Likely Source of Contaminant
Nitrate-Nitrite ppm (as Nitrogen) 02/02/2011	10 n/a	< 0.1 N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate (ppm) (as Nitrogen)) 02/02/2011	10 10	< 0.08 N	
Nitrite (ppm) (as Nitrogen) 02/02/2011	1 1	< 0.02	

## Volatile Organic Chemicals

Date	Your Water
04/23/08	No Regulated VOC'S Detected

## Lead and Copper

Contaminant	MCLG	Your Water	Likely Source of
Sample Date	AL	Violation Y/N	Contaminant
Copper (ppm)	1.3	0.0 N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
07/14/11	1.3		
Lead (ppm)	0	0.001	Corrosion of household plumbing systems; Erosion of natural deposits
07/14/11	0.015	N	

## Maximum Residual Disinfectant Level Chlorine

Running Annual Average MCL  
for Chlorine 4.0 mg/l

Compliance Period 2011	Monitoring Period Average mg/l	Running Annual Average mg/l	Samples Required	Samples Collected	Begin Date 2011	End Date 2011
Jan	2.20	1.602	1	1	01/01	01/31
Feb	1.35	1.50	1	1	02/01	02/28
Mar	1.33	1.50	1	1	03/01	03/31
Apr	0.94	1.50	1	1	04/01	04/30
May	0.98	1.40	1	1	05/01	05/31
Jun	1.42	1.40	1	1	06/01	06/30
Jul	0.97	1.40	1	1	07/01	07/31
Aug	0.88	1.30	5	5	08/01	08/31
Sep	1.16	1.30	5	5	09/01	09/30
Oct	1.19	1.30	1	1	10/01	10/31
Nov	0.92	1.20	1	1	11/01	11/30
Dec	1.19	1.20	1	1	12/01	12/31

## REPORTABLE VIOLATIONS

\*\*\*\*\*  
**A MESSAGE FROM  
 MSDH CONCERNING  
 RADIOLOGICAL SAMPLING**  
 \*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 -December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at

Begin Date	End Date	ANALYTE NAME	VIOLATION NAME
01/01/11	03/31/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
01/01/11	03/31/11	RADIUM-228	ROUTINE MAJOR MONITORING
01/01/11	03/31/11	RADIUM-226	ROUTINE MAJOR MONITORING
01/01/11	03/31/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	RADIUM-226	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	RADIUM-228	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	RADIUM-226	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	RADIUM-228	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	RADIUM-226	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	RADIUM-228	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING

2012 SEP 26 AM ID: 18

During a sanitary survey conducted on June 6, 2011, the Mississippi State Department of Health cited the following significant deficiency(s):

Inadequate internal cleaning/maintenance of storage tanks.

Corrective Actions: This system is currently under a Bi-lateral Compliance Agreement with the MSDH to correct this deficiency by November 2013.

This citation was issued due to the tanks not being inspected by the June 6, 2011 date. This inspection had been scheduled prior to the MSDH inspection and was conducted about two weeks later. It was determined at that time, the tanks, while still performing the necessary function, were at the end of their useful life and would be replaced. The construction of the first tank and new aerator will begin this summer.

\*\*\*\*\*

Significant  
Deficiencies

\*\*\*\*\*

REVIEW

2012 JUN 29 AM 10: 39

**Country Haven Mobile Home Park**  
1151 Hwy 51 N.  
Nesbit MS, 38651

**Phone (662) 429-9626**  
**Fax (662) 449-0764**

Lo-28-12

We have posted the CCR report  
in our office entryway for the  
tenants to see and we also  
hand delivered copies to the tenants.

**IS MY WATER SAFE ?**

Last year your tap water met all monitored U.S. Environmental Protection Agency (EPA) and state drinking water health standards. We vigilantly safeguard the water supply and we are proud to report that our system meets all monitored federal and state requirements.

**REPORT AVAILABILITY**

This report is not mailed to the residents, however, it is published annually in the local paper and is also posted in the central office on the bulletin board for review.

**DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**WHERE DOES MY WATER COME FROM?**

Our water comes from two wells over 200 feet deep, which draw ground water from the Sparta Sand Aquifer.

**SOURCE WATER ASSESSMENT AND ITS AVAILABILITY.**

Our source water assessment has been completed by the Mississippi State Department of Health. Copies are available upon request.

**WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**HOW CAN I GET INVOLVED?**

We encourage all customers who have any concerns or questions to contact our office.

**OTHER INFORMATION:**

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address:

<http://www.msdh.state.us/watersupply/index.htm>.

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" may be obtained.

<b>Certified Operator:</b>	Ralph Augimeri	<b>Phone</b>	662-562-5314
<b>Operations Firm:</b>	MTS, Inc.	<b>Fax</b>	662-562-5314
<b>Emergency Contact :</b>	901-619-4739		

## Haloacetic Acids (HAA5)

Date	Your Water
09/17/08	No Regulated Haloacetic Acids Detected

## Total Trihalomethane

Date	Your Water
09/17/08	No TTHM'S Detected

## Nitrates

Contaminant Sample Date	MCL MCLG	Your Water Violation Y/N	Likely Source of Contaminant
Nitrate-Nitrite ppm (as Nitrogen) 02/02/2011	10 n/a	< 0.1 N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate (ppm) (as Nitrogen) 02/02/2011	10 10	< 0.08 N	
Nitrite (ppm) (as Nitrogen) 02/02/2011	1 1	< 0.02	

## Volatile Organic Chemicals

Date	Your Water
04/23/08	No Regulated VOC'S Detected

## Lead and Copper

Contaminant	MCLG	Your Water	Likely Source of
Sample Date	AL	Violation Y/N	Contaminant
Copper (ppm)	1.3	0.0 N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
07/14/11	1.3		
Lead (ppm)	0	0.001	Corrosion of household plumbing systems; Erosion of natural deposits
07/14/11	0.015	N	

## Maximum Residual Disinfectant Level Chlorine

Running Annual Average MCL  
for Chlorine 4.0 mg/l

Compliance Period 2011	Monitoring Period Average mg/l	Running Annual Average mg/l	Samples Required	Samples Collected	Begin Date 2011	End Date 2011
Jan	2.20	1.602	1	1	01/01	01/31
Feb	1.35	1.50	1	1	02/01	02/28
Mar	1.33	1.50	1	1	03/01	03/31
Apr	0.94	1.50	1	1	04/01	04/30
May	0.98	1.40	1	1	05/01	05/31
Jun	1.42	1.40	1	1	06/01	06/30
Jul	0.97	1.40	1	1	07/01	07/31
Aug	0.88	1.30	5	5	08/01	08/31
Sep	1.16	1.30	5	5	09/01	09/30
Oct	1.19	1.30	1	1	10/01	10/31
Nov	0.92	1.20	1	1	11/01	11/30
Dec	1.19	1.20	1	1	12/01	12/31

## REPORTABLE VIOLATIONS

\*\*\*\*\*  
**A MESSAGE FROM  
 MSDH CONCERNING  
 RADIOLOGICAL SAMPLING**  
 \*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 -December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at

Begin Date	End Date	ANALYTE NAME	VIOLATION NAME
01/01/11	03/31/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
01/01/11	03/31/11	RADIUM-228	ROUTINE MAJOR MONITORING
01/01/11	03/31/11	RADIUM-226	ROUTINE MAJOR MONITORING
01/01/11	03/31/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	RADIUM-226	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
04/01/11	06/30/11	RADIUM-228	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	RADIUM-226	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	RADIUM-228	ROUTINE MAJOR MONITORING
07/01/11	09/30/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	COMBINED URANIUM	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	RADIUM-226	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	RADIUM-228	ROUTINE MAJOR MONITORING
10/01/11	12/31/11	GROSS ALPHA PARTICLE ACTIVITY	ROUTINE MAJOR MONITORING

## Inorganic Chemicals

Contaminant Sample Date	MCL MCLG	Your Water Violation Y/N	Likely Source of Contaminant
Antimony (ppm) 07/27/11	0.006 0.006	< 0.0005 N	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppm) 07/27/11	0.010 n/a	< 0.0005 N	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm) 07/27/11	2.0 2.0	0.030555 N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppm) 07/27/11	0.004 0.004	< 0.0005 N	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppm) 07/27/11	0.005 0.005	<0.0005 N	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppm) 07/27/11	0.10 0.10	<0.0005 N	Discharge from steel and pulp mills; erosion of natural deposits
Cyanide (ppm) 07/27/11	0.20 0.20	<0.015 N	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride (ppm) 07/27/11	4.0 4.0	0.1 N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppm) 07/27/11	0.002 0.002	<0.0005 N	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Selenium (ppm) 07/27/11	0.05	<0.0025 N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium 07/27/11	0.002	<0.0005 N	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories

# Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

## Important Drinking Water Definitions:

**ND: Non-Detects:** Laboratory analysis indicates that the constituent is not present.

**MCLG: Maximum Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL: Maximum Contaminant Level:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**AL: Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

## Units Description:

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

**ppm:** parts per million, or **mg/l:** milligrams per liter

**ppb:** parts per billion, or **µg/l :** micrograms per liter

During a sanitary survey conducted on June 6, 2011, the Mississippi State Department of Health cited the following significant deficiency(s):

Inadequate internal cleaning/maintenance of storage tanks.

**Corrective Actions:** This system is currently under a Bi-lateral Compliance Agreement with the MSDH to correct this deficiency by November 2013.

This citation was issued due to the tanks not being inspected by the June 6, 2011 date. This inspection had been scheduled prior to the MSDH inspection and was conducted about two weeks later. It was determined at that time, the tanks, while still performing the necessary function, were at the end of their useful life and would be replaced. The construction of the first tank and new aerator will begin this summer.

\*\*\*\*\*

**Significant  
Deficiencies**

\*\*\*\*\*