

2012 JUL -2 AM 9:50

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

Siloam Water Association
Public Water Supply Name
130016 130015 130004 130017
130025 130021 130024 130023
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper
 On water bills
 Other _____

Date customers were informed: 6/30/12

- CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Daily Times Leader

Date Published: 6/29/12

- CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

- CCR was posted on a publicly accessible internet site at the address: www. _____

CERTIFICATION

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Mary L. Williams
Name/Title (President, Mayor, Owner, etc.)

6-29-12
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2012 JUL -2 AM 9:50

2011 Drinking Water Quality Report

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environment Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. This report is a snapshot of last years water quality. Included are details about where your water comes from, what it contains and how it compares to standards set by regulatory agencies. We are committed to providing the best information about the quality of your drinking water.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Where does my water come from?

Our water comes from 8 different wells that draw from the Eutaw, Gordo and McShan Aquifers.

Source water assessment and its availability:

Our source water assessment is available on request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791

How can I get involved?

Our board members meet the 2nd Monday of every month at 5:00 pm at the Siloam Water Office. Our annual meeting is the 1st Monday in April. The exact time and place will be printed on your water bill. This is a very important meeting and we encourage all of our members to attend.

Siloam Water Contact Information
Willie Davenport – Certified Operator
P.O. Box 224
West Point, Ms 39773
662-494-1852

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Siloam Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

*******A Message From MSDH Concerning Radiological Sampling*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007- December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

Monitoring and Reporting of Compliance Data Violations Significant Deficiencies

System Name and ID: Una-130023, Griffith-130015, Pine Bluff-130017

During a sanitary survey conducted on 7/28/2011, the Mississippi State Department of Health cited the following significant deficiencies:

Inadequate internal cleaning/maintenance of storage tanks

Corrective actions: These systems are currently under a Bilateral Compliance Agreement with the MSDH to correct this deficiency by 8/22/2012

Inorganic and Radioactive Contaminants

BARIUM

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	2	2	0.02	No	May-11	Discharge of drilling waste and metal refineries. Erosion of natural deposits.
Beasley II- 130025	2	2	0.03	No	May-11	
Griffith- 130015	2	2	0.03	No	May-11	
Gates- 130021	2	2	0.02	No	May-11	
Ivy Village- 130004	2	2	0.03	No	May-11	
Muldon- 130024	2	2	0.06	No	May-11	
Pine Bluff- 130017	2	2	0.07	No	May-11	
Una- 130023	2	2	0.04	No	May-11	

FLOURIDE

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	4	4	1.06	No	May-11	Erosion of natural deposits. Additive which promotes strong teeth. Discharge from fertilizer.
Beasley II- 130025	4	4	0.72	No	May-11	
Griffith- 130015	4	4	0.61	No	May-11	
Gates- 130021	4	4	0.88	No	May-11	
Ivy Village- 130004	4	4	0.83	No	May-11	
Muldon- 130024	4	4	0.40	No	May-11	
Pine Bluff- 130017	4	4	0.10	No	May-11	
Una- 130023	4	4	0.30	No	May-11	

LEAD

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	0	15	0.002	No	Jul-08	Corrosion of household plumbing systems. Erosion of natural deposits.
Beasley II- 130025	0	15	0.001	No	Jul-08	
Griffith- 130015	0	15	0.002	No	Jul-07	
Gates- 130021	0	15	0.003	No	Jul-07	
Ivy Village- 130004	0	15	0.002	No	Jul-08	
Muldon- 130024	0	15	0.001	No	Jul-08	
Pine Bluff- 130017	0	15	0.002	No	Jul-07	
Una- 130023	0	15	0.003	No	Jul-08	

COPPER

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	1.3	1.3	0.60	No	Jul-08	Corrosion of household plumbing systems. Erosion of natural deposits.
Beasley II- 130025	1.3	1.3	0.70	No	Jul-08	
Griffith- 130015	1.3	1.3	0.10	No	Jul-07	
Gates- 130021	1.3	1.3	0.10	No	Jul-07	
Ivy Village- 130004	1.3	1.3	0.00	No	Jul-08	
Muldon- 130024	1.3	1.3	0.46	No	Jul-08	
Pine Bluff- 130017	1.3	1.3	0.30	No	Jul-07	
Una- 130023	1.3	1.3	0.30	No	Jul-08	

CYANIDE

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	0.2	0.2	0.01	No	Aug-11	Discharge from steel/metal factories. Discharge from plastic and fertilizer factories.
Beasley II- 130025	0.2	0.2	0.01	No	Aug-11	
Griffith- 130015	0.2	0.2	0.01	No	Jun-11	
Gates- 130021	0.2	0.2	0.01	No	Aug-11	
Ivy Village- 130004	0.2	0.2	0.01	No	Aug-11	
Muldon- 130024	0.2	0.2	0.01	No	Aug-11	
Pine Bluff- 130017	0.2	0.2	0.01	No	Aug-11	
Una- 130023	0.2	0.2	0.01	No	Aug-11	

NITRATE/NITRATE

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	10	10	0.1	No	Jan-11	Runoff from fertilizer use; leaching from septic tanks and sewage. Erosion of natural deposits.
Beasley II- 130025	10	10	0.1	No	Jan-11	
Griffith- 130015	10	10	0.1	No	Jan-11	
Gates- 130021	10	10	0.1	No	Oct-11	
Ivy Village- 130004	10	10	0.1	No	Jan-11	
Muldon- 130024	10	10	0.1	No	Jan-11	
Pine Bluff- 130017	10	10	0.1	No	Jan-11	
Una- 130023	10	10	0.1	No	Jan-11	

HALOACETIC ACID HAA5

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	0.06	0.06	0.02	No	Aug-11	Disinfection Bi-product
Beasley II- 130025	0.06	0.06	0.06	No	Jun-11	
Griffith- 130015	0.06	0.06	0.06	No	Jun-11	
Gates- 130021	0.06	0.06	0.01	No	Aug-11	
Ivy Village- 130004	0.06	0.06	0.06	No	Aug-11	
Muldon- 130024	0.06	0.06	0.06	No	Aug-11	
Pine Bluff- 130017	0.06	0.06	0.06	No	Aug-11	
Una- 130023	0.06	0.06	0.06	No	Aug-11	

TRICHALOMETHANE TTHM

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	0.08	0.08	0.04	No	Aug-11	Disinfection Bi-product
Beasley II- 130025	0.08	0.08	0.04	No	Aug-11	
Griffith- 130015	0.08	0.08	0.04	No	Jun-11	
Gates- 130021	0.08	0.08	0.04	No	Aug-11	
Ivy Village- 130004	0.08	0.08	0.04	No	Aug-11	
Muldon- 130024	0.08	0.08	0.04	No	Aug-11	
Pine Bluff- 130017	0.08	0.08	0.04	No	Aug-11	
Una- 130023	0.08	0.08	0.01	No	Aug-11	

ALPHA EMITTERS

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	15	15	2.99	No	Nov-11	Erosion of natural deposits.
Ivy Village- 130004	15	15	2.97	No	Nov-11	
Muldon- 130024	15	15	2.92	No	Nov-11	

URANIUM

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	5	5	0.06	No	Nov-11	Erosion of natural deposits.
Ivy Village- 130004	5	5	0.06	No	Nov-11	
Muldon- 130024	5	5	0.06	No	Nov-11	

RADIUM

Well-PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date	Typical Source
Beasley I- 130016	5	5	0.70	No	Nov-11	Erosion of natural deposits.
Ivy Village- 130004	5	5	0.79	No	Nov-11	
Muldon- 130024	5	5	0.48	No	Nov-11	

Chlorine-

Well- PWS ID#	MCLG	MCL	Your Water	Low	High	Sample Date	Violation	Typical Source
Beasley I- 130016	4	4	0.10	0.10	0.10	2011	N	Water additive used to control microbes. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Beasley II- 130025	4	4	0.20	0.20	0.20	2011	N	
Griffith- 130015	4	4	0.15	0.15	0.15	2011	N	
Gates- 130021	4	4	0.15	0.10	0.20	2011	N	
Ivy Village- 130004	4	4	0.10	0.10	0.10	2011	N	
Muldon- 130024	4	4	0.20	0.20	0.20	2011	N	
Pine Bluff- 130017	4	4	0.10	0.10	0.10	2011	N	
Una- 130023	4	4	0.10	0.10	0.10	2011	N	

Term	Definition
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
MCL-Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology
MCLG-Maximum Contaminant Level Goal	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
TT-Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
AL-Action Level	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MRDLG-Maximum Residual Disinfection Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MCLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL-Maximum Residual Disinfection Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

THE MURDOCH FAMILY OF NEWS CORP. UNANIMOUSLY APPROVED THE SPLIT, IT WILL NEED TO REVIEW A MORE FORMAL PROPOSAL ON THE MATTER. THE DEAL IS ALSO SUBJECT TO SHAREHOLDER AND REGULATORY APPROVALS. NEWS CORP. SAID IT PLANS TO HOLD A MEETING OF ITS SHAREHOLDERS SOMETIME IN 2013. THE ENTIRE PROCESS MAY TAKE A YEAR TO FINALIZE.

The Murdoch family, which controls nearly 40 percent of the voting shares in

NEWS CORP. SHAREHOLDERS WILL RECEIVE ONE SHARE OF COMMON STOCK IN EACH NEW COMPANY ABOUT \$54 BILLION.

Australian newspaper that he inherited from his father that became the foundation for News Corp.

foreign culture practices newspapers tracked phones and bribed public officials in gain exclusive information.

Act, which punishes companies that have bribed officials abroad.

Murdoch emphasized on abroad.

'Any Man'

continued from page 3

Oh, enemy you must know that I am on the edge of my sword. For you are truly working hard to keep me from saying no. For you also know that the end is close at hand. You are doing all you can to keep me from entering the promise land. Stand on guard. Stay away from the word of God, I will use my sword.

For I have hidden it in my heart because it was giving by the Lord. Lord, I stand before you waiting to know your will. For I say no to the spirit that came to kill. Lord, I touch and agree. I will live in liberty with thee. It has been a minute, it has been a journey. It has been what it was and by the Grace of God, it is now what it is!

A journey to and from... where no soul would knowingly choose to go...

Yet I did... I believed... I accepted... I denied... I was rejected... But now... I don't... I have faith... I am alive... I am redeemed... I am victorious... I am who I am (Any Man) in Christ as the Holy Spirit keeps me...

My Place... I'm Back

2011 Drinking Water Quality Report										
Agency	Organic and Reactive Contaminants			Violations	Sample Date	Typical Source				
	MCGL	MCL	Year Water							
Alachua	10018	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Brevard	10019	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Collier	10020	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
DeSoto	10021	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Duval	10022	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Flagler	10023	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Franklin	10024	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Hardee	10025	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Highway	10026	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Madison	10027	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Polk	10028	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
St. Johns	10029	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Union	10030	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				

2012 JUL - 2 AM 9:50

Is my water safe?
Let's face it, in this past year you've read all sorts of headlines about the safety of drinking water. The good news is that the vast majority of drinking water in the United States is safe to drink. However, there are some areas where the water quality is not as good as it should be. This is often due to contamination from agricultural runoff, industrial discharges, and natural sources like pesticides and herbicides.

Do I need to take special precautions?
Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, and the elderly are particularly vulnerable. People with compromised immune systems, such as those with HIV/AIDS or other chronic health conditions, are also more vulnerable to waterborne illness.

What does my water come from?
Our water comes from a variety of sources, including rivers, lakes, and groundwater. The source of your water can affect its quality. Groundwater is often cleaner than surface water, but it can be contaminated by leachate from landfills and other sources.

Source water assessment and its availability
Our water source assessment is available on request.

Why are there contaminants in my drinking water?
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some substances. The presence of a contaminant does not necessarily indicate that the water is unsafe to drink. Many contaminants in drinking water do not have health effects. Some contaminants in drinking water may be aesthetically objectionable such as chlorine or inorganic salts. Some inorganic substances, such as lead, can be harmful to health. Some organic substances, such as pesticides, can be harmful to health. All of these substances can be found in drinking water systems in Florida.

How can I get bottled?
Our water is tested for 17 metals every month at 500 points in the State Water Office. Our annual testing is in 14 months in April. The test time and place will be printed on your water bill. This is a very important testing and a source of our confidence in our water.

State Water Control Information
Write Director, Chief of Staff
P.O. Box 121
West Palm Beach, FL 33415

Additional Information for Lead										
Agency	Organic and Reactive Contaminants			Violations	Sample Date	Typical Source				
	MCGL	MCL	Year Water							
Alachua	10018	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Brevard	10019	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Collier	10020	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
DeSoto	10021	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Duval	10022	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Flagler	10023	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Franklin	10024	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Hardee	10025	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Highway	10026	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Madison	10027	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Polk	10028	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
St. Johns	10029	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				
Union	10030	2	2	0.010	May 11	Discharge from septic waste and rural septic tanks. Exposure of rural livestock.				

ACCOUNT NO.	SERVICE FROM	SERVICE TO
13-1302400	05/14	06/11

RETURN THIS STUB WITH PAYMENT TO:
SILOAM WATER ASSOCIATION
 P.O. BOX 204
 WEST POINT, MS 39073

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 26
 WEST POINT, MS

SERVICE ADDRESS
 13425 CUMMINGS RD

2012 JUL 2 AM 9:50

METER READINGS		
CURRENT	PREVIOUS	USED
6048	6024	24

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
20.00	07/15/2012	24.00
NET AMOUNT	SAVE THIS	GROSS AMOUNT
20.00	4.00	24.00

CHARGE FOR SERVICES

OFFICE CLOSED 7/4. CLR AVAIL
 IN OFFICE. WILL NOT BE MAILED

WTR 20.00
 NET DUE >>> 20.00
 SAVE THIS >> 4.00
 GROSS DUE >> 24.00

RETURN SERVICE REQUESTED

13-1302400
 WILLIE DAVENPORT
 13425 CUMMINGS
 CEDARBLUFF MS 39741