

**BUREAU OF PUBLIC WATER SUPPLY**

**CALENDAR YEAR 2011 CONSUMER CONFIDENCE REPORT  
CERTIFICATION FORM**

SUNRISE MOBILE HOME PARK  
Public Water Supply Name

0230057  
List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

*Please Answer the Following Questions Regarding the Consumer Confidence Report*

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper
- On water bills
- Other HAND DELIVERED

Date customers were informed: 7/1/12

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed:  / /

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published:  / /

CCR was posted in public places. *(Attach list of locations)*

BULLETIN BOARD  
LAUNDROMAT IN PARK

Date Posted: 7/1/12

CCR was posted on a publicly accessible internet site at the address: www. \_\_\_\_\_

**CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Daniel Brennan - Owner  
Name/Title (President, Mayor, Owner, etc.)

7-2-12  
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215  
Phone: 601-576-7518

CORRECTED COPY

# 2011 CONSUMER CONFIDENCE REPORT

## Is my water safe?

Sunrise Mobile Home & RV Park is pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Where does my water come from?

Our water comes from one 850 feet deep artesian well that draws from the Miocene Aquifer.

## Source water assessment and its availability

Sunrise Mobile Home & RV Park, as a Public Water Supply, is required to submit monthly bacteriological samples to the MS State Dept of Health. There have been no positive Total Coliform samples and our system has not violated any other maximum contaminant levels that are monitored by state and federal agencies. Copies of these reports are available at our office.

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

## How can I get involved?

Jeff and Dawn Brenegan manage Sunrise Mobile Home & RV Park and operate a private non-community water system. If you have any questions regarding your water service, quality, or any problem related to this water system, please contact the Brenegans at the phone number listed below, or at (228) 216-3643.

**\*\*\*\*A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. SUNRISE MOBILE HOME PARK is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

---

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TL, or		Low	High			
	MRDLG	MRDL	Water			Date		
<b>Inorganic Contaminants</b>								
Antimony (ppb)	6	6	0.5	NA		2011	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	NA		2011	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.0089	NA		2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	0.5	NA		2011	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.5	NA		2011	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	1.8	NA		2011	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.64	NA		2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.5	NA		2011	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	2.5	NA		2011	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA		2011	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Cyanide [as Free Cn] (ppb)	200	200	15	NA		2011	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories

Nitrate [measured as Nitrogen] (ppm)	10	10	0.18	NA		2011	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA		2011	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>Radioactive Contaminants</b>								
Radium (combined 226/228) (pCi/L)	0	5	0.521	NA		2011	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.067	NA		2011	No	Erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA		2011	No	Discharge from textile-finishing factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA		2011	No	Discharge from industrial chemical factories
Xylenes (ppm)	10	10	0.0005	NA		2011	No	Discharge from petroleum factories; Discharge from chemical factories
Dichloromethane (ppb)	0	5	0.5	NA		2011	No	Discharge from pharmaceutical and chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	NA		2011	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA		2011	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	NA		2011	No	Leaching from PVC piping; Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA		2011	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA		2011	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA		2011	No	Discharge from industrial chemical factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA		2011	No	Discharge from metal degreasing sites and other factories
Carbon Tetrachloride (ppb)	0	5	0.5	NA		2011	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	0.5	NA		2011	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA		2011	No	Discharge from metal degreasing sites and other factories

1,1,2-Trichloroethane (ppb)	3	5	0.5	NA	2011	No	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	0	5	0.5	NA	2011	No	Discharge from factories and dry cleaners
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA	2011	No	Discharge from chemical and agricultural chemical factories
Benzene (ppb)	0	5	0.5	NA	2011	No	Discharge from factories; Leaching from gas storage tanks and landfills
Toluene (ppm)	1	1	0.0005	NA	2011	No	Discharge from petroleum factories
Ethylbenzene (ppb)	700	700	0.5	NA	2011	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	NA	2011	No	Discharge from rubber and plastic factories; Leaching from landfills
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	1	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

### Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL or MRDL	Your Water	Violation	Typical Source
TTHMs [Total Trihalomethanes] (ppb)	NA	80	ND	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	ND	No	By-product of drinking water chlorination

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (ug/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

<b>Important Drinking Water Definitions</b>	
<b>Term</b>	<b>Definition</b>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Contact Name: DAWN or JEFF BRENEGAN  
 Address:  
 6033 DEAN RD  
 PEARLINGTON, MS 39572  
 Phone: (228) 533-7001  
 Fax: (228) 533-7645  
 E-Mail: sunriservp@yahoo.com

230057

# 2011 CONSUMER CONFIDENCE REPORT

## **Is my water safe?**

Sunrise Mobile Home & RV Park is pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Our water comes from one 850 feet deep artesian well that draws from the Miocene Aquifer.

## **Source water assessment and its availability**

Sunrise Mobile Home & RV Park, as a Public Water Supply, is required to submit monthly bacteriological samples to the MS State Dept of Health. There have been no positive Total Coliform samples and our system has not violated any other maximum contaminant levels that are monitored by state and federal agencies. Copies of these reports are available at our office.

## **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

## **How can I get involved?**



Jeff and Dawn Brenegan manage Sunrise Mobile Home & RV Park and operate a private non-community water system. If you have any questions regarding your water service, quality, or any problem related to this water system, please contact the Brenegans at the phone number listed below, or at (228) 216-3643.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. SUNRISE MOBILE HOME PARK is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG	MCL	Your Water	Range		Sample Date	Violation	Typical Source
	or MRDLG	TT or MRDL		Low	High			
<b>Organic Contaminants</b>								
Barium (ppm)	2	2	0.0089	NA		2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.64	NA		2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Nitrate [measured as Nitrogen] (ppm)	10	10	0.18	NA		2011	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA		2011	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Antimony (ppb)	6	6	0.5	NA		2011	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	NA		2011	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Beryllium (ppb)	4	4	0.5	NA		2011	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.5	NA		2011	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	1.8	NA		2011	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	15	NA		2011	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Mercury [Inorganic] (ppb)	2	2	0.5	NA		2011	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	2.5	NA		2011	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA		2011	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
<b>Radioactive Contaminants</b>								
Radium (combined 226/228) (pCi/L)	0	5	0.521	NA		2011	No	Erosion of natural deposits
Uranium (ug/L)	0	30	0.067	NA		2011	No	Erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
Toluene (ppm)	1	1	0.0005	NA		2011	No	Discharge from petroleum factories

Xylenes (ppm)	10	10	0.0005	NA		2011	No	Discharge from petroleum factories; Discharge from chemical factories
Benzene (ppb)	0	5	0.5	NA		2011	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	0.5	NA		2011	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA		2011	No	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	NA		2011	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA		2011	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA		2011	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA		2011	No	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA		2011	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA		2011	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	0.5	NA		2011	No	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	0	5	0.5	NA		2011	No	Discharge from industrial chemical factories
Ethylbenzene (ppb)	700	700	0.5	NA		2011	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	NA		2011	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	0.5	NA		2011	No	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA		2011	No	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA		2011	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	NA		2011	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA		2011	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	0.5	NA		2011	No	Leaching from PVC piping; Discharge from plastics factories

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	1	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

## Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL or MRDL	Your Water	Violation	Typical Source
Haloacetic Acids (HAA5) (ppb)	NA	60	ND	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	ND	No	By-product of drinking water disinfection

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (ug/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.