

2011 Annual Drinking Water Quality Report 2012 JUN 19 AM 7: 55
 Evergreen Water Association
 PWS#: 0540007 610007
 June 2012

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Evergreen Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact John Henry Brown, Sr. at 601.826.0368. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of the month at 6:00 PM at 670 Andrew Chapel Rd, Brandon, MS 39042.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	August	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment

Inorganic Contaminants

10. Barium	N	2010*	.002	.001 - .002	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010*	1.6	1.5 – 1.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2009/11	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2009/11	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2010*	6.37	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2011	1.9	1.1 – 2.1	ppm	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2011.

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During August 2011, we tested positive for a total coliform bacteriological sample(s). The law required that valid source water samples must be pulled within 24 hours when notified of a Total Coliform positive bacteriological sample. On August 26, 2011, we collected the source water samples in a timely manner, but due to a clerical error our system did not receive credit for the source water sample for the Ground Water Rule.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*****A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water suppliers were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The Evergreen Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2012 OCT -1 ANHO: 21

AFFIDAVIT

PROOF OF PUBLICATION

RANKIN COUNTY NEWS • P.O. BOX 107 • BRANDON, MS 39043

STATE OF MISSISSIPPI
COUNTY OF RANKIN

THIS 27TH DAY OF JUNE, 2012, personally came Marcus Bowers, publisher of the Rankin County News,

2011 Annual Drinking Water Quality Report
Evergreen Water Association
PWS# 0649001 610007
June 2012

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been provided to our public water system and is available for viewing upon request. The wells for the Evergreen Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact John Henry Brown, Sr. at 601 826-9388. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings they are held on the third Thursday of the month at 6:00 PM at 670 Andrew Chapel Rd, Brandon, MS 39042.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2011. In cases where monitoring wasn't required in 2011, the table reflects the most recent results. As water travels from the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Inorganic contaminants, such as nitrate and borate, that may come from sewage treatment plants, fertilizers, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, pesticides and herbicides, which may come from a variety of sources including agriculture, urban stormwater runoff, and residential use; organic chemical contaminants, including herbicides and insecticides from agricultural, industrial, and domestic wastewater discharges, oil and gas production, mining, pesticides and herbicides, which may come from gas synthesis and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations and mobile vehicle emissions, radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining operations and mobile vehicle emissions, radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water supplied by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGL as is technically feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Pico per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000,000.

Parts per billion (ppb) or Micrograms per liter (µg/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000,000.

Contaminant	Violation Yes/No	Date Detected	Level Detected	Range of Detects at All Sampling Locations	Unit	MCLG	MCL	Likely Source of Contaminant
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	August	Monitoring	HA	0	0	presence of coliform bacteria in 5% of monthly samples	Sanitary Effect on the Environment
Inorganic Contaminants								
10. Boron	N	10/10	0.02	0.01 - 0.02	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	20/10	1.8	1.5 - 1.8	ppm	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	20/04/11	1	0	ppm	1.5	AL=1.5	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	10/08/11	2	0	ppm	0	AL=1.5	Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products								
21. THM5 (Total Trihalomethanes)	N	20/10	0.37	No Range	ppm	0	80	By-product of drinking water disinfection
Chlorine	N	20/11	1.9	1.1 - 2.1	ppm	0	MRDL = 4	Water additive used to control microbes

¹ Most recent sample. No sample required for 2011.

Microbiological Contaminants: All total coliform bacteria are harmful, present in the environment and used as an indicator of other, potentially harmful, bacteria. The presence of coliform bacteria is not a health risk but it is a warning of potential problem.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During August 2011, we tested positive for a total coliform bacteriological sample(1). The test required that our source water samples be held in the dark for 24 hours before a Total Coliform positive bacteriological sample. On August 26, 2011, we collected the source water samples in a timely manner, but due to a clerical error our system did not receive consent for the source water samples for the Ground Water Rule.

Exposure to elevated levels of lead can cause various health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components such as service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/lead. For more information on lead in drinking water, please contact the Mississippi State Department of Health Public Health Laboratory office lead testing. Please contact us at 601 536 1553 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be inorganic, inorganic or organic chemicals and radioactive substances. In drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1 800 426 4731.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as patients with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some infants, and certain elderly are at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1 800 426 4731.

***** MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING *****
In accordance with the Maximum Residual Disinfectant Rule, all community public water suppliers were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply complied sampling by the scheduled deadline. However, during an audit of the Mississippi Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) requested analysis and reporting of radiological compliance samples and results until further notice. Although this was not the result of action by the public water supply, MSDH was required to issue a violation. This is hereby notified that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601 536 1518.

The Evergreen Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, for way of the future and our children's future.

2011 DRINKING WATER QUALITY REPORT
EVERGREEN WATER ASSOCIATION

a copy of which is hereto attached, was published in said newspaper One (1) week, as follows, to-wit:

Vol 164 No. 49 on the 27th day of June, 2012

Marcus Bowers
MARCUS BOWERS, Publisher

Sworn to and subscribed before me by the aforementioned Marcus Bowers this 27th day of June, 2012

Frances Conger, Notary Public
FRANCES CONGER
My Commission Expires: January 25, 2014

PRINTER'S FEE:
3 columns by 10 inches at \$7.00 per column inch..... \$283.50
Proof of Publication..... 3.00
TOTAL..... \$286.50

