

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

2013 MAY 14 AM 8:31

TOWN OF SEMINARY
Public Water Supply Name

0160006

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 5 / 8 / 2013 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: _____ / /

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: THE NEWS-COMMERCIAL

Date Published: 5 / 8 / 2013

CCR was posted in public places. *(Attach list of locations)* Date Posted: _____ / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Billy D. Karolyn, Mayor
Name/Title (President, Mayor, Owner, etc.)

5/13/2013

Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

RECEIVED-WATER SUPPLY
2013 APR 23 PM 3:47

2012 Annual Drinking Water Quality Report
Town of Seminary
PWS#: 0160006
April 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Seminary have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Billy D. Karolyi, Mayor at 601-722-9426. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the Seminary Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2011*	.004	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

14. Copper	N	2009/11*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2011*	62	No Range	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2011*	.412	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Volatile Organic Contaminants

76. Xylenes	N	2012	.002	.0006 - .002	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	------	--------------	-----	----	----	---

Disinfection By-Products

81. HAA5	N	2011*	30	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2011*	40	No Range	ppb	0	80	By-product of drinking water disinfection.
Chlorine	N	2012	1.6	1.21 – 2	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2012.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*****April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Town of Seminary works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2012 Annual Drinking Water Quality Report
Town of Covington
P.O. Box 1000
Covington, MS 38930

We're pleased to present to you this year's Annual Quality Water Report. This report is prepared to provide you with the quality and safety of the water you use. Our contract with you is to provide you with safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process. The Covington Water Treatment Plant is operated by the Covington Water Utility, a public utility. The report is prepared by the Covington Water Utility, a public utility. The report is prepared by the Covington Water Utility, a public utility.

The water we deliver has been tested for over 100 different substances to ensure the overall safety of the water supply. We have tested for over 100 different substances to ensure the overall safety of the water supply. We have tested for over 100 different substances to ensure the overall safety of the water supply.

If you have any concerns about the report or concerning your water, please contact the City of Covington at 662-722-2222. We want to hear from you. We want to hear from you. We want to hear from you. We want to hear from you. We want to hear from you.

We highly monitor for contaminants in your drinking water according to Federal and State laws. The same laws that protect you from contaminants in your drinking water also protect you from contaminants in your drinking water. The same laws that protect you from contaminants in your drinking water also protect you from contaminants in your drinking water.

In this report you will find many facts and information you might not be familiar with. We will continue to provide you with the best water possible. We will continue to provide you with the best water possible. We will continue to provide you with the best water possible.

TEST RESULTS									
Contaminant	Maximum Allowable Concentration (MACCL)	Date Collected	Level Detected	Range of All Samples	MACCL	MSD	MSD	MSD	MSD
Inorganic Contaminants									
42. Calcium	175	05/11/13	100	80-120	175	0.05	0.05	0.05	0.05
43. Copper	1.3	05/11/13	0.2	0.1-0.3	1.3	0.01	0.01	0.01	0.01
44. Lead	0.01	05/11/13	0.005	0.002-0.008	0.01	0.01	0.01	0.01	0.01
Volatile Organic Compounds									
45. Toluene	0.1	05/11/13	0.05	0.02-0.08	0.1	0.01	0.01	0.01	0.01
Disinfection By-Products									
46. THM5	0.1	05/11/13	0.05	0.02-0.08	0.1	0.01	0.01	0.01	0.01
47. Haloacetic Acids	0.1	05/11/13	0.05	0.02-0.08	0.1	0.01	0.01	0.01	0.01

Water disinfection is essential to public health. As you know, the health of our citizens is our top priority. We have tested our water for disinfection byproducts. We have tested our water for disinfection byproducts. We have tested our water for disinfection byproducts.

We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts.

If present, elevated levels of these disinfection byproducts can cause health problems. We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring in their source. We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts.

Some people may be more vulnerable to contaminants in drinking water than the general population. We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts.

As of April 1, 2012, the Mississippi State Department of Health (MSDH) has updated its list of disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts.

The Town of Covington would like to thank you for your interest in our water. We are required to monitor your drinking water for specific disinfection byproducts. We are required to monitor your drinking water for specific disinfection byproducts.

Publish one time: May 8, 2013

Proof of Publication

STATE OF MISSISSIPPI
COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority, in and for said County and State, Analyn Arrington Goff, Publisher of THE NEWS-COMMERCIAL, a newspaper published in Collins, said County, who being duly sworn, says the publication of a certain notice, a true copy of which is hereto attached, was made in said paper on the hereinafter dates, as follows, to-wit:

RECEIVED - WATER SUPPLY
2013 MAY 14 AM 8:31

Vol. 111 No. 43 Dated May 8, 2013

Vol. No. Dated

Vol. No. Dated

Vol. No. Dated

Analyn A. Goff Publisher

Sworn to and subscribed before me, this the 8 day of May, 2013.

James Arrington Goff Notary Public

Printer's Fee \$ 180.00

Proof of Publication \$ 3.00

TOTAL \$ 183.00



Please Fold Open
LEGAL Inside