

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

2013 JUN -6 AM 9: 21

Town of Terry

Public Water Supply Name

0250025

PWS ID # ('s):

The Federal Safe Drinking Water Act requires each Community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- E-mail message (MUST Email the message to the address below)
- Other _____

Date customers were informed: 5/20/2013 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date mailed/distributed: ~~APR~~ / /

CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: Hinds Co. Gazette

Date Published: May 23 2013

CCR was posted in public places. *(Attach list of locations)* Date posted: 5/10/2013

CCR was posted on a publicly accessible internet site at the address: **(DIRECT URL REQUIRED):** City HALL

CERTIFICATION:

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Roderick J. Nichol, Mayor
Name/Title (President, Mayer, Owner, etc.)

6-5-13
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Bayette
Signature

5-3-13
Date

**Deliver or send via U. S. Postal Service:
Bureau of Public Water Supply
P O Box 1700
Jackson, MS 39215**

**May be faxed to:
(601) 576-7800**

**May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us**

Annual Drinking Water Quality Report 2013 JUN 13 AM 9: 05*Town of Terry**PWS ID #0250025**May, 2013****CORRECTED REPORT***

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Forest Hill Aquifer.

A source water assessment has been completed for the Town of Terry's water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of Terry received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mary Smith at 601-878-5521. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at Terry Town Hall at 7:00 p.m.

The Town of Terry routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*****APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Terry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the newspaper will not be mailed. Please call our office if you would like a copy or have questions.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	Oct	Pos	One		0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Inorganic Contaminants								
10. Barium	N		0.00404	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N		0.204	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011*	3	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	Y	Oct	0.80	0.40 to 1.90	ppm	4	4	Water additive used to control microbes
73. TTHM [Total trihalomethanes]	N	2011*	16.57	None	ppb	0	80	By-product of drinking water chlorination
HAA5 [Halocetic Acids]	N	2011*	12	None	ppb	0	60	By-product of drinking water chlorination

* *Most recent sample results available*

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Monitoring Violation:

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During October 2012 1 routine bacteriological sample(s) tested positive for total coliform. The law requires that valid re-samples be collected for each positive routine sample within 24 hours. We collected the required re-samples in a timely manner, but due to a clerical error the sample paperwork was improperly completed. This caused our system to not receive credit for the three re-samples collected. Also we are required to collect chlorine samples on each bacteriological compliance sample. We did not complete all chlorine sampling during that time, therefore we cannot be sure of the quality of our drinking water during that time.

Annual Drinking Water Quality Report 2013 JUN -6 AM 9: 21*Town of Terry**PWS ID #0250025**May, 2013*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Forest Hill Aquifer.

A source water assessment has been completed for the Town of Terry's water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of Terry received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mary Smith at 601-878-5521. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at Terry Town Hall at 7:00 p.m.

The Town of Terry routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	Oct	Pos	One		0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Inorganic Contaminants								
10. Barium	N	2011*	0.02	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2011*	2.10	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	0.164	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011*	3	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	Y	Oct	0.80	0.40 to 1.90	ppm	4	4	Water additive used to control microbes
73. TTHM [Total trihalomethanes]	N		16.57	None	ppb	0	80	By-product of drinking water chlorination
HAA5 [Halocetic Acids]	N		12	None	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Monitoring Violation:

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During October 2012 1 routine bacteriological sample(s) tested positive for total coliform. The law requires that valid re-samples be collected for each positive routine sample within 24 hours. We collected the required re-samples in a timely manner, but due to a clerical error the sample paperwork was improperly completed. This caused our system to not receive credit for the three re-samples collected. Also we are required to collect chlorine samples on each bacteriological compliance sample. We did not complete all chlorine sampling during that time, therefore we cannot be sure of the quality of our drinking water during that time.

*****APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Terry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the newspaper will not be mailed. Please call our office if you would like a copy or have questions.

2013 JUN -6 AM 9: 22

STATE OF MISSISSIPPI)
)
COUNTY OF HINDS)

PERSONALLY CAME before me, a notary public in and for the State of Mississippi at Large, the CLERK of the *HINDS COUNTY GAZETTE*, a newspaper published in the City of Raymond, Second Judicial District of Hinds County, in said state, who being duly sworn, deposes and says that the *HINDS COUNTY GAZETTE* is a newspaper as defined and prescribed in the Mississippi Code of 1972, and the publication of a notice of which the annexed is a copy, in the matter of:

Annual Drinking Water Quality Report
Town of Terry
PWS ID# 0250025

Has been made in said paper 1 times consecutively, to-wit:


On the 23 day of May, 2013
On the _____ day of _____, 2013
On the _____ day of _____, 2013
On the _____ day of _____, 2013

SWORN TO and SUBSCRIBED before me, this

23 day of May, 2013

Mary Ann Keith
Notary Public

Heather Rupton
Clerk



66 HINDS COUNTY GAZETTE Dr.

TO PUBLISHING _____

Case of _____

Word space _____ Weeks _____ Proof Charge \$3.00 - Total \$ _____

RECEIVED OF _____

Check No. _____ Date _____

Annual Drinking Water Quality Report
Town of Terry
PWS ID #0250025
May, 2013

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Forest Hill Aquifer.

A source water assessment has been completed for the Town of Terry's water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of Terry received a low susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mary Smith at 601-878-5521. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at Terry Town Hall at 7:00 p.m.

The Town of Terry routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS									
Contaminant	Violation	Unit	Level	Range of Values	Unit	Level	Unit	Level	1) Method of Contamination
Microbiological Contaminants									
1. Total Coliform Bacteria	Y	Col	500	None	ppm	0	0	0	presence of coliform bacteria in the water supply
Inorganic Contaminants									
10. Nitrate	N	mg/L	10.0	No Range	ppm	0	0	0	leachate of nitrate from water supply
13. Chloride	N	mg/L	2.0	No Range	ppm	100	100	100	leachate of nitrate from water supply
14. Copper	N	mg/L	0.1	None	ppm	1.3	1.3	1.3	leachate of copper from water supply
16. Fluoride	N	mg/L	0.14	No Range	ppm	1	1	1	leachate of fluoride from water supply
17. Lead	N	mg/L	1	None	ppm	0	0	0	leachate of lead from water supply
Disinfectants & Disinfection By-Products									
Chlorine (as Cl ₂)	Y	mg/L	0.80	0.40 to 1.00	ppm	1	1	1	chlorine used in water treatment
7. Trihalo Methane (THM)	N	mg/L	16.57	None	ppm	0	0	0	by-product of chlorine disinfection
HAAs (Halogeno Acids)	N	mg/L	12	None	ppm	0	0	0	by-product of chlorine disinfection

*All values comply with standards.

Microbiological Contaminants:

(1) Total Coliform, Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in most samples that allowed and this was a warning of potential problems.

Monitoring Violation:

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During October 2012 1 routine bacteriological sample(s) tested positive for total coliform. The law requires that valid re-samples be collected for each positive routine sample within 24 hours. We collected the required re-samples in a timely manner, but due to a clerical error the sample paperwork was improperly completed. This caused our system to not receive credit for the three re-samples collected. Also we are required to collect chlorine samples on each bacteriological compliance sample. We did not complete all chlorine sampling during that time, therefore we cannot be sure of the quality of our drinking water during that time.

*******APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline, however, during an audit of the Mississippi State Department of Health, Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7515.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Terry is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the newspaper will not be mailed. Please call our office if you would like a copy or have questions.



TOWN OF TERRY WATER DEPARTMENT
 PO BOX 327
 TERRY, MS 39170
 (601) 878-5521

FIRST-CLASS MAIL
 U.S. FIRST CLASS POSTAGE PAID

US POSTAGE
 PAID
 TERRY MS
 PERMIT NO. 4

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]

CUSTOMER		PAY GROSS AMOUNT	
ROUTE	ACCT NO.	DATE	DATE
[REDACTED]	[REDACTED]	[REDACTED]	[REDACTED]
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID	
[REDACTED]		[REDACTED]	

MAIL THIS STUB WITH YOUR PAYMENT

ACCOUNT 957 5/23/13

METER READ			TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY	CLASS			
7	4	4	[REDACTED]	10.00	[REDACTED]

CW & W CONTRACTORS
 CALLIE
 LA 0

DUE TO THE ELECTION JUNE 04, Board IS JUNE 06, 2013 AT 7:00 pm.
A COPY OF THE CCR CONCERNING TERRY WATER WILL BE POSTED AT CITY HALL FOR YOUR REVIEW.
 Fire Station Bldg almost completed. The Springfling was a success
 The New Fred's Dollar Store is under construction.