

MISSISSIPPI STATE DEPARTMENT OF HEALTH 2010 JUN 13 PM 3:41
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

Okatoma Water Association, INC. #1 & #2
 Public Water Supply Name

MS0640009

MS0640022

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
 On water bills (attach copy of bill)
 Email message (MUST Email the message to the address below)
 Other _____

Date(s) customers were informed: 04 / 25 / 2013, 04 / 24 / 2013, 04 / 24 / 2013

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: _____ / _____ / _____
 As a URL (Provide URL _____)
 As an attachment
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Magee Courier, Smith County Reformer, The News Commercial

Date Published: 04/25/2013 04/24/2013 04/24/2013

CCR was posted in public places. *(Attach list of locations)* Date Posted: _____ / _____ / _____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


 Name/Title (President, Mayor, Owner, etc.)

6-11-13
 Date

Deliver or send via U.S. Postal Service:
 Bureau of Public Water Supply
 P.O. Box 1700
 Jackson, MS 39215

May be faxed to:
 (601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

Radioactive Contaminants

6. Radium 228	N	2012	2.3	1.1 – 2.3	pCi/L	0	5	Erosion of natural deposits
---------------	---	------	-----	-----------	-------	---	---	-----------------------------

Inorganic Contaminants

8. Arsenic	N	2010*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2010*	.024	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride**	N	2010*	.79	.5 - .79	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2012	5.5	2.01 – 5.5	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2010*	.2	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

Chlorine	N	2012	1	.60 – 1.10	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	---	------------	------	---	----------	-----------------------------------------

PWS ID # 0640022

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	--------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2010*	.021	.014 - .021	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride**	N	2010*	.79	.63 - .79	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2012	1.36	.34– 1.36	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2010*	.7	.1 - .7	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2010*	7.49	2.27	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2012	1	.70 – 1.2	mg/l	0	MDRL = 4	Water additive used to control microbes

* *Most recent sample. No sample required for 2012*

** *Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.*

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the OKATOMA WATER ASSOCIATION #1 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 57%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the OKATOMA WATER ASSOCIATION #2 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 53%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

*******April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

****** Special Notice Concerning Nitrate Sample Results******

The nitrate samples for Okatoma Water Association #1 (PWSID MS 0640009) ranged from 2.0 ppm to 5.5 ppm during 2012. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

The Okatoma Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please Note: this report is being published in the local newspaper, copies will not be mailed unless requested.

The State of Mississippi,
County of Smith

PERSONALLY CAME before me, the undersigned a Notary Public in and for SMITH COUNTY, MISSISSIPPI the OFFICE CLERK of the SMITH COUNTY REFORMER, a newspaper published in the Town of Raleigh, Smith County, in said State, who being duly sworn, deposes and says that the SMITH COUNTY REFORMER is a newspaper as defined and prescribed in §13-3-31 of the Mississippi Code 1972 Annotated and that the publication of a notice, of which the annexed is a copy, in the matter of

2012 Annual Drinking Water Report

has been made in said paper 1 times consecutively, to-wit:

On the 24 day of April
On the ___ day of ___
On the ___ day of ___
On the ___ day of ___

RECEIVED - WATER SUPPLY
2013 JAN 13 PM 3:42

Paul Turner
OFFICE CLERK

SWORN to and subscribed before me,

this the 25th
day of April 2013

Nelissa Ferrara
NOTARY PUBLIC
No 89914
Comm Expires June 17, 2014
STATE OF MISSISSIPPI
RANKIN COUNTY

2011

We're pleased to present to you this year's Annual Report and services we deliver to you every day. Our constant goal is to provide you with a safe and reliable water supply to continually improve the water treatment process and protect our water resources. We are proud of the Catahoula, Miocene and Citronelle Aquifers.

The source water assessment has been completed to identify potential sources of contamination. A report containing detailed information for public water system and is available for viewing upon request. The wells for the Okatoma Aquifer.

If you have any questions about this report or our valued customers to be informed about their water utility. If you want to learn more, please call the month at 7:00 PM at 1970 SCR 45, Mt. Olive, MS 39119.

We routinely monitor for constituents in your water that we detected during the period of January 1st to December 31st. As water travels over the surface of land or underground, it dissolves naturally occurring contaminants from the presence of animals or from human activity; microbial contaminants, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and minerals, agricultural or domestic wastewater discharges, oil and gas production, mining or farming; petroleum production, and can also come from gas stations and septic systems; radioactive and mining activities. In order to ensure that our water is safe to drink, EPA requires public water systems. All drinking water, including bottled water, should be treated to minimize lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing services.

To comply with the "Regulation Governing Fluoridation of our water system. The number of fluoride samples collected during the period of January 1st to December 31st was 10. The percentage of fluoride samples collected that were within the optimal range of 0.7-1.3 ppm was 100%.

All sources of drinking water are subject to contamination. Contaminants can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water should be treated to minimize health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-424-9303.

Some people may be more vulnerable to contamination than others. As persons with cancer undergoing chemotherapy, persons who have undergone organ transplantation, and persons who are immunocompromised can be particularly at risk from infections. These people should seek advice about drinking water and other microbiological contaminants are available from the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-424-9303.

The Okatoma Water Association, Inc. works to help us protect our water sources, which are the heart of our community, our way of life.

In accordance with the Radionuclides Rule promulgated by the Environmental Protection Agency (EPA) in 1991, the public water supply completed sampling for radionuclides during January 2007 - December 2007. Your health Radiological Health Laboratory, the Environmental Protection Agency (EPA) notified you of the results of the sampling. Although this was not the result of inaction by the public water supply, MSDP has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. For more information, contact the Bureau of Public Water Supply, at 601.576.7518.

The nitrate samples for Okatoma Water Association are at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels can also occur after short periods of time because of rainfall or agricultural activity. If you are caring for a child under the age of six months, please contact the Okatoma Water Association, Inc. to help us protect our water sources, which are the heart of our community, our way of life.

Please Note: This report is being published in the SMITH COUNTY REFORMER.

y'all. church and said for me to remind her that she had something for me. She would not tell me what it was. When we got to church and lots of folks were there I asked her what did she have for me. She said I don't want to give this to you, but here goes. She gave me a great big kiss on the cheek. I wiped it off as fast as I could and made an ugly face. She said Troy Puckett sent it to me. I told her to come back and put it back on when I heard who it was from. She did not. I hope everyone has another great week.

RECEIVED-WATER SUPPLY DEPT JUN 13 PM 3:12

2012 ANNUAL DRINKING WATER QUALITY REPORT OKATOMA WATER ASSOCIATION, INC. PWS#: 0640009 & 0640022 April 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment processes and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula, Miocene and Citronelle Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Okatoma Water Association have received a lower to higher susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael Speed at 601.733.2363. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 7:00 PM at 1970 SCR 45, Mt. Olive, MS 39119.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0640009		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Radium 228	N	2012	2.1	1.1 - 2.1	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2010*	6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass & electronics production waste
10. Borium	N	2010*	.024	No Range	ppm	2	2	Discharge of drilling waste; discharge from metal ref.; erosion of natural deposits
16. Fluoride	N	2010*	.79	.5 - .79	ppm	4	4	Erosion of nat. dep.; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits.
19. Nitrate (Nitrogen)	N	2012	5.5	2.01 - 5.5	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.
21. Selenium	N	2010*	2	No Range	ppb	50	50	Discharge from petroleum & metal refineries; erosion of natural deposits; discharge from mines

21 Selenium	N	2010*	2	No Range	ppb	50	50	Discharge from petroleum & metal refineries, erosion of nat. dep., discharge from mines.
Disinfection By-Products								
Chlorine	N	2012	1	60 - 1.10	mg/l	0	MDRL-4	Water additive used to control microbes.
PWS ID # 0640022 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10 Barium	N	2010*	.021	.014 - .021	ppm	2	2	Discharge of drilling wastes; discharge from metal ref.; erosion of natural dep.
16 Fluoride	N	2010*	79	63 - 79	ppm	4	4	Erosion of nat. dep., water additive which promotes strong teeth; discharge from fertilizer & aluminum factories.
17 Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits.
19 Nitrate (as Nitrogen)	N	2012	1.36	.34 - 1.36	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
21 Selenium	N	2010	.7	1 - .7	ppb	50	50	Discharge from petroleum & metal refineries, erosion of nat. dep., discharge from mines.
Disinfection By-Products								
82 THM (Total trihalomethanes)	N	2010*	7.49	2.27	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2012	1	70 - 1.2	mg/l	0	MDRL-4	Water additive used to control microbes.

*Most recent sample. No sample required for 2012.

**Fluoride level is routinely adjusted to the MS State Dept. of Health's recommended level of 0.7 - 1.3 mg/l.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the OKATOMA WATER ASSOCIATION #1 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 - 1.3 ppm was 57%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Okatoma Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

******April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result on inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

******SPECIAL NOTICE CONCERNING SAMPLE RESULTS******

The nitrate samples for Okatoma Water Association #1 (PWSID MS 0640009) ranged from 2.0 ppm during 2012. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

The Okatoma Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please Note: This report is being published in the local newspaper, copies will not be mailed unless requested.

11
ada

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI
COUNTY OF SIMPSON

Personally appeared before me, the undersigned Notary Public in and for the County and State aforesaid Margaret Brown who being by me duly sworn states on oath, that she is Advertising of The Magee Courier a newspaper published in the City of Magee, State and County aforesaid, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 times, as follows:

- In Vol. 115 No. 47 Date 25th day of April 2013.
- In Vol. _____ No. _____ Date _____ day of _____ 2013.
- In Vol. _____ No. _____ Date _____ day of _____ 2013.
- In Vol. _____ No. _____ Date _____ day of _____ 2013.
- In Vol. _____ No. _____ Date _____ day of _____ 2013.
- In Vol. _____ No. _____ Date _____ day of _____ 2013.

Signed _____

Sworn to and subscribed before me, this 15 day of May

Notary Public

My Commission Expires: _____



No. words _____ at _____ cts. Total \$ \$650⁰⁰

Proof of Publication : \$ \$3⁰⁰

Total Cost: \$ \$653⁰⁰

2012 Annual Drinking Water Quality Report

Okatoma Water Association, Inc. PWS#: 0640009 & 0640022 April 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Calhoun, Micoone and Citronelle Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Okatoma Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael Speed at 601.7332363. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 1970 SCR 45, Mt. Olive, MS 39119.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:
Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0640009		TEST RESULTS							
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Radioactive Contaminants									
6. Radium 226	N	2012	2.3	1.1 - 2.3	pCi/L	0		5	Erosion of natural deposits
Inorganic Contaminants									
8. Arsenic	N	2010*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	
10. Barium	N	2010*	.024	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
16. Fluoride**	N	2010*	.79	5 - .79	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
19. Nitrate (as Nitrogen)	N	2012	5.5	2.01 - 5.5	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
21. Selenium	N	2010*	.2	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines	
Disinfection By-Products									
Chlorine	N	2012	1	.60 - 1.10	mg/l	0	MDRL = 4	Water additive used to control microbes	

PWS ID # 0640022		TEST RESULTS							
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Inorganic Contaminants									
10. Barium	N	2010*	.021	.014 - .021	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
16. Fluoride**	N	2010*	.79	.63 - .79	ppm	4	4	Erosion of natural deposits; water additive which promotes strong	

metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

Chlorine	N	2012	1	.60 - 1.10	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	---	------------	------	---	----------	-----------------------------------------

PWS ID # 0640022

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2010*	.021	.014 - .021	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride**	N	2010*	.79	.63 - .79	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2012	1.36	.34- 1.36	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2010*	.7	.1 - .7	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. THM (Total trihalomethanes)	N	2010*	7.49	2.27	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2012	1	.70 - 1.2	mg/l	0	MDRL = 4	Water additive used to control microbes

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water is SAFE at these levels. We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Enforcing Fluoridation of Community Water Supplies", the OKLAHOMA WATER ASSOCIATION #1 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 80. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 was 57%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the OKLAHOMA WATER ASSOCIATION #2 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 was 53%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. These include: pregnant women, infants and young children, people with certain chronic diseases, people who take certain medications, people with kidney disease, and people who are immunocompromised. These people should consult with their health care providers, EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants, or available from the Safe Drinking Water Hotline 1-800-426-4791.

****APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING****

In accordance with the Radon rule, all community public water supplies were required to sample quarterly for radon starting beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline, however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analysis and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.3518.

****SPECIAL NOTE CONCERNING NITRATE SAMPLE RESULTS****

The nitrate samples for Oklahoma Water Association #1 (PWSID MS-0640022) ranged from 2.99 ppm to 5.4 ppm during 2012. Nitrate in drinking water at levels above 10 ppm is a health risk for infants less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may increase quickly in short periods of time because of agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

The Oklahoma Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please Note: this report is being published in the local newspaper, copies will not be mailed unless requested.

Proof of Publication

STATE OF MISSISSIPPI
COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority, in and for said County and State, **Analyn Arrington Goff**, Publisher of **THE NEWS-COMMERCIAL**, a newspaper published in Collins, said County, who being duly sworn, says the publication of a certain notice, a true copy of which is hereto attached, was made in said paper on the hereinafter dates, as follows, to-wit:

Vol. 111 No. 41 Dated April 24, 2013
Vol. _____ No. _____ Dated _____
Vol. _____ No. _____ Dated _____
Vol. _____ No. _____ Dated _____

Analyn A. Goff Publisher

Sworn to and subscribed before me, this the 24 day of
April, 2013.

James Arrington Goff Notary Public

Printer's Fee \$ 318.50
Proof of Publication \$ 3.00
TOTAL \$ 321.50



We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula, Micoons and Oklawaha Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Oklahoma Water Association have received a lower to higher susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael Speed at 601.733.2303. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 7:00 PM at 1070 SCR 45, Mt. Olive, MS 39118.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, toxic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/L) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0640009 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AOL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	------------------	------	-----	--------------------------------

Radioactive Contaminants

Radium 226	N	2012	7.3	1 - 7.3	pCi/L	0	0	Emission of natural uranium
------------	---	------	-----	---------	-------	---	---	-----------------------------

Inorganic Contaminants

Ammonia	N	2012	5	No Range	ppm	0.5	10	Emission of natural deposits runoff from sewards, runoff from pipes and septic tank production wastes
Barium	N	2012	0.4	No Range	ppm	2	2	Discharge of drilling muds discharge from metal refineries, emission of natural deposits
Bromine	N	2012	76	5 - 76	ppm	4	4	Emission of natural deposits water addition which penetrates along with discharge from refineries and aluminum facilities
Calcium	N	2012	1	0	ppm	0	15	Corrosion of brass and plumbing systems, emission of natural deposits
Chloride as ion	N	2012	5.5	2.01 - 5.5	ppm	15	10	Run off from highway use, leaching from septic tanks, average amount of total dissolved
Fluoride	N	2012	3	No Range	ppm	30	30	Discharge from petroleum and metal refineries, emission of natural deposits, discharge from mines

Disinfection By-Products

Chlorine	N	2012	4	30 - 110	mg/L	0	MRDL = 4	Water disinfect used to control microbes
----------	---	------	---	----------	------	---	----------	------------------------------------------

PWS ID # 0640022 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AOL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	------------------	------	-----	--------------------------------

Inorganic Contaminants

Ammonia	N	2012	0.21	0.14 - 0.21	ppm	2	2	Discharge of drilling muds discharge from metal refineries, emission of natural deposits
Barium	N	2012	79	0.3 - 79	ppm	4	4	Emission of natural deposits water addition which penetrates along with discharge from refineries and aluminum facilities
Bromine	N	2012	1	0	ppm	0	15	Corrosion of brass and plumbing systems, emission of natural deposits
Calcium as Calcium	N	2012	1.30	0.1 - 1.30	ppm	0	10	Runoff from agriculture leaching from septic tanks, average amount of natural deposits
Fluoride	N	2012	1	1	ppm	0	50	Discharge from petroleum and metal refineries, emission of natural deposits, discharge from mines

Disinfection By-Products

Total Trihalomethanes	N	2012	7.40	1.27	ppm	0	0	Byproduct of drinking water disinfection
Chlorine	N	2012	1	30 - 110	mg/L	0	MRDL = 4	Water disinfect used to control microbes

* Most recent sample. No sample required for 2012
 ** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/L

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSUH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadwaterlead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7882 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the OKATOMA WATER ASSOCIATION #1 is required to report results...