

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

2013 JUN 19 AM 9:35

Kokomo Shiloh Water Association
Public Water Supply Name

0460014

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
 On water bills (attach copy of bill)
 Email message (MUST Email the message to the address below)
 Other _____

Date(s) customers were informed: 6/6/2013 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___ / ___ / ___
 As a URL (Provide URL _____)
 As an attachment
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Columbian Progress

Date Published: 6/06/2013

CCR was posted in public places. *(Attach list of locations)* Date Posted: ___ / ___ / ___

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):

CERTIFICATION

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Daniel R. Woodard Cert. Operator
Name/Title (President, Mayor, Owner, etc.)

6/17/2013
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2013 JUN -5 PM 12: 16

2012 Annual Drinking Water Quality Report
Kokomo-Shiloh Water Association
PWS#: 0460014
June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Citronelle Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Kokomo-Shiloh Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact David R. Woodward at 601.441.2040. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:00 PM at the water office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants

10. Barium	N	2012	.025	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2012	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012	.81	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
19. Nitrate (as Nitrogen)	N	2012	.34	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

Chlorine	N	2012	1	.8 – 1.1	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	---	----------	------	---	----------	---

** Most recent sample. No sample required for 2012*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the KOKOMO-SHILOH WATER ASSN. is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 3. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 75%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*****April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Kokomo-Shiloh Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

**THE STATE OF MISSISSIPPI
COUNTY OF MARION**

Personally appeared before me, the undersigned Notary Public, in and for the County and State aforesaid, **Susan Amundson** who being by me and duly sworn, states on oath that she is Legal Clerk of the Columbian-Progress, a newspaper published in the City of Columbia, State and County, aforesaid, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 time(s), as follows:

In Vol. 111 No. 45 Date 6 day of June, 2013

In Vol. 111 No. _____ Date _____ day of _____, 2013


In Vol. 111 No. _____ Date _____ day of _____, 2013

In Vol. 111 No. _____ Date _____ day of _____, 2013

Signed Susan Amundson
Susan Amundson

Sworn to and subscribed before me, this 6 day of June, 2013.

Bonnie Hudson
Bonnie Hudson, Notary Public



See attached

(SEAL)

3 x 14 @ \$10.50 = \$44.00
No. words _____ at _____ Total \$ _____

Proof of Publication \$3.00

Total Cost..... \$ 444.00

THIS IS NOT A STATEMENT

PRCC announces spring graduates

Special to
The Columbian-Progress

Pearl River Community College awarded degrees and certificates during commencement exercises on May 15 at the James Lynn Cartledge Forrest County Multi Purpose Center in Hattiesburg.

Graduates who completed their course work in the past year received the associate in arts degree, the associate in applied science degree or the certificate of proficiency.

From Columbia: Shirley A. Boyd, Paige L. Brown, Shirley Michelle Brown, Sean William Everhart, Dinah

Louise Flowers, Marques J. Zacherly Deron Saulters, Camen Denise Scooby, Tanya Lynn Stevens, Joseph L. Thompson, Jana E. Tolar. From Foxworth: Whitney Marie Armstrong, Erin N. Ballew, Brittany E. Farris, Brandon D. Fisher, Joshua Luke Hall, Tiffany Leann Hieks, Zikoya Johnson, Henry A. Pittman, Shannon L. Rose, Alex M. Singley, Dany Paul Smith, Jasper L. Stringer, Russell James Thomas, Ashley N. Wells, Ethan R. Whaley, Tiffany Wheat. From Kokomoe: Suzette Nercelia Andrews, Autumn Batie, Clinton A. Hammond, Nicholas Adam Sanders, Brittany G. Lewis.

2012 Annual Drinking Water Quality Report Kokomo-Shiloh Water Association PWS# 0460014 June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Columbia Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to develop potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Kokomo-Shiloh Water Association have received best susceptibility ratings to contamination.

If you have any questions about the report or contacting your water utility, please contact David R. Woodruff at 601-441-2040. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:00 PM at the water office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, effluent, or runoff from urban stormwater runoff, irrigation, or domestic wastewater, septic tanks, or other animal production, including farm animals, which are by-products of agricultural processes and petroleum production, and can also come from gas stations and septic systems. Radioactive contaminants, which can be produced naturally or by the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA has established regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not necessarily take into account the benefits that the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000,000.

TEST RESULTS									
Contaminant	Violation year	Date collected	Level Detected	Range of Detects (MCL/MCLG/ARL)	Unit	MCLG	MCL	ARL	Primary Source of Contamination

Inorganic Contaminants									
10 Boron	N	2012	023	No Report	ppm	2	2		Discharge of drinking water; discharge from metal refineries, erosion of natural deposits.
14 Copper	N	2012	2	0	ppm	1.3	1.3	0.4	Corrosion of household plumbing system; erosion of natural deposits; leaching from wood preservatives.
16 Fluoride	N	2012	81	No Range	ppm	4	4		Erosion of natural deposits; water added which promotes leaching; discharge from battery and aluminum facilities.
19 Nitrate (as Nitrogen)	N	2012	34	No Range	ppm	10	10	3	Runoff from fertilizer use; leaching from fertilizers; sewage, erosion of natural deposits.

Disinfection By-Products									
Chlorine	N	2012	1	2-11	mg/l	0	0	MRDL=4	Water additive used to control microbes.

* Limit means sample is sample reported for 2012. As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water is SAFE at these levels.

The state requires to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems compliance with monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

In present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Water Act website. Please contact 601-376-7562 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the KOKOMO-SHILOH WATER ASSN. is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 3. The percentage of fluoride samples collected in the previous calendar year that were within the optimal range of 0.7-1.3 ppm was 12%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may occasionally be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4761.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4761.

April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING: In accordance with the Radioactivity Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline. However, during the sampling process, the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) and the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analysis and reporting of radiological compliance samples and results until further notice. Although we were not the result of action by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radioactivity Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601-576-7512.

The Kokomo-Shiloh Water Association works around the clock to provide top quality water to every tap. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Senior Life

Connecting with Marion Counties elders, one question at time.

in the NEW

The COLUMBIAN PROGRESS

www.columbianprogress.com