

RECEIVED - WATER SUPPLY  
2013 JUN 14 AM 8:58

Porterville Water Association Porterville W/A-Kemper Springs

Public Water Supply

0350006 & 0350024

PWS ID # ('s):

The Federal Safe Drinking Water Act requires each Community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

**Please Answer the Following Questions Regarding the Consumer Confidence Report**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- E-mail message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date customers were informed: \_\_\_\_/\_\_\_\_/\_\_\_\_

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date mailed/distributed: \_\_\_\_/\_\_\_\_/\_\_\_\_

CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: THE KEMPER MESSENGER

Date Published: MAY 16 2013

CCR was posted in public places. *(Attach list of locations)* Date posted: \_\_\_\_/\_\_\_\_/\_\_\_\_

CCR was posted on a publicly accessible internet site at the address: **(DIRECT URL REQUIRED):**  
\_\_\_\_\_

**CERTIFICATION:**

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature] PRESIDENT  
Name/Title (President, Mayor, Owner, etc.)

6/11/13  
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

[Signature]  
Signature

5-2-13  
Date

**Deliver or send via U. S. Postal Service:**  
**Bureau of Public Water Supply**  
**P O Box 1700**  
**Jackson, MS 39215**

**May be faxed to:**  
**(601) 576-7800**

**May be emailed to:**  
**Melanie.Yanklowski@msdh.state.ms.us**

2013 JUN 14 AM 8:59

PROOF OF PUBLICATION
THE STATE OF MISSISSIPPI
KEMPER COUNTY

PERSONALLY appeared before me, the undersigned notary public in and for Kemper County, Mississippi, for the KEMPER COUNTY MESSENGER, a weekly newspaper of general circulation in Kemper County, Mississippi as defined and prescribed in Section 13-3-31, of the Mississippi Code of 1972, as amended, who, being duly sworn, states that the notice, a true copy of which is attached hereto was published in the issues of said newspaper as follows:

Date May 16, 2013
Vol. 80, No. 33
Date, 2013
Vol., No.
Date, 2013
Vol., No.
Date, 2013
Vol., No.

Signed: [Signature]
For the KEMPER COUNTY MESSENGER

before me the 13th day of May, 2013.



We're pleased to present to you this year's Annual Water Quality Report. Our constant goal is to provide you with a safe drinking water supply and protect our water resources. Wilcox Aquifer.

A source water assessment has been completed for all potential sources of contamination. The water supply for Porterville is safe. We're pleased to report that our drinking water meets all state and federal requirements.

If you have any questions about this report or concerning your water utility. If you want to learn more, please call the Porterville Water Association office at 6:30 p.m.

Porterville Water Association-Kemper Springs routinely monitors our water for the period of January 1st to December 31st for lead, copper, inorganic and organic chemicals, and radioactive materials. It's important to remember that even small amounts of some constituents can be harmful to your health.

In this table you will find many terms and abbreviations used in this report.

Action Level - the concentration of a contaminant which requires that you take corrective action.

Treatment Technique (TT) - A treatment technique is used to reduce the concentration of a contaminant.

Maximum Contaminant Level - The "Maximum Allowable Concentration" (MAC) is the highest level of a contaminant that is allowed in drinking water.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health.

Table with 3 columns: Contaminant, Violation Y/N, and MCLG. Rows include Radioactive Contaminants (5. Alpha emitters), Inorganic Contaminants (10. Barium), and Organic Contaminants (13. Chromium).

This report being published in the paper will not be mailed. Please call for more information. EPA/CDC provides advice about drinking water from their health care providers. (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than others. People with kidney disease, pregnant women, and infants are at higher risk.

All sources of drinking water are subject to potential contamination by substances that may be harmful to your health. All drinking water, including bottled water, may contain very small amounts of substances that are not considered safe.

Additional information for lead and copper. If you are concerned about lead in your water, you may want to flush your pipes before drinking or cooking. If you are concerned about lead in your water, you may want to flush your pipes before drinking or cooking.

Additional information for lead and copper. If you are concerned about lead in your water, you may want to flush your pipes before drinking or cooking. If you are concerned about lead in your water, you may want to flush your pipes before drinking or cooking.

Additional information for lead and copper. If you are concerned about lead in your water, you may want to flush your pipes before drinking or cooking. If you are concerned about lead in your water, you may want to flush your pipes before drinking or cooking.

Annual Drinking Water Quality Report  
 Porterville Water Association - Kemper Springs  
 PWSID #0350024  
 May, 2013

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well that draws from the Lower Wilcox Aquifer.

A source water assessment has been completed for the Porterville - Kemper Springs water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Porterville - Kemper Springs received a high susceptibility ranking to contamination. We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Sue Stuart at 662-476-9614. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Monday of each month at the Porterville Water Association office at 6:30 p.m.

Porterville Water Association-Kemper Springs routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "GoaP"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Alpha emitters			1.2		PCl/l	0	15	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
10. Barium			0.016		Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium			0.66		Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper			0.3		ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead			1		ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
19. Nitrate (as Nitrogen)			0.29		ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> )			1.30	1.00 to 1.30	ppm	4	4	Water additive used to control microbes
HAAS (Halacetic acids)			2.0		ppb	0	60	By-product of drinking water chlorination

\* Most recent sample results available

\*\*\*\*\* APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\* In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Porterville Water Association-Kemper Springs is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you would like a copy or have any questions.

ACCOUNT NO	SERVICE FROM	SERVICE TO
020239000	04/15	05/15
SERVICE ADDRESS		
99 BUCHANAN RD		
CURRENT	METER READINGS PREVIOUS	USED
846480	844449	2031
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:  
**PORTERVILLE WATER ASSOC.**  
P.O. BOX 8  
PORTERVILLE, MS 39352

PRESORTED  
FIRST-CLASS MAIL  
U.S. POSTAGE  
PERMIT NO. 7  
PORTERVILLE, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2013	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
20.00	2.00	22.00

Consumer Confidence Report ran  
in Kemper Messenger 5/16/2013

WTR 20.00  
NET DUE >>> 20.00  
SAVE THIS >> 2.00  
GROSS DUE >> 22.00

**RETURN SERVICE REQUESTED**

020239000  
JOHNIE B STUART

99 BUCHANAN RD  
PORTERVILLE MS 39352

WATER SUPPLY  
8:59