

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION FORM  
CALENDAR YEAR 2012

JUL -9 AM 8:29

Adaton Water Association  
Public Water Supply Name

530001

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 6/1/13 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_ / \_\_\_ / \_\_\_

- As a URL (Provide URL \_\_\_\_\_)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Starkville Daily News

Date Published: 6/19/13

CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_ / \_\_\_ / \_\_\_

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED): \_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Doss Brodway - President  
Name/Title (President, Mayor, Owner, etc.)

7-1-13  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
[Melanie.Yanklowski@msdh.state.ms.us](mailto:Melanie.Yanklowski@msdh.state.ms.us)

Adaton Water Assoc  
1542 West Reed Rd  
Starkville, MS 39759  
662-418-0802

RECEIVED-WATER SUPPLY  
2013 JUN -5 PM 12:16

2012 Annual Drinking Water Quality Report  
Adaton Water Association, Inc.  
PWS#: 530001  
May 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Adaton Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Doss Brodnax at 662.323.9543. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 7:00 PM at 5818 Self Creek Road well site.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2010*	1.	.9 - 1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

10. Barium	N	2010*	.113	.10 - .113	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2010*	.2	.19 - .2	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010*	4.3	4.2 - 4.3	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Disinfection By-Products</b>								
Chlorine	N	2012	.7	.48 - .94	ppm	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2012.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

**\*\*\*\*\*April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Adaton Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please note: CCR will not be mailed to each customer. It will be published in Starkville Daily News.

The State of Mississippi  
OKTIBBEHA COUNTY

RECEIVED - WATER SUPPLY  
2013 JUL -9 AM 8:30

**AFFIDAVIT OF PUBLICATION**


Before me, in and for said county, this day personally came the undersigned representative of the Starkville Daily News, a newspaper published in the City of Starkville, of said county and state, who being duly sworn deposes and says that the publication of a certain notice, a true copy of which, is hereto affixed has been made for 1 weeks consecutively, to wit:

Dated June 19, 2013  
Dated \_\_\_\_\_, 20\_\_\_\_  
Dated \_\_\_\_\_, 20\_\_\_\_  
Dated \_\_\_\_\_, 20\_\_\_\_

Said representative further certifies that the several numbers of the newspaper containing the above mentioned notice have been produced and compared with the copy affixed; and that the publication thereof has been correctly made.

WITNESS MY HAND AND SEAL OF OFFICE, this the 17 day of June, A.D., 2013

By: Mona Howelle  
Notary Public for the State of Mississippi

SEAL: 

STARKVILLE DAILY NEWS  
By: Kathleen G. Galt  
( ) Publisher (X) Clerk  
Publication Fee \$ 501.90  
Proof(s) Of Publication \$ \_\_\_\_\_  
Total Charges \$ 501.90  
AFFIDAVIT# 36150

2012 Annual Drinking Water Quality Report  
Annual Water Association, Inc.  
P.O. Box 33007  
July 2013

You are the new Annual Quality Report. The report is designed to inform you about the water you are drinking. Our annual goal is to provide you with a safe and dependable source of drinking water. You will find this report to be a valuable resource. The report contains information on the water treatment process and the water quality monitoring system. It also contains information on the water quality monitoring system and the water quality monitoring system. The report is designed to provide you with information on the water quality monitoring system and the water quality monitoring system.

**TEST RESULTS**

Date Collected	Lead (ppb)	Total Dissolved Solids (ppm)	Calcium (ppm)	Magnesium (ppm)	Hardness (ppm)	Chloride (ppm)	Sulfate (ppm)	Total Hardness (ppm)	Number of natural radon measurements exceeding 4 pCi/L
06/19/13	0	145	100	20	120	10	10	130	0
06/20/13	0	145	100	20	120	10	10	130	0
06/21/13	0	145	100	20	120	10	10	130	0
06/22/13	0	145	100	20	120	10	10	130	0
06/23/13	0	145	100	20	120	10	10	130	0
06/24/13	0	145	100	20	120	10	10	130	0
06/25/13	0	145	100	20	120	10	10	130	0
06/26/13	0	145	100	20	120	10	10	130	0
06/27/13	0	145	100	20	120	10	10	130	0
06/28/13	0	145	100	20	120	10	10	130	0
06/29/13	0	145	100	20	120	10	10	130	0
06/30/13	0	145	100	20	120	10	10	130	0

**Disinfection By Product**

Date	Chlorine (ppm)	Total Chlorine (ppm)	Free Chlorine (ppm)	Chlorine Dioxide (ppm)	Chloramine (ppm)	Total Chlorine Dioxide (ppm)
06/19/13	1.5	1.5	1.5	0	0	0
06/20/13	1.5	1.5	1.5	0	0	0
06/21/13	1.5	1.5	1.5	0	0	0
06/22/13	1.5	1.5	1.5	0	0	0
06/23/13	1.5	1.5	1.5	0	0	0
06/24/13	1.5	1.5	1.5	0	0	0
06/25/13	1.5	1.5	1.5	0	0	0
06/26/13	1.5	1.5	1.5	0	0	0
06/27/13	1.5	1.5	1.5	0	0	0
06/28/13	1.5	1.5	1.5	0	0	0
06/29/13	1.5	1.5	1.5	0	0	0
06/30/13	1.5	1.5	1.5	0	0	0

**Disinfection By Product**

The purpose of this report is to provide you with information on the water quality monitoring system and the water quality monitoring system. The report is designed to provide you with information on the water quality monitoring system and the water quality monitoring system.

RECEIVED - WATER SUPPLY

2013 JUL -9 AM 8:30

GTPDD - Adaton Water Assn.  
P.O. Drawer 1008  
Starkville, MS 39760-1008  
662 324 7388

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	246360	244240	2,120	12.24

45 PINEDALE LN



400009 5/30/2013

METER READ			TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
MONTH	DAY	CLASS			
5	28	1	12.24	1.22	13.46

THE CONSUMER CONFIDENCE REPORT WILL BE PUBLISHED IN THE STARKVILLE DAILY NEWS IN JUNE.

10% PENALTY AFTER 15TH