

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

HUB WATER ASSOCIATION
Public Water Supply Name

460008

List PWS ID #s for all Community Water Systems included in this CCR

RECEIVED-WATER SUPPLY
2013 JUN 28 PM 2:18

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

N/A Date(s) customers were informed: 6/27/2013 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

- CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___ / ___ / ___
 - As a URL (Provide URL _____)
 - As an attachment
 - As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: _____

Date Published: ___ / ___ / ___

CCR was posted in public places. (Attach list of locations) Date Posted: ___ / ___ / ___

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):
WWW.IMPROVEMATER.COM/DOCUMENTS/257/CCR-Report.pdf

CERTIFICATION

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Kush Banta (OPERATOR)
Name/Title (President, Mayor, Owner, etc.)

6-28-13
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2012 Annual Drinking Water Quality Report
 Hub Water Association
 PWS#: 460008
 June 2013

2013 JUN 22 PM 12: 24

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Hub Water Association have received a lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Ken Foster at 601.736.0019. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for Saturday, May 4, 2013 at 9:00 AM at the Hub Water Warehouse.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012 the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination	
Microbiological Contaminants									
1. Total Coliform Bacteria	N	May 2012	Positive	1	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment	
Radioactive Contaminants									

5. Gross Alpha	N	2012	4.1	1- 4.1	pCi/L	0	15	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2012	.040	.004 - .040	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012	3.71	2 – 3.71	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2009/11*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012	.225	.175 - .225	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2012	1.1	.6 – 1.5	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2012.

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In May of 2012 we had one sample that showed the presence of total coliform,. We flushed the water main and the re-samples showed no bacteria.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*******A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water suppliers were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological health laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has not completed the monitoring requirements. The Bureau of Public Water Supply has taken action to ensure that your water system be returned to compliance by March 31, 2013. If you have any questions, please contact Melissa Parker, Deputy Director, Bureau of Public Water Supply, at 601.576.7518.

The Hub Water Association works around the clock to provide top quality water to every tap. In 2008, we have initiated installing an additional well on the system. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Hub Water Association
1844 Hwy 13 South
Columbia, MS 39429
601-736-0019

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39429
PERMIT # 32

Hub Water Association
1844 Hwy 13 South
Columbia, MS 39429
601-736-0019

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39429
PERMIT # 32

Previous CREDIT Balance: -19.38
WATER USED: 0 20.00
PREV: 32710 PRES: 32710

Billed: 06/30
After 07/15 pay 0.68
0.62 IS DUE UPON RECEIPT

Previous Balance: 0.00
WATER USED: 0 20.00
PREV: 86130 PRES: 86130

Billed: 06/30
After 07/15 pay 22.00
20.00 IS DUE UPON RECEIPT

TOTAL NEW CHARGES 20.00

TOTAL NEW CHARGES 20.00

0.62 IS DUE UPON RECEIPT

Acc# 010073900
Z71 SEAMON BULLOCK RD
Return Service Requested

20.00 IS DUE UPON RECEIPT

Acc# 010017100
51 WHALLUM LANE
Return Service Requested

SEAMON BULLOCK RD
SVC:06/29-06/25 (27 days) After 07/15 pay 0.68
Last Print \$250.00 on 07/06
SARAH L. DYPSKY Acct# 010073900
PLEASE READ BACK
FOR IMPORTANT MESSAGE

Return Service Requested
SARAH L. DYPSKY
12912 Center Dr
Ocean City MD 21842-9744

After 07/15 pay 22.00
51 WHALLUM LANE
SVC:06/28-06/24 (27 days) Acct# 010017100
Last Print \$20.00 on 06/12
WIN STEVENS
PLEASE READ BACK
FOR IMPORTANT MESSAGE

Return Service Requested
WIN STEVENS
C/o Linda Martin
127 Willow Street
Baxter TN 38544

Deliver payment to:

Hub Water Association
1844 Hwy 13 South
Columbia, MS 39429
601-736-0019

Deliver payment to:

Hub Water Association
1844 Hwy 13 South
Columbia, MS 39429
601-736-0019

Previous Balance: 0.00
WATER USED: 0 20.00
PREV: 2000 PRES: 2000

Billed: 06/30
20.00 PAID BY DIRECT DEBIT

Previous CREDIT Balance: -88.70
WATER USED: 1420 20.00
PREV: 23560 PRES: 24980

Billed: 06/30
No Payment Due, Bal = -88.70

TOTAL NEW CHARGES 20.00

TOTAL NEW CHARGES 20.00

20.00 PAID BY DIRECT DEBIT

Acc# 010061800
42 SANDERS ROAD
Return Service Requested

No Payment Due, Bal = -68.70

Acc# 010060300
821 COLUMBIA PURVIS RD
Return Service Requested

42 SANDERS ROAD MARGANIE SANDERS
SVC:05/28-06/24 (27 days) Acct# 010061800
Last Print \$20.00 on 06/12
PLEASE READ BACK
FOR IMPORTANT MESSAGE

Return Service Requested
MARGANIE SANDERS
% JOE SANDERS
5060 CRAWLEY RD
FAYETTE AL 35555

1 COLUMBIA PURVIS RD WILDA L. BUCKLEY
SVC:05/28-06/24 (27 days) Acct# 010060300
Last Print \$200.00 on 03/13
PLEASE READ BACK
FOR IMPORTANT MESSAGE

Return Service Requested
WILDA L. BUCKLEY
110 ROLLING WOOD DR
BRANDON MS 39042

RECEIVED-WATER SUPPLY 2013 JUN 28 PM 2:19

!! IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
!! IS AVAILABLE IN THE 2012 CONSUMER CONFIDENCE REPORT AT:

www.improvewater.com/documents/257/CCR_Report.pdf

!! YOU MAY REQUEST A HARD COPY BY CHECKING THIS BOX ()
!! OR BY CALLING OUR OFFICE AT (601) 736-0019.

** Our office will be closed THURSDAY, JULY 4, 2013, for Independence Day. Have a safe and happy holiday!

** Make bill paying easier! No more late fees. Use direct debit. (Call the office for details.) **

** For faster payment processing, please enclose SMALL portion of bill with payment & write account number on check/money order. **

!! IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
!! IS AVAILABLE IN THE 2012 CONSUMER CONFIDENCE REPORT AT:

www.improvewater.com/documents/257/CCR_Report.pdf

!! YOU MAY REQUEST A HARD COPY BY CHECKING THIS BOX ()
!! OR BY CALLING OUR OFFICE AT (601) 736-0019.

** Our office will be closed THURSDAY, JULY 4, 2013, for Independence Day. Have a safe and happy holiday!

** Make bill paying easier! No more late fees. Use direct debit. (Call the office for details.) **

** For faster payment processing, please enclose SMALL portion of bill with payment & write account number on check/money order. **

!! IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
!! IS AVAILABLE IN THE 2012 CONSUMER CONFIDENCE REPORT /

www.improvewater.com/documents/257/CCR_Report.pdf

!! YOU MAY REQUEST A HARD COPY BY CHECKING THIS BOX ()
!! OR BY CALLING OUR OFFICE AT (601) 736-0019.

** Our office will be closed THURSDAY, JULY 4, 2013, for Independence Day. Have a safe and happy holiday!

** Make bill paying easier! No more late fees. Use direct debit. (Call the office for details.) **

** For faster payment processing, please enclose SMALL portion of bill with payment & write account number on check/money order. **

!! IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
!! IS AVAILABLE IN THE 2012 CONSUMER CONFIDENCE REPORT /

www.improvewater.com/documents/257/CCR_Report.pdf

!! YOU MAY REQUEST A HARD COPY BY CHECKING THIS BOX ()
!! OR BY CALLING OUR OFFICE AT (601) 736-0019.

** Our office will be closed THURSDAY, JULY 4, 2013, for Independence Day. Have a safe and happy holiday!

** Make bill paying easier! No more late fees. Use direct debit. (Call the office for details.) **

** For faster payment processing, please enclose SMALL portion of bill with payment & write account number on check/money order. **

61:2 PM 82 NUN 610Z

ALPDDNS 312AW -03A13038