

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
 BUREAU OF PUBLIC WATER SUPPLY  
 CCR CERTIFICATION FORM  
 CALENDAR YEAR 2012

2013 JUN 26 AM 8:43

White Station Water Assn.  
 Public Water Supply Name

0130020  
 List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper (attach copy of advertisement)
  - On water bills (attach copy of bill)
  - Email message (MUST Email the message to the address below)
  - Other \_\_\_\_\_
- Date(s) customers were informed: 6/21/2013 / /
- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_
- Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_
- CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_
  - As a URL (Provide URL \_\_\_\_\_)
  - As an attachment
  - As text within the body of the email message
- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
  - Name of Newspaper: \_\_\_\_\_
  - Date Published: \_\_\_\_ / \_\_\_\_ / \_\_\_\_
- CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_\_ / \_\_\_\_ / \_\_\_\_
- CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):  
 \_\_\_\_\_

**CERTIFICATION**  
 I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

President Bryan J. Walker  
 Name/Title (President, Mayor, Owner, etc.)

6/24/13  
 Date

Deliver or send via U.S. Postal Service:  
 Bureau of Public Water Supply  
 P.O. Box 1700  
 Jackson, MS 39215

May be faxed to:  
 (601)576-7800  
 May be emailed to:  
Melanie.Yanklowski@msdh.state.ms.us

2012 Annual Drinking Water Quality Report  
 White Station Water Association  
 PWS#: 130020  
 June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is purchased from the City of West Point that has wells drawing from the Eutaw Formation & the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of West Point have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Barrett Baggett at 662-436-7329. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for the third Monday of the month at 7:00 PM at the Fire Station – Hazelwood Road.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2011*	.06	.03 - .06	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2011*	1.3	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2010*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	.82	.43 - .82	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2010*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2012	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2012	1.2	.79 – 1.4	mg/l	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2012.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF WEST POINT is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 80%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

**\*\*\*\*April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The White Station Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

RECEIVED: WATER SUPPLY

June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of the water you receive from the White Station Water Association. Our goal is to provide you with the information you need to understand the quality of your water. Our water is treated to meet or exceed all applicable federal, state, and local drinking water standards. The water quality assessment has been conducted for our public water system to determine the overall quality of the drinking water supply in the White Station Water Association. A report containing detailed information on how the water quality assessment was conducted is available at [www.whitestationwater.com](http://www.whitestationwater.com). If you have any questions about this report or concerning your water, please contact the Water Supply Department at 601-378-7339. We want our customers to be informed about their water. If you wish to learn more, please contact the Water Supply Department at 601-378-7339.

We regularly monitor for contaminants in your drinking water according to federal and state laws. The table below lists all of the drinking water contaminants we monitor for. The table includes the name of the contaminant, the federal and state drinking water standards, and the maximum contaminant level (MCL) for each contaminant. In some cases, the federal and state drinking water standards are different. The table also includes the name of the contaminant, the federal and state drinking water standards, and the maximum contaminant level (MCL) for each contaminant. In some cases, the federal and state drinking water standards are different. The table also includes the name of the contaminant, the federal and state drinking water standards, and the maximum contaminant level (MCL) for each contaminant. In some cases, the federal and state drinking water standards are different.

Contaminant	Vendor	Year	Test Date	Test Result	MCL	Unit	Excess of MCL	Excess of State MCL	Excess of Federal MCL
<b>Inorganic Contaminants</b>									
10. Arsenic	N	2011	08	0.01	0.05	ppm			
11. Chromium	N	2011	03	No Range	0.1	ppm			
14. Copper	N	2011	05	0	1.3	ppm			
16. Fluoride	N	2011	02	0.7	4.0	ppm			
17. Lead	N	2011	05	0	0.01	ppm			
<b>Disinfection By-Products</b>									
61. HAA5	N	2011	05	No Range	0.1	ppm			
62. Chloroform	N	2011	05	No Range	0.05	ppm			

As you can see by the table, our system met the national drinking water standards for all of the federal and state drinking water contaminants. We have tested through our monitoring and testing that our drinking water meets or exceeds all federal and state drinking water standards. We have tested through our monitoring and testing that our drinking water meets or exceeds all federal and state drinking water standards. We have tested through our monitoring and testing that our drinking water meets or exceeds all federal and state drinking water standards. We have tested through our monitoring and testing that our drinking water meets or exceeds all federal and state drinking water standards.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We do not operate the monitoring requirements for contaminants that are not listed in the table. We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We do not operate the monitoring requirements for contaminants that are not listed in the table. We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We do not operate the monitoring requirements for contaminants that are not listed in the table.

To comply with the Regulation Governing Fluoridation of Community Water Supplies, the CITY OF WEST POINT is required to report certain results to the public. The number of fluoride samples collected in the previous calendar year was 100. The percentage of fluoride samples collected in the previous calendar year that met the optimal range of 0.7-1.2 ppm was 100%. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances include inorganic, organic, and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more susceptible to contaminants in drinking water than the general population. Immunocompromised persons, persons with cancer, pregnant women, and infants are more susceptible to contaminants in drinking water. Immunocompromised persons, persons with cancer, pregnant women, and infants are more susceptible to contaminants in drinking water. Immunocompromised persons, persons with cancer, pregnant women, and infants are more susceptible to contaminants in drinking water. Immunocompromised persons, persons with cancer, pregnant women, and infants are more susceptible to contaminants in drinking water.

The White Station Water Association works around the clock to provide you quality water to every tap. We are committed to providing you with the highest quality water possible. We are committed to providing you with the highest quality water possible. We are committed to providing you with the highest quality water possible. We are committed to providing you with the highest quality water possible.