

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

RECEIVED-WATER SUPPLY
2013 JUL -1 PM 5:14

Tri Lake Rural Water Assoc (East)
Public Water Supply Name

08/00/0

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other Door To Door

Date(s) customers were informed: 6/28/13 / / / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used Copy delivered to each customer residence

Date Mailed/Distributed: 6/28/13

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: / /

CCR was posted in public places. *(Attach list of locations)* Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**: _____

CERTIFICATION

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Henry A. White President/Operator
Name/Title (President, Mayor, Owner, etc.)

6-28-2013
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

WATER QUALITY DATA TABLE

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contamination in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of this report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the contaminants do not change frequently. Some of the data, though representative of the water quality, may be more than one year old.

Terms and Abbreviations used in the Table

MCLG: Maximum Contamination Level Goal: The level of contamination in drinking water below which is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contamination Level: The highest level of a contamination that is allowed in drinking water. MCLs are set as close to the MCLs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contamination which if exceeded triggers treatment or other requirements, which a water system must allow.

MRDL: Maximum residual disinfectant level. Highest disinfectant allowed in drinking water.

RRA: Running annual average.

Contaminants (Units)	MCLG	MCL	YOUR WATER	SAMPLE DATE	VIOLATION	TYPICAL SOURCE
Inorganic Contaminants						
Barium	2	2	.0231	5/10/2010	No	Discharge of drilling waste Discharge from metal refineries Erosion of natural deposits
Chromium	0.1	0.1	0.0007	5/10/2010	No	Discharge from steel and pulp mills Erosion of natural deposits
Cyanide	0.2	0.2	0.015	4/26/2010	No	Discharge from plastic and fertilizer, steel and metal factories
Nitrate + Nitrite (ASN)	10	10	0.1	4/11/2011	No	Run off from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Copper (ppm)	1.3	1.3	0.2	6/21/2011	No	Erosion of natural deposits; leaching Corrosion of household plumbing system From wood preservatives
Lead (ppb)	0	15	0	6/21/2011	No	Corrosion of household plumbing system Erosion of natural deposits

Microbiological Contaminants						
# Total Coliform	0	>1	0		No	Naturally present in the environment

TTHM(ppb) (Total Trihalomethanes)	0	100	11.6	8/2/2010	No	By product of drinking water chlorination
HAAs(PPB) (Total Haloacetic Acids)	0	100	0	8/3/2010	No	By product of drinking water chlorination
Chlorine	MRDL=4	RAA	0.5MG/L	2012	No	Additive to control microbes
MRDL Range Field 0.20 to 0.60MG/L						

10

Units Description:

ppm: parts per million or milligrams per liter (mg/l)

ppb: parts per billion or micrograms per liter (ug/l)

pCi/l: picocuries per liter (a measure of radioactivity)

% of monthly positive samples: Percent of samples taken monthly that were positive

Education Information (No Violation):

Lead- Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your homes plumbing. If you are concerned about elevated lead levels in your home's water you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water.

Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791)

Additional information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from the materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

*******April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007-December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601-576-7518.