

CITY OF COLLINS

Public Water Supply Name

0160002

PWS ID # ('s):

The Federal Safe Drinking Water Act requires each Community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

**Please Answer the Following Questions Regarding the Consumer Confidence Report**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*

- Advertisement in local paper (attach copy of advertisement)  
 On water bills (attach copy of bill)  
 E-mail message (MUST Email the message to the address below)  
 Other \_\_\_\_\_

Date customers were informed: \_\_\_\_/\_\_\_\_/\_\_\_\_

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date mailed/distributed: \_\_\_\_/\_\_\_\_/\_\_\_\_

CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: The News Commercial

Date Published: 6 / 12 / 2013

CCR was posted in public places. *(Attach list of locations)* Date posted: \_\_\_\_/\_\_\_\_/\_\_\_\_

CCR was posted on a publicly accessible internet site at the address: **(DIRECT URL REQUIRED):**  
\_\_\_\_\_

**CERTIFICATION:**

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

U.O. Smith Mayor  
Name/Title (President, Mayer, Owner, etc.)

6/12/2013  
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Boyette  
Signature

5/23/13  
Date

**Deliver or send via U. S. Postal Service:  
Bureau of Public Water Supply  
P O Box 1700  
Jackson, MS 39215**

**May be faxed to:  
(601) 576-7800**

**May be emailed to:  
[Melanie.Yanklowski@msdh.state.ms.us](mailto:Melanie.Yanklowski@msdh.state.ms.us)**

CORRECTED  
*Annual Drinking Water Quality Report*  
*City of Collins*  
*PWS ID # 0160002*  
*June, 2013*

RECEIVED-WATER SUPPLY  
2013 JUN 27 PM 12: 11

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of three wells that draw from the Catahoula Formation & Miocene Series Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Collins received a lower and a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Bob Shoemaker at 601-765-4491. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesdays of each month at Collins City Hall at 6:00 p.m.

The City of Collins routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31<sup>st</sup>, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2011*	0.011	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2011*	7	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	1.17	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011*	3	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	1/1/12 to 12/31/12	1.20	0.50 to 2.20	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri-halomethanes]	N		1.51	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5 [Haloacetic Acids]	N		4.0	No Range	ppb	0	60	By-product of drinking water chlorination

\* Most recent sample results available

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", CITY OF COLLINS is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7 to 1.3 ppm was 7. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 to 1.3 ppm was 57%.

\*\*\*\*\*APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Collins is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you

can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you would like a copy or have any questions.

*Annual Drinking Water Quality Report*

2013 JUN 17 AM 8: 57

*City of Collins**PWS ID # 0160002**May, 2013*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of three wells that draw from the Catahoula Formation & Miocene Series Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Collins received a lower and a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Bob Shoemaker at 601-765-4491. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesdays of each month at Collins City Hall at 6:00 p.m.

The City of Collins routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31<sup>st</sup>, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2011*	0.011	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2011*	7	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011*	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	1.17	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011*	3	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> )	N	1/1/12 to 12/31/12	1.20	0.50 to 2.20	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri-halomethanes]	N	2008*	13	None	ppb	0	80	By-product of drinking water chlorination

\* Most recent sample results available

To comply with the “Regulation Governing Fluoridation of Community Water Supplies”, CITY OF COLLINS is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7 to 1.3 ppm was 7. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 to 1.3 ppm was 57%.

\*\*\*\*\*APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Collins is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available

from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you would like a copy or have any questions.

Please contact City Hall if you have any questions.

601-765-4491

RECEIVED  
JUN 14 2013

# Proof of Publication

STATE OF MISSISSIPPI  
COVINGTON COUNTY

PERSONALLY APPEARED before me, the undersigned authority,  
in and for said County and State, **Analyn Arrington Goff**, Publisher  
of **THE NEWS-COMMERCIAL**, a newspaper published in Collins,  
said County, who being duly sworn, says the publication of a certain  
notice, a true copy of which is hereto attached, was made in said  
paper on the hereinafter dates, as follows, to-wit:

Vol. 111 No. 48 Dated June 12, 2013  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Dated \_\_\_\_\_  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Dated \_\_\_\_\_  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Dated \_\_\_\_\_

*Analyn A. Goff* Publisher

Sworn to and subscribed before me, this the 12 day of  
June, 2013.

*James Arrington Goff* Notary Public

Printer's Fee \$ 213.75  
Proof of Publication \$ 3.00  
**TOTAL** \$ 216.75



RECEIVED - WATER SUPPLY  
2013 JUN 17 AM 8:57



Annual Drinking Water Quality Report RECEIVED-WATER SUPPLY

City of Collins  
PWS ID # 0166002  
Aug. 2013  
2013 JUN 17 AM 8:53

We're pleased to present to you this year's Annual Water Quality Report. This report is prepared in accordance with the Safe Drinking Water Act and the quality water and service we deliver to you every day. Our ongoing goal is to provide you with a safe and dependable supply of clean water. We want to thank you for the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water supply consists of three wells that draw from the Cascade Formation in Boone County, Missouri.

A routine water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Collins received a lower and a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or contacting your water utility, please contact Bob Shoemaker at 601-765-4491. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesdays of each month at Collins City Hall at 6:00 p.m.

The City of Collins routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Advanced Treatment Technique (ATT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set at least as strict as the MCLGs to be feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Water Type	Sample Date	Sample Type	Water Treatment Method	Units	Result	Health	Safe Drinking Water Act
<b>Inorganic Constituents</b>								
13. Arsenic	Drinking	2012	0311	No Range	ppb	1	1	1
14. Chloride	Drinking	2012	03	No Range	ppm	100	100	100
15. Copper	Drinking	2012	03	No Range	ppm	1.1	1.1	1.1
16. Fluoride	Drinking	2012	117	No Range	ppm	1	1	1
17. Nitrate	Drinking	2012	1	No Range	ppm	0	0	0
<b>Disinfectants &amp; Disinfection By-Products</b>								
18. Chlorine	Drinking	2012	100	No Range	ppm	4	4	4
19. Total Trihalomethanes	Drinking	2012	100	No Range	ppb	0	0	0

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", CITY OF COLLINS is required to report certain results regarding the fluoridation of our water system. The number of samples in the previous calendar year in which fluoride sample results were within the optimal range of 0.7 to 1.3 ppm was 7. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 to 1.3 ppm was 57%.

\*\*\*\*APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*  
In accordance with the Radiocesium Rule, all community public water supplies were required to sample quarterly for radiocesium beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit by the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analysis and reporting of radiological sample results and results will further follow. Although this was not the result of an action by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radiocesium Rule. If you have any questions, please contact Kevin Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7318.

**Additional Information for Lead**  
If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Collins is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested for lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or that are made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you would like a copy or have any questions. Please contact City Hall at 601-765-4491 if you have any questions.