

2013 JUN 28 PM 4:07

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION FORM
CALENDAR YEAR 2012

Dixie Community Utility Association
Public Water Supply Name

0180005

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 6/28/13, / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Impact

Date Published: 6/19/13

CCR was posted in public places. *(Attach list of locations)* Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


Name/Title (President, Mayor, Owner, etc.)

6-27-13
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800
May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2013 JUN 22 PM 12: 25

2012 Annual Drinking Water Quality Report
Dixie Community Utility Association
PWS#: 0180005
June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Middle Catahoula, Lower Catahoula and the Hattiesburg Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Dixie Community Utility Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Sebron Pullen at 601.584.0875. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of the month at 4:30 PM at 500 Elks Lake Rd, Hattiesburg, MS.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure -ment | MCLG | MCL | Likely Source of Contamination |
|-------------------------------|---------------|----------------|----------------|--|--------------------|------|-----|--|
| Inorganic Contaminants | | | | | | | | |
| 8. Arsenic | N | 2011* | .6 | No Range | ppb | n/a | 10 | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes |
| 10. Barium | N | 2011* | .02 | .01 -.02 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |

| | | | | | | | | |
|--------------------------------------|---|---------|------|------------|------|-----|----------|---|
| 14. Copper | N | 2010/12 | .2 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2011* | .9 | No Range | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2010/12 | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| 19. Nitrate (as Nitrogen) | N | 2012 | .78 | .66 - .78 | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Volatile Organic Contaminants | | | | | | | | |
| 75. Vinyl Chloride | N | 2012 | .998 | No Range | ppb | 0 | 2 | Leaching from PVC piping; discharge from plastics factories |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2012 | 29 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2012 | 52.8 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2012 | 1.4 | .75 – 1.81 | mg/l | 0 | MDRL = 4 | Water additive used to control microbes |

* Most recent sample. No sample required for 2012.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*******April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*******

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Dixie Community Utility Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**2012 Annual Drinking Water Quality Report
Dixie Community Utility Association**

PWS# 0180005 • June 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our primary goal is to provide you with a safe and dependable supply of drinking water. We work to understand the effect we make on continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water comes from the Middle Catahulpa, Lower Catahulpa and the Hattiesburg Formation Aquifers.

The water quality assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been forwarded to our public water system and is available for viewing upon request. The web for Dixie Community Utility Association has received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water quality, please contact Schele Pullen at 601-534-6875. We want our valued customers to be informed about their water quality. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of the month at 4:30 pm at 501 Old Lake Road, Hattiesburg, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State law. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. A water sample over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals from human activity, industrial contamination, such as salts and metals, which can be naturally occurring or result from agricultural, domestic, agricultural, and wildlife, inorganic contaminants, such as salts and metals, which can be naturally occurring or result from agricultural, domestic, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and auto systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA provides regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level: the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGL as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l): one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/l): one part per billion corresponds to one minute in 2,900 years or a single penny in \$10,000,000.

| Contaminant | Violation Y/N | Date of Collection | Level Detected | Range of Detects or # of Samples | Unit Measurement | MCLGL | MCL | Likely Source of Contamination |
|---------------------------------|---------------|--------------------|----------------|----------------------------------|------------------|-------|--------|---|
| Inorganic Contaminants | | | | | | | | |
| 8. Arsenic | N | 2011* | 8 | No Range | ppb | N/A | 10 | Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes |
| 10. Barium | N | 2011* | .02 | .01 - .02 | ppm | 2 | 2 | Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits |
| 14. Copper | N | 2010/12 | 2 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2011* | 9 | No Range | ppm | 4 | 4 | Erosion of natural deposits, water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2010-12 | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |
| 19. Nitrate (as Nitrogen) | N | 2012 | 78 | 66 - 78 | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2012 | 29 | No Range | ppb | 0 | 60 | By-product of drinking water disinfection |
| 82. THM (Total trihalomethane) | N | 2012 | 52.8 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination |
| Chlorine | N | 2012 | 1.4 | 1.5 - 1.81 | mg/l | 0 | MDRL=1 | Water additive used to control microbes |

*This is one sample in which a violation occurred.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water is SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems compliance all monitoring requirements, MSUHH now monitors systems of any monitoring system prior to the end of the compliance period.

In present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the source of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 1 minute before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate actions to lessen the risk of infection by cryptosporidium and other microbial water contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

*** April 1, 2013 MESSAGE FROM MSUHH CONCERNING RADIOLOGICAL SAMPLING ***

In accordance with the Radonradon Rule, all community public water supplies were required to sample quarterly for radonradon beginning January 2007. December 2007. Your public water supply completed sampling by the scheduled deadline. However, during an audit of the Mississippi State Department of Health (MSD) Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this is not the result of action by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radonradon Rule. If you have any questions, please contact Kevin Walters, Director Compliance & Enforcement, Bureau of Public Water Supply at 601-536-7518.

The Dixie Community Utility Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

2013 JUN 28 PM 4: 07
PUBLIC WATER SUPPLY
OFFICE

ACCOUNT NO. 030181000
SERVICE FROM 05/24
SERVISE ADDRESS 570 OLD LAKE RD
HATTIESBURG MS 39401

DATE DUE 07/31/2013
GROSS DUE 18.69
NET AMOUNT 64650
METER READING 3770

CHARGE FOR SERVICES
WTR NET DUE >>> 18.69
SAVE THIS >>> 18.69
GROSS DUE >>> 18.69

RETURN SERVICE REQUESTED
DAY: D ARMSTRONG
HATTIESBURG MS 39401-9344

RECEIVED WATER SUPPLY

RECEIVED WATER SUPPLY

6/19/13

** INVOICE **

Page 1

BNI, Inc. dba Impact Hattiesburg
(Acctg. purposes only-825-4004)
P. O. Box 103
Brandon, MS 39043-0103
Telephone 601-264-8181

Invoice # 89240
Invoice Date 6/19/13
89240

Bill To: Dixie Community Water 39
Association
500 Elks Lake Rd.
Hattiesburg, MS 39401

Deliver To: Dixie Community Water 39
Association
500 Elks Lake Rd.
Hattiesburg, MS 39401

Customer #: 9955 Your PO:

Terms: due by the 10th

| Item-# | Description | Qty | Unit | Price | Ext-price |
|--------|------------------------------------|------|-------|-------|-----------|
| | \$18.00 per column inch 4x14 ad | 56.0 | 18.00 | | 1008.00 |

TOTAL 1,008.00
Sales Tax 0.00
Discount 0.00
BALANCE DUE ----> 1,008.00

RECEIVED-WATER SUPPLY
2013 JUN 28 PM 4:07