

RECEIVED-WATER SUPPLY

2013 JUL -1 PM 2:11

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION FORM  
CALENDAR YEAR 2012

*City of Lumberton*  
Public Water Supply Name

*0376005*

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper (attach copy of advertisement)
  - On water bills (attach copy of bill)
  - Email message (MUST Email the message to the address below)
  - Other \_\_\_\_\_

Date(s) customers were informed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

- CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_
  - As a URL (Provide URL \_\_\_\_\_)
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: *6/28/13*

- CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_\_ / \_\_\_\_ / \_\_\_\_
- CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED): \_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

*Miriam B. Holder*  
Name/Title (President, Mayor, Owner, etc.)

*July 1, 2013*  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
[Melanie.Yanklowski@msdh.state.ms.us](mailto:Melanie.Yanklowski@msdh.state.ms.us)

RECEIVED-WATER SUPPLY  
2013 JUN -5 PM 12: 16

2012 Annual Drinking Water Quality Report  
City of Lumberton  
PWS#: 0370005  
May 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Lumberton have received a moderate to higher ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Merlene P. Wall, City Clerk at 601.796.8341. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 6:00 PM at 102 E Main Street, Lumberton, MS 39455.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	-------------------	------	-----	--------------------------------

**Microbiological Contaminants**

1. Total Coliform Bacteria	Y	September	Monitoring		NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
<b>Inorganic Contaminants</b>								
10. Barium	N	2012	.003	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride	N	2012	.192	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
82. TTHM [Total trihalomethanes]	N	2009*	22.87	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2012	.8	.5 - 1.2	mg/l	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2012.

**Microbiological Contaminants:**

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

**Disinfection By-Products:**

Chlorine. Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During September 2012 we did not monitor or test for bacteriological and chlorine contaminants and therefore cannot be sure of the quality of our drinking water during that time. We were required to take two samples however none were taken. The samples have since been taken and the system has been returned to compliance.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

**\*\*\*\*\*April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The City of Lumberton works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

RECEIVED-WATER SUPPLY

2013 JUL -1 PM 2:11

Proof of Publication  
The State of Mississippi  
Forrest County

H17313  
PASTE PROOF HERE  
City of Lumberton  
0200441646

PERSONALLY appeared before me, the undersigned notary public in and for Forrest County, Mississippi,

KATHY BULLOCK

An authorized clerk of the HATTIESBURG AMERICAN, a daily newspaper published in the City of Hattiesburg, Forrest County, Mississippi who, being duly sworn, states that the notice, a true copy of which is hereto attached, appeared in the issues of said newspaper as follows:

**Date of Publication:**  
**June 28, 2013**

Size: 6.00x10.00"  
Issues: 1  
Total: \$651.00

Signed:

*Kathy Bullock*

Authorized Clerk  
Of the Hattiesburg American

*Jennifer J Brogdon*  
Notary Public

Sworn to and subscribed before me on

*June 28, 2013*



RECEIVED-WATER SUPPLY

2013 JUL -1 PM 2:1

2012 Annual Drinking Water Quality Report  
City of Lamberton  
May 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and to make the delivery to you as easy as possible. Our commitment is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to consistently improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Minnesota Aquifer.

The ground water contamination has been contained for our public water system to determine the overall acceptability of its drinking water supply to identify its health status of contaminants. A recent monitoring detailed information on how the susceptibility determine water made has been furnished to our public water system and is available for viewing upon request. The water for the City of Lamberton has received a "Moderate to High" rating in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Margaret H. Wahl, City Clerk at 801.796.2321. We want our readers to be able to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 6:00 PM at 102 E. Main Street, Lamberton, MN-56056. We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2012. In some cases, monitoring wasn't required in 2012. The table reflects the most recent results. As water travels over the surface of and is underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence or absence of iron, natural organic compounds, and other substances. These substances can be naturally occurring or man-made. Some of these substances are: radon, pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and auto repair systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of certain substances. It is important to remember that the presence of these substances does not necessarily indicate that the water poses a health risk. In this table you will find many terms and acronyms you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Contaminant	Violation Y/N	Date Detected	Level Detected	Range of Occurs or # of Samples Exceeding MCL/MCL/MDL	Unit Measurement	MCL	MDL	Likely Source of Contamination
Microbiological Contaminants 1. Total Coliform	Y	September	Monitoring		n/a	0	presence of coliform bacteria in 0% of monthly samples	Naturally present in the environment
Inorganic Contaminants 10. Barium	N	2012	.003	no range	ppm	2	2	Discharge of mining wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride	N	2012	.192	No Range	ppm	4	4	Erosion of natural deposits; additive which promotes strong tooth enamel
17. Lead	N	3/00/11*	1	0	ppb	0	AL = 15	Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products 22. Trihalomethanes	N	2009	29.87	no Range	ppb	0	50	By-product of drinking water disinfection
Chlorine	N	2012	.8	.5 - 1.2	mg/l	0	MDL = 4	Water additive to control microbes

\* Most recent sample. No samples required for 2012.

**Microbiological Contaminants:**  
 (1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator of other. Potentially harmful bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.  
**Disinfection By-Products:**  
 Disinfection. Some people with the water containing chlorine will experience irritation to their eyes and nose. Some people who drink water containing chlorine will experience a metallic taste.  
**Disinfection By-Product:**  
 Disinfection. Some people with the water containing chlorine will experience irritation to their eyes and nose. Some people who drink water containing chlorine will experience a metallic taste.  
 We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During September 2012 we did not monitor or test for bacteriological and chemical contaminants and therefore cannot be sure of the quality of our drinking water during that time. We were required to take two samples however none were taken. The samples have since been taken and the system has been returned to compliance.  
 If present, higher levels of lead can cause various health problems, especially for infants, women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791.  
 All sources of drinking water are susceptible to potential contamination by substances that are naturally occurring or man-made. These substances can be inorganic (naturally occurring) and radioactive (naturally occurring). All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The probability of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.  
 Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, and the elderly (especially people with kidney disease) are particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC provides an appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.  
 April 1, 2013 MESSAGE FROM MICHIGAN CONCERNING RADIOLOGICAL CONTAMINATION  
 In accordance with the Radioactive Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007. December 2007, your public water supply conducted sampling by the Michigan Department of Environment, Great Lakes and Energy (EGLE). However, during an audit of the Michigan State Department of Health (MSDH) Health Laboratory, the Environmental Protection Agency (EPA) discovered deficiencies and sampling of radiological contaminants was not being performed. Although this was not the result of laxity by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radioactive Rule. If you have any questions, please contact Karen Hibbard, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 801.270.2318. The City of Lamberton would appreciate the check to provide the quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.