

2013 JUL -8 AM 10: 35

BUREAU OF PUBLIC WATER SUPPLY**CONSUMER CONFIDENCE REPORT
2012 CERTIFICATION FORM****John C. Stennis Space Center and Area 9**

Public Water Supply Name

#0230015 and #0230052

List PWS ID #s for all Water Systems Covered by this CCR

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence ReportCustomers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper

On water bills

Other: **Email to Environmental Working Group Members, Resident Agencies and Acedemia**Date customers were informed: 06 / 19 / 2013

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date Mailed/Distributed: / /CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*Name of Newspaper: ORBITERDate Published: 06 / 21 / 2013CCR was posted in public places. *(Attach list of locations)(See Attachment A)*Date Posted: 06 / 19 / 2013CCR was posted on a publicly accessible internet site at the address: **www.sscintranet.ssc.nasa.gov/safety.asp and www.ssccommunity.ssc.nasa.gov/library.asp****CERTIFICATION**

I hereby certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

David Lorange
Name/Title (President, Mayor, Owner, etc.)
David K. Lorange/Environmental Officer

7/2/2013
Date

Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215
Phone: 601-576-7518

2012 Consumer Confidence Report - Area 9

Is my water safe?

The John C. Stennis Space Center (SSC) continues to report as in years past, that the drinking water met the requirements of the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Only those contaminants that were detected are incorporated in this report.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

There are several aquifers that can be traced through Hancock County where Area 9 is located. The area is underlain by freshwater bearing, southward-tipping sands of Miocene and Pliocene ages. The sequence of alternating and discontinuous clay layers, creating the confining nature of the deeper aquifers, is part of the Catahoula Aquifer System. Area 9's drinking water well depths range from 600 to 700 feet with a natural flow of 1,500 gallons per minute.

Source water assessment and its availability

The Mississippi State Health Department (MSDH) conducts an annual compliant site review and we continue to maintain excellent water quality.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

How can I get involved?

See the Conservation Tips for how you can get involved at work as well as at home.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. AREA 9/PWS #MS0230052 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	0.63	0.12	0.63	2011	No	Water additive used to control microbes
THMs [Total Trihalomethanes] (ppb)	NA	80	3.64	NA		2012	No	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	NA	60	12	NA		2012	No	By-product of drinking water chlorination
Inorganic Contaminants								
Barium (ppm)	2	2	0.005	0.0045	0.005	2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Copper - source water (mg/L)		1.3	0.1216(MPL)	0.0065	0.1216	2011	No	Corrosion of household plumbing systems; Erosion of natural deposits

Lead - source water (ppm)		0.015	0.0038(MPL)	ND	0.0038	2011	No	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	4	4	0.383	0.375	0.383	2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Cyanide [as Free Cn] (ppb)	200	200	20	ND	20	2011	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories

Microbiological Contaminants

Total Coliform (positive samples/month)	0	1	0	NA		2012	No	Naturally present in the environment
---	---	---	---	----	--	------	----	--------------------------------------

<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
---------------------	-------------	-----------	-------------------	--------------------	-------------------------------	-------------------	-----------------------

Inorganic Contaminants

Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Jenette B. Gordon
Address:
B1100 Room 3021F
SSC, MS 39529
Phone: 228-688-1416
Fax: 228-688-6699
E-Mail: Jenette.B.Gordon@nasa.gov

Contact Name: Adam W. Murrah
Address:
B1100 Room 3021D
SSC, MS 39529
Phone: 228-688-1619
Fax: 228-688-6699
E-Mail: Adam.W.Murrah@nasa.gov

Attachment II
MSDH Public Water Notification Listing

Gordon, Jenette B. (SSC-RA02)

From: Gordon, Jenette B. (SSC-RA02)
Sent: Wednesday, June 19, 2013 10:26 AM
To: Lorance, David K. (SSC-RA02); Tripp Boone (Boone.Tripp@epamail.epa.gov); Lisa A Garcia (lagarcia@usgs.gov); 'sashby@gri.msstate.edu'; 'Keith.Long@usm.edu'; Merritt Tuel (Merritt.Tuel@usm.edu); john.wasserman@noaa.gov; Calehuff, Lou (Lou.Calehuff@nrlssc.navy.mil); Shelby, Terry D CIV N62306 (terry.shelby@navy.mil); david.everett@navsoc.socom.mil; Johnny.Finch@navsoc.socom.mil; william.samuels@navsoc.socom.mil; dona.scdc@yahoo.com; Good, Ronald W. (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Stewart, Marcia L. (SSC-JACOBS)[JACOBS TECHNOLOGY INC (SSC FOSC)]; Butler, Tabatha (SSC-A2R) [A2Research (SSC)]; HYDORN, RICKEY R. (SSC-NCCIPS)[SAIC - SSC]; Pulliam, LaSonya D PWR (LaSonya.Pulliam@rocket.com); Bonnie.Sanders@lmco.com; Patti Ferguson (Patti.Ferguson@nexweb.org); Flinders, Martin A (martin.a.flinders@rolls-royce.com) (martin.a.flinders@rolls-royce.com); dennis.w.marshall@lmco.com; Canady, Cynthia P. (SSC-PA20); Nelson.May@noaa.gov; Sciarabba, Peter J. (SSC-JACOBS)[JACOBS TECHNOLOGY INC (SSC FOSC)]; Smith, Sue L. (SSC-JACOBS)[COMPREHENSIVE OCCUPATIONAL RESOURCES]; Barnett, James C. (NSSC-XB000); philip.geraci@boetel.com; sangelo@pdi-entech.com; rtrussel@gpo.gov; mississippistormrider@yahoo.com; valoeie.wheat@navy.mil; pmorris@otiengineering.com; Case, Craig J SAM (Craig.J.Case@usace.army.mil); julie.boudin@qinetiq-na.com; brett.sturm@spr.doe.gov
Cc: etillman@usgs.gov; john.young@noaa.gov; Todd.Haverstic@nrlssc.navy.mil; Marshall.Dunn@navy.mil; Fannaly, Marion T. Civ NAVFAC SE, Stennis Western Maneuver Area (marion.fannaly@navy.mil); paul.reed@navsoc.socom.mil; phuong.nguyen@navsoc.socom.mil; Sever, James (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Watkins, Al E. (SSC-A2R)[A2Research (SSC)]; BARGER, MICHAEL S. (SSC-NCCIPS)[SAIC - SSC]; 'Kristi.Hurt@rocket.com'; 'Fulton, Keith B. (SSC-JACOBS)[ENGINEER RESOURCES COMPANY]'; 'Glen.A.Harriel@lmco.com'; Kennedy, Carolyn D. (SSC-RA02); MURRAH, ADAM W. (SSC-RA02); Miller, Daryl W. (SSC-JACOBS) [JACOBS TECHNOLOGY INC (SSC FOSC)]; Andrews, Lucius C. (SSC-JACOBS) [COMPREHENSIVE OCCUPATIONAL RESOURCES]
Subject: 2012 Consumer Confidence Reports
Attachments: 2012 Consumer Confidence Report MS0230015 0613.docx; 2012 Consumer Confidence Report Area 9- MS0230052 0613.docx

All,

The attached Consumer Confidence Reports (CCR) for the SSC Base Side and Area 9 drinking water is being sent to each of you to **post** in your respective areas of responsibility in accordance with Subpart O of 40 CFR 141.155/National Primary Drinking Water regulations. The ID #s for each system is as follows: Base Side # is MS0230015 and Area 9 # is MS0230052 . Neither of the water systems violated any water quality standards, which means we continue to provide good quality water to the SSC Base Side and Area 9 personnel. This information shall also be placed on the SSC Intranet Portal and published in the Orbiter.

A hard copy of this report is being sent to the Mississippi Department of Health per regulatory requirements.

If you have any questions, please give me a call as listed below or Adam Murrah @ 228-688-1619.

Sincerely,

Jenette

Jenette B. Gordon
Environmental Management Staff
B1100 Room 3017F
SSC, MS 39529-6000
Phone: (228) 688-1416
FAX: (228) 688-6699

'We do not inherit the earth from our ancestors, we borrow it from our children.'
~ Native American Proverb

2013 JUL -8 AM 10: 34

National Aeronautics and
Space Administration

John C. Stennis Space Center
Stennis Space Center, MS 39529-6000



July 2, 2013

Reply to the Attn: **RA02**

Ms. Melissa Parker
Mississippi Department of
Health
Post Office Box 1700
Jackson, MS 39215-1700

Dear Ms. Parker:

The John C. Stennis Space Center (SSC) is submitting the 2012 calendar year signed Consumer Confidence Report (CCR) Certification Form for public water system #s MS0230015 and MS0230052 (Area 9). The population for this reporting period was 5,082.

The CCR was electronically submitted to the Environmental Working Group members per the listing below, which consist of NASA contractors, resident government agencies, resident academia and other specific contact persons who will disseminate or post the CCR in their respective areas. The following materials are attached to demonstrate dissemination:

Attachment A/2012 CCR Certification Page

Attachment B/ Copy of the e-mail that was sent to the Environmental Working Group and the Federal City Listing of other agencies, contractors and academia

Attachment C/Copy of the Orbiter dated June 26, 2013

Attachment D/CCR Posted on the SSC's Intranet and Community Portals

If you have additional questions, please contact Ms. Jenette B. Gordon at (228) 688-1416 or Mr. Adam Murrah at (228) 688-1619.

Sincerely,

A handwritten signature in cursive script that reads "David K. Lorance". The signature is written in black ink and is followed by a horizontal line.

David K. Lorance
Environmental Officer

Enclosure

cc:

RA02/Adam Murrah

Attachment A
2012 CCR Certification

Attachment B

E-Mail to the Environmental Working Group, Resident Agencies, Academia and Other
Contact Listings

2013 JUL -8 AM 10: 35

Gordon, Jenette B. (SSC-RA02)

From: Gordon, Jenette B. (SSC-RA02)
Sent: Wednesday, June 19, 2013 10:26 AM
To: Lorance, David K. (SSC-RA02); Tripp Boone (Boone.Tripp@epamail.epa.gov); Lisa A Garcia (lagarcia@usgs.gov); 'sashby@gri.msstate.edu'; 'Keith.Long@usm.edu'; Merritt Tuel (Merritt.Tuel@usm.edu); john.wasserman@noaa.gov; Calehuff, Lou (Lou.Calehuff@nrlssc.navy.mil); Shelby, Terry D CIV N62306 (terry.shelby@navy.mil); david.everett@navsoc.socom.mil; Johnny.Finch@navsoc.socom.mil; william.samuels@navsoc.socom.mil; dona.scdc@yahoo.com; Good, Ronald W. (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Stewart, Marcia L. (SSC-JACOBS)[JACOBS TECHNOLOGY INC (SSC FOSC)]; Butler, Tabatha (SSC-A2R) [A2Research (SSC)]; HYDORN, RICKEY R. (SSC-NCCIPS)[SAIC - SSC]; Pulliam, LaSonya D PWR (LaSonya.Pulliam@rocket.com); Bonnie.Sanders@lmco.com; Patti Ferguson (Patti.Ferguson@nexweb.org); Flinders, Martin A (martin.a.flinders@rolls-royce.com) (martin.a.flinders@rolls-royce.com); dennis.w.marshall@lmco.com; Canady, Cynthia P. (SSC-PA20); Nelson.May@noaa.gov; Sciarabba, Peter J. (SSC-JACOBS)[JACOBS TECHNOLOGY INC (SSC FOSC)]; Smith, Sue L. (SSC-JACOBS)[COMPREHENSIVE OCCUPATIONAL RESOURCES]; Barnett, James C. (NSSC-XB000); philip.geraci@boetel.com; sangelo@pdi-entech.com; rtrussel@gpo.gov; mississippistormrider@yahoo.com; valoeie.wheat@navy.mil; pmorris@otiengineering.com; Case, Craig J SAM (Craig.J.Case@usace.army.mil); julie.boudin@qinetiq-na.com; brett.sturm@spr.doe.gov
Cc: etillman@usgs.gov; john.young@noaa.gov; Todd.Haverstic@nrlssc.navy.mil; Marshall.Dunn@navy.mil; Fannaly, Marion T. Civ NAVFAC SE, Stennis Western Maneuver Area (marion.fannaly@navy.mil); paul.reed@navsoc.socom.mil; phuong.nguyen@navsoc.socom.mil; Sever, James (SSC-ARTS)[ASRC Research & Technology Solutions LLC (SSC)]; Watkins, Al E. (SSC-A2R)[A2Research (SSC)]; BARGER, MICHAEL S. (SSC-NCCIPS)[SAIC - SSC]; 'Kristi.Hurt@rocket.com'; 'Fulton, Keith B. (SSC-JACOBS)[ENGINEER RESOURCES COMPANY]'; 'Glen.A.Harriel@lmco.com'; Kennedy, Carolyn D. (SSC-RA02); MURRAH, ADAM W. (SSC-RA02); Miller, Daryl W. (SSC-JACOBS) [JACOBS TECHNOLOGY INC (SSC FOSC)]; Andrews, Lucius C. (SSC-JACOBS) [COMPREHENSIVE OCCUPATIONAL RESOURCES]
Subject: 2012 Consumer Confidence Reports
Attachments: 2012 Consumer Confidence Report MS0230015 0613.docx; 2012 Consumer Confidence Report Area 9- MS0230052 0613.docx

All,

The attached Consumer Confidence Reports (CCR) for the SSC Base Side and Area 9 drinking water is being sent to each of you to **post** in your respective areas of responsibility in accordance with Subpart O of 40 CFR 141.155/National Primary Drinking Water regulations. The ID #s for each system is as follows: Base Side # is MS0230015 and Area 9 # is MS0230052 . Neither of the water systems violated any water quality standards, which means we continue to provide good quality water to the SSC Base Side and Area 9 personnel. This information shall also be placed on the SSC Intranet Portal and published in the Orbiter.

A hard copy of this report is being sent to the Mississippi Department of Health per regulatory requirements.

If you have any questions, please give me a call as listed below or Adam Murrah @ 228-688-1619.

The potential areas where the report could be posted are as follows and the asterisk (*) indicates those areas that have accessibility to the SSC internal website:

Working Group Members & Other Contacts	Agency	Building Location
Tripp Boone	U. S. EPA	1105
Terry Shelby/Rodney Dunn	Naval Oceanographic Office	1000, 1002, 1100, 1005, 1032, 1011, 2406, 9134, 9307, 9600
Lisa Garcia Evan Tillman	United States Geological Survey/HIF	2101
John Wasserman John Young	National Data Buoy Center	3202, 3203, 3206
Lou Calehuff	Naval Research Lab	1005, 1007, 1009
Merritt Tuel	University Southern Mississippi	1020, 1022
Steve Ashby	Mississippi State University	1021
Keith Long	Mississippi Enterprise for Technology	1103
Nelson May Walt Gandy	National Marine Fisheries Service	1100
*Cindy Canady Patty Ferguson	NASA Concessionaires	1100, 3225, 3226, 2124, 2411, 3219, 9101
*Kristi Hurt Lasonya Pulliam	Aerojet Rocketdyne	4120, 4220, 4995, 4122, 4301, 9101
*Peter Sciarabba Darryl Miller	Jacobs/FOSC	2109, 8100
*Marcia Stewart	Jacobs/FOSC	1100, 1200, 2105, 2204, 2201, 2205, 8000, 9104
*Bonnie Sanders	Lockheed/TOC	8201, 8301, 4010, 3305, 3407, 4400, 410, 3226
*Ronald Good Jim Sever	Computer Science	1100 (1 st & 2 nd floor), 1105, 1110, 1210, 1201T
*Al Watkins/ Tabatha Butler	A2R	8100, 8110, 9801
*Dr. Lucius Andrews	Jacobs/Clinic	8000

Sue L. Smith		
Johnny Finch	SBT-22	2601, 2602, 2603, 2604, 2605,
David Everett	USSOCOM	2108, 2109, 2110, 2119, 9600
Jim Barnett	NSSC	1111
Matthew Martini	NAVSCIATTS	2606
William Samuels	NAVSCIATTS	2104, 2606, 9312
Dona Stewart	Navy/Child Care	2120
Martin Flinders	Rolls Royce	5001, 5003, 5005, 5008
Glen Harriel Dennis Marshall	Lockheed Martin	5100
Philip Geraci	Boe-Tel	8302
Sharon Angelo	Entech Systems/PDI	9101, 9166
Rachel Trussell	GPO	9101
Hugh Fouquet	DaKitchen	9110
Valorie Wheat	Navy HR	9110
Phillip Morris	OMNI	9115
Craig Case	COE	9119, 9801
Julie Boudin	QinetiQ	9121
Rick Hydorn	NCCIPS	9300, 9302, 9306, 9308-9311, 9315-9321, 9323-9333, 9348, 9353, 9354
Brett Sturm	DOE	9355

Attachment C
SSC Newspaper/Orbiter Notice



John C. Stennis Space Center

ORBITER

Wednesday, June 26, 2013

Features in this issue:

- *SSC Drinking Water Report Available*
- *Protecting Privacy Webinar, TOMORROW*
- *Save the Date: 2013 SSC Gala*
- *NASA Exchange Announcements*
- *Training Courses Available in SATERN*
- *Legal Corner: Subcommittee on Space*
- *History Article: First S-II-T and External Tank*
- *Safety Tip: Firework Safety*

Orbiter is produced for employees by the NASA Stennis Space Center Office of Communications. *Orbiter* is distributed every Wednesday. **The deadline for content submission is noon on Monday prior to the week's issue.** Current and previous editions of *Orbiter* may be downloaded from the Stennis Intranet. To submit a news brief to *Orbiter*, contact Samone Faulkner at 688-3346, or send submission to Samone.Faulkner@nasa.gov.

SSC Drinking Water Report Available

The Consumer Confidence Reports (CCR) for the SSC Base Side and Area 9 drinking water is available in accordance with Subpart O of 40 CFR 141.155/National Primary Drinking Water regulations. This report shows that neither water system violated any water quality standards, which means we continue to provide good quality water to the SSC Base Side and Area 9 personnel.

To read the full reports, visit the SSC Intranet Portal at:

http://ssccommunity.ssc.nasa.gov/documents/SSC_WaterQualityReport.pdf

http://ssccommunity.ssc.nasa.gov/documents/SSC_WaterQualityReport_Area9.pdf


Protecting Privacy Webinar, TOMORROW

The NASA IT Security Awareness and Training Center will host a "Protecting Privacy" webinar on Thursday, June 27 from 11:30 a.m. - 1 p.m. in the Estess Building, Room 235. The presenter will be Bryan McCall, NASA Privacy and SBU Programs Manager. This presentation will cover the importance of protecting privacy and sensitive information.

Attachment D
Copy of SSC's Intranet & Community Portal Pages

2013 JUL -8 AM 10: 35

Home |



John C. Stennis Space Center

SSC Intranet Portal

Search:

[Advanced Search](#)

[Collapse/Expand Quick LINKS](#)

- Organizations
- Councils & Boards
- Director's Office
- Employee Services
- Systems & Applications
- Safety, Security, & Health
- Health
- People Search
- Programs & Initiatives
- Information
- Technology
- Reference Library

Safety, Security, & Health

SSC Safety Policy - Everyone working together creates our safe environment.

- [Office of Safety & Mission Assurance \(OSMA\)](#)
- [Close Call Reporting System \(CCRS\)](#)
- [Ergonomic Risk Assessment System \(ERGO\)](#)
- [Ergonomic Risk Assessment, Tracking, and Evaluation System \(ERATES\)](#)
- **"For Industrial Hygienist and Ergonomists Only"**
- [NASA Safety Reporting System \(NSRS\)](#)
- [Occupational Health Services \(Medical Clinic, EAP, Wellness Center, & Industrial Hygiene\)](#)
- [Office of Protective Services](#)
- [Permit Required Confined Space Database](#)
- [Safety Advisories Administration](#)
- [Safety Management Review](#)
- [Safety Management Review Administration](#)
- [SafetySmart](#)
- [Single Visitor Request](#)
- [SSC Counterintelligence](#)
- [SSC Incident Command Post](#)
- [SSC Integrated Risk Management](#)
- [SSC Safety Advisories](#)
- [SSC Water Quality Consumer Confidence Report](#)
- [SSC Water Quality Consumer Confidence Report - Area 9](#)
- [Striving to Achieve Real Safety \(STARS\)](#)

Featured Video



[April 2009 Safety Day Stand Down \(HD\)](#)



[Process Safety Management](#)



[It's Not My Job](#)



2009 Safety Day: [Emergency Response](#)



[Embody Health](#)



[JSC Bldg 37 Electrocution Mishap](#)



2008 Safety Day: [Environmental Health - Mike Blotzer](#)



2008 Safety Day: [SSC Managers Safety Presentation](#)




2008 Safety Day: [Guest Speaker - John Martin](#)



2008 Safety Day: [Hazard Awareness Presentation](#)

2013 JUL -8 AM 10: 35

Home |



John C. Stennis Space Center

SSC Community Portal

SSC PUBLIC WEBSITE

ACCESS REQUEST SYSTEM (ARS)

NASA.GOV

Search:


[Advanced Search](#)

NASA Exchange

Reference Library


- Office of
- Protective Services
- Stennis Diversity
- Council
- SSC Occupational
- Health Services
- Reference Library
- SSC Telephone
- Book
- Lunch Menus

- [Federal City Handbook](#)
- [Maury Library](#)
- [NASA Acronyms](#)
- [NASA Electronic Forms](#)
- [SSC Water Quality Consumer Confidence Report](#)
- [SSC Water Quality Consumer Confidence Report - Area 9](#)
- [Stennis Image Retrieval System \(SIRS\)](#)



Curator: SDC Operations, x2525 opt 3 NASA Official: Charles Hallal SSC Community Portal NASA Web Privacy Policy

National Aeronautics and
Space Administration
John C. Stennis Space Center
Stennis Space Center, MS 39529-6000



June 19, 2013

Reply to the Attn: RA02

Ms. Melissa Parker
Mississippi Department of
Health
Post Office Box 1700
Jackson, MS 39215-1700

Dear Ms. Parker:

The John C. Stennis Space Center (SSC) is submitting the 2012 calendar year Consumer Confidence Report (CCR) for public water system #s MS0230015 and MS0230052. The population for this reporting period was 5,082. This report is inclusive of data for Area 9.

This letter includes a listing of the Environmental Working Group members, which consist of NASA and NASA contractors, resident government agencies, resident academia, independent companies and representatives who shall disseminate or post the CCR in their respective areas.

The attachments for this submission are:

Attachment I - CY 2012 CCRs for

- PWS # MS0230015
- PWS # MS0230052

Attachment II- Copy of the e-mail that was forwarded to the listing noted. Information was placed on the SSC Community website, which is available to all resident agencies at <http://ssccommunity.ssc.nasa.gov/library.asp>

The CCR Certification form shall be forwarded to you under separate cover letter to meet the October 1st deadline.

The potential areas where the report could be posted are as follows and the asterisk (*) indicates those areas that have accessibility to the SSC internal website:

Working Group Members & Other Contacts	Agency	Building Location
Tripp Boone	U. S. EPA	1105
Terry Shelby/Rodney Dunn	Naval Oceanographic Office	1000, 1002, 1100, 1005, 1032, 1011, 2406, 9134, 9307, 9600
Lisa Garcia Evan Tillman	United States Geological Survey/HIF	2101
John Wasserman John Young	National Data Buoy Center	3202, 3203, 3206
Lou Calehuff	Naval Research Lab	1005, 1007, 1009
Merritt Tuel	University Southern Mississippi	1020, 1022
Steve Ashby	Mississippi State University	1021
Keith Long	Mississippi Enterprise for Technology	1103
Nelson May Walt Gandy	National Marine Fisheries Service	1100
*Cindy Canady, Patty Ferguson	NASA Concessionaires	1100, 3225, 3226, 2124, 2411, 3219, 9101
*Kristi Hurt Lasonya Pulliam	Pratt-Whitney Rocketdyne	4120, 4220, 4995, 4122, 4301, 9101
*Peter Sciarabba Darryl Miller	Jacobs/FOSC	2109, 8100
*Marcia Stewart	Jacobs/FOSC	1100, 1200, 2105, 2204, 2201, 2205, 8000, 9101
*Bonnie Sanders	Lockheed/TOC	8201, 8301, 4010, 3305, 3407, 4400, 4120, 3226
*Ronald Good Jim Sever Stacy Brunson	ARTS	1100 (1 st & 2 nd floor), 1105, 1110, 1210, 1201T
*Al Watkins/ Tabatha Butler	A2R	8100, 8110, 9801
*Dr. Lucius Andrews Sue L. Smith	Jacobs/Clinic	8000

Johnny Finch	SBT-22	2601, 2602, 2603, 2604, 2605
David Everett	USSOCOM	2108, 2109, 2110, 9600, 2119
Jim Barnett	NSSC	1111
William Samuels	NAVSCIATTS	2606, 2104, 9312
Dona Stewart	Navy/Child Care	2120
Martin Flinders	LMSO/Rolls Royce	5001, 5003, 5005, 5008
Glen Harriel	Lockheed Martin	5100
Phillip Geraci	Boe-Tel	8302
Sharon Angelo	Entech Systems/PDI	9101, 9166
Rachel Trussell	GPO	9101
Hugh Fouquet	DaKitchen	9110
Valorie Wheat	Navy HR	9110
Philip Morris	OMNI	9115
Craig Case	COE	9119, 9801
Julie Boudin	QinetiQ	9121
Rick Hydoro	NCCIPS	9300, 9302, 9306, 9308-9311, 9315- 9321, 9323-9333, 9348, 9353, 9354
Brett Sturm	DOE	9355

If you desire to know more about SSC's Water System compliance history, please contact the Mississippi Department of Health representative, Ms. Karen Walters at (601) 576-7518.

If you have additional questions, please contact Ms. Jenette B. Gordon at (228) 688-1416 or Mr. Adam Murrah at (228) 688-1619.

Sincerely,



David K. Lorance
Environmental Officer

Enclosure

cc:
RA02/Adam Murrah

Attachment I
CCR for PWS # MS0230015 & PWS # MS0230052