

MISSISSIPPI STATE DEPARTMENT OF HEALTH 2013 JUL -1 AM 9:46  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION FORM  
CALENDAR YEAR 2012

Public Water Supply Name 0450002  
BEAR CREEK WATER ASSN. INC 0450021  
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
  - Advertisement in local paper (attach copy of advertisement)
  - On water bills (attach copy of bill)
  - Email message (MUST Email the message to the address below)
  - Other \_\_\_\_\_

Date(s) customers were informed: \_\_\_ / \_\_\_ / \_\_\_ , \_\_\_ / \_\_\_ / \_\_\_

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: 6/28/13

- CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_ / \_\_\_ / \_\_\_
  - As a URL (Provide URL \_\_\_\_\_)
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*  
Name of Newspaper: \_\_\_\_\_  
Date Published: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_ / \_\_\_ / \_\_\_

- CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED): \_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Brenda Vothel PRES  
Name/Title (President, Mayor, Owner, etc.)

6/27/2013  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
Melanie.Yanklowski@msdh.state.ms.us

2013 MAY -3 PM 3:42

2012 Annual Drinking Water Quality Report  
Bear Creek Water Association, Inc.  
PWS ID#:0450021 & 0450002  
April 2013

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Cockfield Formation, Sparta Sand Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Bear Creek Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact H. A. "Tony" McMullen, Jr. at 601-856-5969. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held by the 10<sup>th</sup> of each month at 5:00 PM at 301 Distribution Dr., Madison, MS 39110.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**PWS ID#: 0450021****TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2012	.016	.002 - .016	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012	2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2010*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2012	.764	.131 - .764	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2010*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2012	10	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2012	8.55	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2012	1.20	1 - 2	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2012.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l

**PWS ID#: 0450002****TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2012	.03	.001 - .03	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012	4.7	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2010*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2012	.451	.186 - .451	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2010*	2	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products</b>								
81. HAA5	N	2012	4	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2012	4.19	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2012	1.30	.6 - 2.7	mg/l	0	MDRL = 4	Water additive used to control microbes

*\* Most recent sample. No sample required for 2012.*

*\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.*

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the BEAR CREEK W/A-WEST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 91%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the BEAR CREEK W/A -EAST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 90%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

**\*\*\*\*\*April 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING\*\*\*\*\***

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 – December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Bear Creek Water Association works continuously to provide top quality water to every tap. Bear Creek has received an excellent score with MS State Department of Health for capacity development. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goals is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Cockfield Formation, Sparta Sand Aquifers.



The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Bear Creek Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact H. A. "Tony" McMullen, Jr. at 601-856-5969. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held by the 10th of each month at 5:00 PM at 301 Distribution Dr. Madison, MS 39110.


We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2012. In cases where monitoring wasn't required in 2012, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.



P.O. BOX 107  
CANTON, MS 39046

BEAR CREEK  
WATER ASSOCIATION

# WATER QUALITY REPORT



PWSID 0450021 & 0450002  
JULY 2013

RECEIVED WATER SUPPLY  
2013 JUL -1 AM 9:46

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000,000.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however the EPA has determined that your water is SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7592 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the BEAR CREEK W/A-WEST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 91%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the BEAR CREEK W/A-EAST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 90%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

## PWS ID #0450021 - TEST RESULTS

Contaminant	Unit	Date Collected	Level Detected	Range of Defects or No. of Samples Exceeding MCL/AQL	Unit Measurement	MCLG	MCL
<b>Inorganic Contaminants</b>							
10. Barium	N	2012	.016	.002 - .016	ppm	2	2
<i>Likely Source of Contamination: Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits</i>							
13. Chromium	N	2012	2	No Range	ppb	100	100
<i>Likely Source of Contamination: Discharge of slat and pulp mills; erosion of natural deposits</i>							
14. Copper	N	2010*	.2	0	ppm	1.3	AL=1.3
<i>Likely Source of Contamination: Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives</i>							
16. Fluoride**	N	2012	.764	.131 - .764	ppm	4	4
<i>Likely Source of Contamination: Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories</i>							
17. Lead	N	2010*	2	0	ppb	0	AL=15
<i>Likely Source of Contamination: Corrosion of household plumbing systems; erosion of natural deposits</i>							

## Disinfection By-Products

81. HAA5	N	2012	10	No Range	ppb	0	60
<i>Likely Source of Contamination: By-Product of drinking water disinfection</i>							
82. THM (Total trihalomethanes)	N	2012	8.55	No Range	ppb	0	80
<i>Likely Source of Contamination: By-product of drinking water chlorination</i>							
Chlorine	N	2012	1.20	1 - 2	mg/l	0	MDRL=4
<i>Likely Source of Contamination: Water additive used to control microbes</i>							

## PWS ID #0450002 - TEST RESULTS

Contaminant	Unit	Date Collected	Level Detected	Range of Defects or No. of Samples Exceeding MCL/AQL	Unit Measurement	MCLG	MCL
<b>Inorganic Contaminants</b>							
10. Barium	N	2012	.03	.001 - .03	ppm	2	2
<i>Likely Source of Contamination: Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits</i>							
13. Chromium	N	2012	4.7	No Range	ppb	100	100
<i>Likely Source of Contamination: Discharge from steel and pulp mills; erosion of natural deposits</i>							
14. Copper	N	2010*	.3	0	ppm	1.3	AL=1.3
<i>Likely Source of Contamination: Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives</i>							
16. Fluoride**	N	2012	.451	.186 - .451	ppm	4	4
<i>Likely Source of Contamination: Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories</i>							
17. Lead	N	2010*	2	No Range	ppb	0	AL=15
<i>Likely Source of Contamination: Corrosion of household plumbing systems; erosion of natural deposits</i>							

## Disinfection By-Products

81. HAA5	N	2012	4	No Range	ppb	0	60
<i>Likely Source of Contamination: By-Product of drinking water disinfection</i>							
82. THM (Total trihalomethanes)	N	2012	4.19	No Range	ppb	0	80
<i>Likely Source of Contamination: By-product of drinking water chlorination</i>							
Chlorine	N	2012	1.30	.6 - 2.7	mg/l	0	MDRL = 4
<i>Likely Source of Contamination: Water additive used to control microbes</i>							

\* Most recent sample. No sample required for 2012.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l

### APRIL 1, 2013 A MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at 601.576.7518.

The Bear Creek Water Association works continuously to provide top quality water to every tap. Bear Creek has received an excellent score with MS State Department of Health for capacity development. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2013 JUL -1 AM 9:46

PS Form 3602-R - Standard Mail - Permit Imprint

Final

Postage Summary

Account Holder:	AMERIMAIL 125 E SOUTH ST JACKSON, MS 39201 -5106  Contact: LISA BROWN (601) 948 - 6245 Ext. 223 JOrgeron@amerimaildirect.com	Mailing Agent:	AMERIMAIL DIRECT, INC. 125 E SOUTH ST JACKSON, MS 39201 -5106	Org. For Mailing is Prepared:	BEAR CREEK WATER ASSOCIATION PO BOX 107 CANTON, MS 39046 -0107		
Account Number:	26369						
Permit:	Permit Imprint 369 Price Eligibility: Regular CRID: 4593802			Processing Category:	Letters CRID: 6370616		
Post Office Of Mailing:	JACKSON MS 39201-9650	Mailer's Mailing Date:	06/27/2013	Weight of Single Piece:	0.0200 lbs.		
Post Office of Permit:	JACKSON MS 39201-9650						
Total Pieces:	11,287 pcs.	Total Weight:	225.7400 lbs.	Total Postage:	\$ 2,342.20		
Sequencing Date:	06/06/2013	Address Matching Date - Automation:	06/06/2013	Address Matching Date - Carrier Route:	06/06/2013		
No of Containers:	1' MM Trays 7	2' MM Trays 8	2' EMM Trays	Fiat Trays	Sacks	Pallets	Other
Move Update Method:	NCOALink	NSA:	NO				
Mailpiece is a product sample: NO			Mailpieces contain a DVD/CD or other Disk: NO				
Incentive/Discount Claimed: N/A			Type of Fee: N/A				
Mail Arrival Date and Time: 06/27/2013 11:18		Payment Date and Time: 06/27/2013 11:19		Caps Transaction Number:: 2013062711193501M1			
Comments:							
Copal Mailing Type:							

Part A: Automation Letters

Line Number	Entry Discount	Title	Description	Price	Quantity	Subtotal Postage	Discount Total	Fee Total	Postage	
A4	NONE	Mixed AADC	Letters 3.3 oz (0.2063 lbs) or less	0.282	100pcs.	28.2000	\$ 0.0000	0	\$ 28.2000	
A9	DSCF	5-Digit	Letters 3.3 oz (0.2063 lbs) or less	0.204	10451pcs.	2,132.0040	\$ 0.0000	0	\$ 2,132.0040	
A10	DSCF	3-Digit	Letters 3.3 oz (0.2063 lbs) or less	0.223	387pcs.	86.3010	\$ 0.0000	0	\$ 86.3010	
A23			Standard Mail Automation Letters Subtotal (Add lines A1-A22)						\$ 2,246.5050	
									Part A Total (Line A23 minus A24)	\$ 2,246.5050

Part B: Nonautomation Letters

Line Number	Entry Discount	Title	Description	Price	Quantity	Subtotal Postage	Discount Total	Fee Total	Postage	
B1	NONE	AADC	Machinable Letters 3.3 oz (0.2063 lbs) or less	0.274	345pcs.	94.5300	\$ 0.0000	0	\$ 94.5300	
B2	NONE	Mixed AADC	Machinable Letters 3.3 oz (0.2063 lbs) or less	0.290	4pcs.	1.1600	\$ 0.0000	0	\$ 1.1600	
									Part B Total (Add lines B1-B27)	\$ 95.6900
									<b>Total Postage From All Parts</b>	<b>\$ 2,342.1950</b>
									<b>Total Postage</b>	<b>\$ 2,342.20</b>

Certification

The mailer's signature certifies acceptance of liability for and agreement to pay any revenue deficiencies assessed on this mailing, subject to appeal. If an agent signs this form, the agent certifies that he or she is authorized to sign on behalf of the mailer, and that the mailer is bound by the certification and agrees to pay any deficiencies. In addition, agents may be liable for any deficiencies resulting from matters within their responsibility, knowledge, or control.

I hereby certify that all information furnished on this form is accurate, truthful, and complete; that the mail and the supporting documentation comply with all postal standards and that the mailing qualifies for the prices and fees claimed; and that the mailing does not contain any matter prohibited by law or postal regulation.

I understand that anyone who furnishes false or misleading information on this form or who omits information requested on the form may be subject to criminal and/or civil penalties, including fines and imprisonment.

Signature

Signature of Mailer or Agent	Name of Mailer or Agent	Telephone
	Lisa Brown	(601) 948 - 6245

Facsimile Form 3602-R

USPS Use Only

Weight of a Single Piece		Are figures at left adjusted from mailer's entries? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, Give Reason
Total Pieces 11,287 pcs.	Total Weight 225.7400 lbs.	Date Mailer Notified
Total Postage \$2,342.20		Contact
Presort Verification: Check One (If Applicable) <input type="checkbox"/> Not Scheduled <input type="checkbox"/> Performed		By (Initials)
I CERTIFY that this mailing has been inspected concerning: (1) eligibility for postage price claimed; (2) Proper preparation (and presort where required); and (3) proper completion of postage statement; and (4) payment of annual fee (if required).		
Verifying Employee's Signature		Verifying Employee's Name
		Round Stamp Required
Optional Procedure No	Location Code 0015A	Mailing Date

Facsimile Form 3602-R

No signature or round stamp required statement has been submitted electronically through the PostalOne! System.

Verification	Request Source	Performance Status	Disposition	Performance Type	Performance Percentage	Additional Postage	Cost Avoidance
eMIR Cursory review		Not Performed	N/A		N/A		
MERLIN	Verification not requested by system	Not Performed	N/A		N/A		
Content Eligibility	Verification not requested by system	Not Performed	N/A		N/A		
Mailing Review	Verification not requested by system	Not Performed	N/A		N/A		
Labeling Review	Verification not requested by system	Not Performed	N/A		N/A		
Mailpiece Review	Verification not requested by system	Not Performed	N/A		N/A		
Documentation/Postage Statement Review	Verification not requested by system	Not Performed	N/A		N/A		
<b>Total:</b>						<b>\$0.00</b>	<b>\$0.00</b>

This mailing has been inspected concerning:  
 (1) eligibility for postage prices claimed;  
 (2) proper preparation (and presort where required);  
 (3) proper completion of postage statement; and  
 (4) payment of annual fee (if required).

This postage statement was verified and accepted under the PostalOne! program. No postal signature or round stamp is required.