

Wheeler Frankstown Water Association

Public Water Supply Name

0590014

PWS ID # ('s):

The Federal Safe Drinking Water Act requires each Community public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **Since this is the first year of electronic delivery, we request you mail or fax a hard copy of the CCR and Certification Form to MSDH. Please check all boxes that apply.**
Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- E-mail message (MUST Email the message to the address below)
- Other *posted at Post office in wheeler*

Date customers were informed: *5/13/13 . 1 1 . 1 1*

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date mailed/distributed: *1 1*

CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: *Banner Independent*
Date Published: *6 16 113*

CCR was posted in public places. *(Attach list of locations)* Date posted: *5 129 113*

CCR was posted on a publicly accessible internet site at the address: **(DIRECT URL REQUIRED):**

CERTIFICATION:

I hereby certify that the 2012 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Lenny S. Brown

Name/Title (President, Mayer, Owner, etc.)

6-10-13

Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Boyette

Signature

5/17/13

Date

Deliver or send via U. S. Postal Service:
Bureau of Public Water Supply
P O Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

Annual Drinking Water Quality Report
Wheeler-Frankstown Water Association
PWS ID # 0590014
June, 2013
CORRECTED

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of five wells that draw from the Eutaw Formation Aquifer,

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Wheeler-Frankstown Water Association received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jimmy Glover at 662-365-8750. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at the Wheeler-Frankstown Water Association office at 6:00 p.m.

Wheeler-Frankstown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Combined radium	N	2011*	.630	None	PCi/l	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2010*	0.1	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010*	1.8	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/10 to 12/31/12*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	1/1/10 to 12/31/12*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
21. Selenium	N	2010*	1	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Volatile Organic Contaminants								
66. Ethylbenzene	N		17.4	None	ppb	700	700	Discharge from petroleum refineries
76. Xylenes	N		5.32	None	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	N	1/1/12 to 12/31/12	0.90	0.60 to 1.20	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

***** APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wheeler-Frankstown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you would like a copy or have any questions.

2013 JUN 17 AM 9:00

*Annual Drinking Water Quality Report
Wheeler-Frankstown Water Association
PWS ID #0590014
May, 2013*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of five wells that draw from the Eutaw Formation Aquifer.

A source water assessment has been completed for the Wheeler-Frankstown Water Association's water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Wheeler-Frankstown Water Association received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jimmy Glover at 662-365-8750. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at the Wheeler-Frankstown Water Association office at 6:00 p.m.

Wheeler-Frankstown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Combined radium	N	2011*	.630	None	PCi/l	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2010*	0.1	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2010*	1.8	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/10 to 12/31/12	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservative
17. Lead	N	1/1/10 to 12/31/12	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2010*	1	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfectants & Disinfection By-Products								
Chlorine (as Cl ₂)	N	1/1/12 to 12/31/12	0.90	0.60 to 1.20	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

*****APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wheeler-Frankstown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested..

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the newspaper will not be mailed. Please call our office if you would like a copy or have any questions.

2013 JUN 17 AM 9:00

\$ 302.40

Annual Drinking Water Quality Report
Wheeler-Frankstown Water Association
PWS ID H0390014
May, 2013

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of five wells that draw from the Eutaw Formation Aquifer.

A source water assessment has been completed for the Wheeler-Frankstown Water Association's water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Wheeler-Frankstown Water Association received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jimmy Glover at 662-365-8750. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at the Wheeler-Frankstown Water Association office at 6:00 p.m.

Wheeler-Frankstown Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2012. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS									
Contaminant	Violations Y/N	Date Collected	Level Detected	Range of Detect or # of Samples Exceeding MCL/AC	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Radioactive Contaminants									
6. Combined radium	N	2011*	.630	None	PCU/l	0	5	Erosion of natural deposits	
Inorganic Contaminants									
10. Barium	N	2010*	0.1	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N	2010*	1.8	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
14. Copper	N	1/11/10 to 12/3/12	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing system; erosion of natural deposits; leaching from wood preservative	
17. Lead	N	1/11/10 to 12/3/12	1	None	ppb	0	AL=15	Corrosion of household plumbing system; erosion of natural deposits	
21. Selenium	N	2010*	1	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines	
Disinfectants & Disinfection By-Products									
Chlorine (as Cl ₂)	N	1/11/10 to 12/3/12	0.90	0.60 to 1.20	ppm	4	4	Water additive used to control microbes	

* Most recent sample results available

*****APRIL 1, 2013 MESSAGE FROM MSDH CONCERNING RADIOLOGICAL SAMPLING*****
In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 - December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that as of this date, your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rules. If you have any questions, please contact Karen Walters, Director of Compliance and Enforcement, Bureau of Public Water Supply, at 601-576-7518.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wheeler-Frankstown Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the newspaper will not be mailed. Please call our office if you would like a copy or have any questions.

OF PUBLICATION

OF MISSISSIPPI
TY OF PRENTISS

I, Teresa C. Smith
lic in and for said county, or other
ed to administer oaths, this day
me the undersigned official of The
endent, a newspaper published
City of Booneville, in Prentiss
e of Mississippi, who, being duly
s that the notice, a true copy of
to attached, was published in the
wspaper for one consecutive

- Number 16, June 06, 2013
- Number _____, _____, 20__
- Number _____, _____, 20__
- Number _____, _____, 20__
- Number _____, _____, 20__
- Number _____, _____, 20__
- Number _____, _____, 20__
- Number _____, _____, 20__

[Signature]
Editor

Day of June, 2013

Teresa C. Smith
Notary Public
2-1-14
My Commission Expires _____

if _____, 20__

WATER BILL

WHEELER-FRANKSTOWN WATER ASSOC.
 P.O. BOX 157
 WHEELER, MS 38880
 365-8750

PRE-SORTED
 FIRST CLASS MAIL
 U.S. POSTAGE PAID
 PERMIT NO. 103
 WHEELER, MS 38880

DUPLICATE	BILLING DATE	DUPLICATE	DATE METER READ	ADDRESS SERVICE REQUESTED
06-10-13	05-30-13	06-10-13	05-02-13	
DESCRIPTION	CHARGES	DESCRIPTION	CHARGES	
WATER	375.40	WATER	575.40	
VOL-FIRE	223.60	VOL-FIRE	223.60	
ACCOUNT NO.	TOTAL DUE	ACCOUNT NO.	TOTAL DUE	
001341	599.00	001341	599.00	
AFTER 05-10-13 PAID 35.54	GROSS	SVC ADDRESS 0 BOX 179	IF NOT PAID BEFORE	
WHEELER PUBLIC SCHOOLS		2013 CONSUMER CONFIDENCE REPORT AVAILABLE	06-10-13	
		IN OFFICE UPON REQUEST.	636.54	

PREVIOUS METER READING
 20110600
 CURRENT METER READING
 20197400

USAGE IN GALLONS
 86800
 AVERAGE DAILY USAGE
 2893
 USAGE SAME PERIOD LAST YR
 85900

WHEELER PUBLIC SCHOOLS
 P O BOX 179
 BOONEVILLE MS 38829-

RECEIVED - WATER SUPPLY
 2013 JUN 17 AM 9:00

WATER BILL

WHEELERWATER, DOWN WATER CSD#6
 P.O. BOX 102
 WHEELER FL 32082
 904/4700

07-10-13	06-27-13	07-10-13	06-12-13
WATER	WATER	WATER	WATER
31.15	31.15	31.15	31.15
118900	118900	118900	118900

SEWER	SEWER	SEWER	SEWER
1.00	1.00	1.00	1.00
5800	5800	5800	5800

DEPOSIT REFUND	DEPOSIT REFUND	DEPOSIT REFUND	DEPOSIT REFUND
-20.00	-20.00	-20.00	-20.00
193	193	193	193

002252	002252	002252	002252
12.15	12.15	12.15	12.15
15300	15300	15300	15300

KEN PUGH
 1724 SW 15TH TERRACE CAPE
 CORAL FL 33991

CORRECTED COPY OF 2013 CCR REPORT
 AVAILABLE UPON REQUEST AT OFFICE

Wheeler-Frankstown Water Association

(662) 365-8750

RECEIVED - WATER SUPPLY

2013 JUN 17 AM 9:00

P.O. Box 157
Wheeler, Mississippi 38880

GEORGE E. ALLEN LIBRARY, BOONEVILLE, MS

WHEELER WATER OFFICE, WHEELER MS

WHEELER POST OFFICE , WHEELER, MS