

5/12/14

WATER SUPPLY
2014 MAY 12 AM 9:06

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

Town of Maatachie
Public Water Supply Name
290005
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 5/1/14, 5/8/14, / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Area Promoter
Date Published: 5/8/14

CCR was posted in public places. *(Attach list of locations)* Date Posted: 5/8/14

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):
Maatachie Town Hall

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Jeff Butler (Mayor)
Name/Title (President, Mayor, Owner, etc.)

5-7-14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800
May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

RW 6

2013 Annual Drinking Water Quality Report
 Town of Mantachie
 PWS#: 0290005
 April 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. In order to better serve our customers with a better water supply the Town of Mantachie began purchasing our water from the Northeast MS Regional Water Supply, which has greatly improved our water system.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Mantachie have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Rod McFerrin at 662-282-7949. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the Mantachie Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2013	.023	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2013	.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2008*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2013	.75	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Disinfection By-Products

81. HAA5	N	2013	33	21 - 33	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	44.8	35.7 – 44.8	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	1.60	No Range	ppm	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2013.

We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Town of Mantachie is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 92%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

This Water System purchases its drinking water from N.E.M.S Regional Water District. We strive to provide adequate, clean and safe drinking water to our customers. We ask for you to report any leaks you may find to Town Hall. Thank You!

The Town of Mantachie works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Free Take One!



Like Us on Facebook

Area Promoter

WATER SUPPLY
2014 MAY 12 AM 9:06


Connecting Local Business to Local Customers!

Thursday, May, 8, 2014 Pecked, Published, & Printed Local Vol. 6 No. 43

WITH A LOT OF HELP FROM OUR FRIENDS WE ARE...

RECOVERING

More Volunteer and Clean-up Pictures inside this Special Edition




GMFD members unload a Salvation Army truck of supplies now housed at the old Centerville Store.

3 year old Anna Boutwell (left) helps pile brush at her Great Grandfather's house, while 4 year old Adian Reynolds helps his family at Oak Grove Cemetery on Saturday.



Volunteer groups like the Mennonite Disaster Service from Kentucky and Pennsylvania helped clear trees from homes like this one on Hall Road Friday. Many Faith Based Groups from other states made quite an improvement in the storm affected areas this past week. Our thanks and gratitude go out to each and every one.



**Itawamba Historical Society's
PICTURE OF THE WEEK**

1949 FARM VETERANS CLASS #2

This is one of three Farm Veteran Classes at IJC in 1949. First Row LtoR: Paul Tabler, Oran Smith, Hurlus Kelso, Hilton C. Smith, Brown Woods, Earnest F. Townsend, Hubert Smith, William Britton, John Roger Gray Second Row: LtoR: Troy Gray (special instructor), Olun Dulaney, J.N. Burch, Melvin Humphries, John A. Burch, Aubrey H. Smith, James Ellis Townsend, W. Clinton Nabers, Lowell Taylor, Elmer A. Tucker, Troy Dickerson, Morris V. Tucker, and Edsel Wiginton.




If you have any old photo's you would like to share in the Area Promoter bring them by the office, we love our local history! Help support the Itawamba County Historical Society with your donations and become a member today.



Absentee Ballots are now available for the June 3, 2014 Primary Election. BE SURE TO BRING DRIVER'S LICENSE (Voter ID) WITH YOU WHEN YOU VOTE! You can vote absentee at the Circuit Clerk's Office.

NOTICE: Everyone who has sustained damage by the tornado can call 1-800-621-3362 Or go to <http://www.disasterassistance.gov> It does not matter if you had insurance or not, you can apply for FEMA funds for Individuals, information on businesses will come later. FEMA has an office set up and now open at The Mantachie Community Center located on Tishtonee Drive just off Highway 363.



**Veterans Blvd · Tupelo, MS
662-840-7980
Check Us Out on Facebook & claysbaitandtackle.com**

D & D Electrical Contractors

Residential, Industrial & Commercial
24 Hour Emergency Service
Licensed, Bonded & Insured
Over 20 Years Experience

**Kevin Donald
662-213-9746**



FREE! FREE! FREE!

FAWN GROVE MARKET PLACE

1810 Fawn Grove Road- Mantachie, MS
(at the former Fawn Grove Restaurant)

FREE THIS WEEKEND SATURDAY & SUNDAY

**VENDOR PARKING!
VENDORS NEEDED!**

GARAGE SALE FOLKS WELCOME!

**OUTDOOR FLEA MARKET STYLE
FREE PARKING • FREE ADMISSION**

ALL VENDORS WELCOME

Concessions Available • Clean Indoor Restrooms
(662) 231- 3126 or 601-466-6973

FREE! FREE! FREE!

2014 MAY 12 AM 9:06

Deliver payment to:

Mantachie Water Assoc.
3256 Hwy 371 N •
P.O.Box 70
Mantachie, MS 38855
662-282-7949 OR 662-282-7936

This institution is an equal opportunity provider and employer

Previous Balance: 0.00

WATER (RES) 100-100=0 17.06
GARBAGE BILL 13.00

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 38855
PERMIT # 003

Billed: 05/01/14 Return this portion with payment.

30.06 PAID BY DIRECT DEBIT

TOTAL NEW CHGS 05/01/14 30.06

30.06 PAID BY DIRECT DEBIT

Acct# 0305300

Last Pmt \$42.06 04/10/14

MANTACHIE TOWN HALL

SVC:03/27/14-04/25/14 (29 days)

3256 HWY 371

OUR CCR REPORT WILL BE PUBLISHED IN THE
AREA PROMOTOR IN THE MAY 8, 2014 ISSUE.

Acct# 0305300

3256 HWY 371

MANTACHIE TOWN HALL

P.O. BOX 70

MANTACHIE MS 38855

~~_____~~
~~_____~~
~~_____~~