

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

CITY OF CORINTH GAS & WATER DEPT
Public Water Supply Name

0020002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other

Date(s) customers were informed: 05/09/14, 05/20/14, 05/28/14

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: / /

As a URL (Provide URL)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper:

Date Published: / /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

WWW.CGANDW.COM

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


Name/Title (President, Mayor, Owner, etc.)

5-30-2014
Date


Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowksi@msdh.state.ms.us

CITY OF CORINTH GAS AND WATER DEPARTMENT

2014 WATER QUALITY REPORT



CLIFFORD G. WORSHAM

WATER TREATMENT FACILITY

ADDITIONAL INFORMATION FOR LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Corinth Gas and Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or <http://www.epa.gov/safe water/lead>. The Mississippi State Department of Health Public Laboratory offers lead testing for \$10 per sample. Please call 601-576-7518 if you wish to have your water tested.

FLUORIDATION COMPLIANCE

To comply with the "Regulation Governing Fluoridation of Community Water Supply", CITY OF CORINTH is required to report certain results to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within in the optimal range of 0.7-1.3 ppm was 10. The percentage of fluoride samples collected the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 59%.

DO YOU WANT MORE INFORMATION?

If you are interested in learning more about the Corinth Gas and Water Department, or if you have any questions concerning water quality, our office is located at 305 West Waldron Street. Our office hours are from 8:00 AM to 5:00 PM, Monday through Friday. You can also call us at (662) 286-2263. Our contact person is David Bass. The City of Corinth Public Utility Commission meets at 7:00 PM on the second Monday of each month at the address above. Board meetings are open to the public.

CONTINUING OUR COMMITMENT

Mission Statement

"To assure the availability of a consistently adequate supply of natural gas and water while providing for the highest quality service possible at a reasonable cost to our customers consistent with good management and sound business practices."

All the information in this Annual Water Quality Report has been prepared in accordance with the standards established by the Environmental Protection Agency (EPA) and includes details about where your water comes from, what it contains and how it compares to standards set by the regulatory agencies.

CALL BEFORE YOU DIG

YOU CAN SUBMIT A REQUEST ONLINE @ WWW.MS1CALL.ORG

OR

YOU CAN CALL **811** TO SUBMIT A REQUEST

TREATED WATER QUALITY SUMMARY

The table below lists all of the drinking water contaminants that we detected during the 2013 calendar year. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Except as indicated, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

INORGANIC CONTAMINANTS						
CONTAMINANT	MCL	MCLG	DETECTED	RANGE DETECTED	DATE	TYPICAL SOURCE
ARSENIC	.010 mg/l	NA	.0006 mg/l		2013	Erosion of natural deposits, runoff from orchards
BARIUM	2 mg/l	2 mg/l	.0146 mg/l		2013	Erosion of natural deposits
CHROMIUM	0.1 ppb	0.1 ppb	.0007 ppb		2013	Erosion of natural deposits
FLUORIDE	4 mg/l	4 mg/l	.67 mg/l		2013	Erosion of natural deposits
LEAD	15 ppb	0 ppb	6 ppb		2013	Customer plumbing and service connection
COPPER	1.3 mg/l	1.3 mg/l	.29 mg/l		2013	Customer plumbing and service connection

VOLATILE ORGANIC CONTAMINANTS						
CONTAMINANT	MCL	MCLG	DETECTED	RANGE DETECTED	DATE	TYPICAL SOURCE
XYLENES, TOTAL	10 mg/l	10 mg/l	1.99 ppb		2013	Discharge from petroleum/chemical factories
ETHYLBENZENE	700 ppb	700 ppb	.565 ppb		2013	

DISINFECTION BYPRODUCTS						
CONTAMINANT	MCL	MCLG	DETECTED	RANGE DETECTED	DATE	TYPICAL SOURCE
CHLORINE	4 mg/l	4 mg/l	1.50 mg/l	.5-2.30 mg/l	2013	Water additive to control microbes
TRIHALOMETHANES	80 ppb	0	68.7 ppb		2013	By-products of drinking water chlorination
HALOACETIC ACID	60 ppb	0	44 ppb		2013	By-products of drinking water chlorination

ADDITIONAL CONTAMINANTS						
CONTAMINANT	MCL	MCLG	DETECTED	RANGE DETECTED	DATE	TYPICAL SOURCE
IRON	.3 mg/l	NA		.10-.41 mg/l	2013	Erosion of natural deposits
COLIFORM	1 positive	1 positive		2 positive	2013	Naturally present in the environment

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. The violation occurred in February 2013. It was resolved in one week.

UNREGULATED CONTAMINANTS						
CONTAMINANT	MRL	DETECTED	RANGE DETECTED	DATE	TYPICAL SOURCE	
HEXAVALENT CHROMIUM	.030 ppb	0.093 ppb	.051-.093 ppb	2013	Naturally-occurring element	
STRONTIUM	.30 ppb	760 ppb	90-760 ppb	2013	Naturally-occurring element	
VANADIUM	.20 ppb	.42 ppb	.25-.42 ppb	2013	Naturally-occurring element	
CHROMIUM	.20 ppb	.59 ppb		2013	Naturally-occurring element	
1,4 DIOXANE	.070 ppb	.84 ppb		2013	Used as solvent or solvent stabilizer in manufacturing	
BROMOCHLOROMETHANE	.010 ppb		.094-.43 ppb	2013	fire-extinguishing fluid or solvent in manufacturing pesticides	
1,1 DICHLOROTHANE	.010 ppb	.043 ppb		2013	Halogenated alkane; used as solvent	

TABLE OF DEFINITIONS

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers a treatment of other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the MCLGs as is economically and technologically feasible.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U. S. Environmental Protection Agency.

MRDL (Maximum Residual Disinfectant Level): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLs are set by the U. S. Environmental Protection Agency.

MRL (Minimal Risk Level) Estimate of the daily human exposure to a hazardous substance that is likely to be without appreciable risk of adverse noncancerous health effects over a specified duration of exposure.

NA: Not applicable.

ppb (parts per billion): One part substance per billion parts of water, or

Ug/l micrograms per liter.

ppm (parts per million): One part substance per million parts water, or mg/l milligrams per liter.

PDWS (Primary Drinking Water Standards): MCL's and MRDL's for contaminants that affect health along with the requirements for monitoring, reporting and treatment.

SOURCE WATER ASSESSMENT

The Safe Drinking Water Act (1996) mandates states to develop and implement Source Water Assessment Programs designed to notify public water systems and their customers regarding the susceptibility of the potable water supply to contamination (i.e. spills, floods, etc.). The Mississippi Department of Environmental Quality has completed our SWA. MDEQ has determined the rankings of our wells as follows: 3 wells "low", 7 wells "moderate", and 1 well "high". These rankings are used to notify systems in Mississippi of the relative susceptibility of their wells to contamination. Wells with high ranking have a higher chance of becoming contaminated than the average public water well in Mississippi, but they should not be considered as unsafe sources of drinking water. Likewise, it should not be construed that those public water system wells with low susceptibility rankings are totally immune from contamination events; however, such wells are less susceptible than the average well operating in the state. A moderate susceptibility ranking signifies wells that have an average chance of becoming contaminated; these wells serve as the norm or standard for comparison. The final susceptibility ranking represents a "snap shot" in time, and thus, are subject to modification as conditions associated with wells and potential contaminant sources located around wells change with time. A copy of the Source Water Assessment for Corinth's water system is available for viewing at our office during business hours.

TEAR OFF SIDE MARGINS FIRST, THEN SLIDE FINGER UNDER THIS EDGE



CORINTH GAS & WATER DEPT.
P.O. BOX 1870
CORINTH, MS 38835-1870

ADDRESS SERVICE
REQUESTED

PRE-SORTED
FIRST CLASS MAIL
U.S. POSTAGE PAID
CORINTH, MS 38835
PERMIT NO. 221

TEAR OFF SIDE MARGINS FIRST, THEN SLIDE FINGER UNDER THIS EDGE

BRYTANY E BUCK
133 CR 405
CORINTH MS 38834



CORINTH GAS & WATER DEPT.
305 WEST WALDRON • P.O. BOX 1870 • CORINTH, MS 38835-1870
TELEPHONE (662) 286-2263

CITY OF CORINTH
GAS & WATER DEPT.
P.O. BOX 1870
CORINTH, MS 38835-1870
CUSTOMER NAME:

BUCK
ACCOUNT NUMBER:
63397-4

CUSTOMER	BILLING DATE	PAST DUE AFTER	DAYS
63397-4	5/31/14	6/16/14	7

SERVICE	PREVIOUS	CURRENT	MULT.	USAGE
BALANCE BROUGHT FORWARD 53.09-				
CREDIT BALANCE REFUND 53.09				
TOTAL AMOUNT DUE .00				
** CLOSED **				

OUR 2014 WATER QUALITY REPORT
IS AVAILABLE AT WWW.CGANDW.COM
OR BY CALLING 662-286-2263

BILLING DATE
NET AMOUNT DUE
NONE
GROSS AMOUNT DUE
.00

FOR "WARM NEIGHBOR" CONTRIBUTION
CHECK HERE AND ADD \$1.00 TO YOUR
PAYMENT

RETURN THIS STUB WITH
YOUR PAYMENT


** CLOSED **

DETACH HERE
FOLD HERE

Detach Along Perforation
Slide Finger Under Envelope Edge To Open
MOISTEN AND FOLD TO SEAL

DETACH HERE
FOLD HERE

First-Class
Postage Required
Post Office will
not deliver
without proper
postage.


CORINTH GAS & WATER DEPT
PO BOX 1870
CORINTH MS 38835-1870