

2014 JUL 17 AM 8:30

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

Town of Liberty
Public Water Supply Name

0030004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: ____ / ____ / ____ , ____ / ____ / ____ , ____ / ____ / ____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ____ / ____ / ____
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Enterprise Journal

Date Published: 06 / 11 / 2014

CCR was posted in public places. *(Attach list of locations)* Date Posted: ____ / ____ / ____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.



Name/Title (President, Mayor, Owner, etc.)

June 12, 2014

Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

0020004

Town of Liberty 2013 Consumer Confidence Report for Water

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The Town of Liberty drinking water comes from two wells in the Miocene Series Aquifer.

Source water assessment and its availability

Questions regarding the availability of a source water assessment should be directed to Liberty Town Hall at 601-657-8071.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater

runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

The Town of Liberty Mayor and Board of Aldermen meet the first Tuesday of each month at 5:00 pm at Liberty Town Hall.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Liberty is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of

contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	2	NA		2011	No	By-product of drinking water chlorination
Chlorine (as Cl ₂) (ppm)	4	4	1.2	0.94	1.2	2013	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	4	NA		2011	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	0.01375 7	NA		2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.1	NA		2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	0.54	NA		2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA		2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Antimony (ppb)	6	6	0.5	NA		2011	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	NA		2011	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Beryllium (ppb)	4	4	0.5	NA		2011	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.5	NA		2011	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints

30004

Chromium (ppb)	100	100	0.5	NA		2011	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	15	NA		2011	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Mercury [Inorganic] (ppb)	2	2	0.05	NA		2011	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	2.5	NA		2011	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA		2011	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Volatile Organic Contaminants								
Toluene (ppm)	1	1	0.0005	NA		2013	No	Discharge from petroleum factories
Xylenes (ppm)	10	10	0.5	NA		2013	No	Discharge from petroleum factories; Discharge from chemical factories
Benzene (ppb)	0	5	0.5	NA		2013	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	0.5	NA		2013	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA		2013	No	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	NA		2013	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA		2013	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA		2013	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA		2013	No	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA		2013	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA		2013	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	0.5	NA		2013	No	Discharge from pharmaceutical and chemical factories

1,2-Dichloropropane (ppb)	0	5	0.5	NA		2013	No	Discharge from industrial chemical factories
Ethylbenzene (ppb)	700	700	0.5	NA		2013	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	NA		2013	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	0.5	NA		2013	No	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA		2013	No	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA		2013	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	NA		2013	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA		2013	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	0.5	NA		2013	No	Leaching from PVC piping; Discharge from plastics factories

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0.002	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Shawn Felder
Address:
P.O. Box 301
Liberty, MS 39645
Phone: 601-657-8071
Fax: 601-657-8078
E-Mail: townoflibertyms@yahoo.com

2014 JUL 17 AM 8:30

STATE OF MISSISSIPPI,
COUNTY OF PIKE

PERSONALLY CAME before me, the undersigned, a notary public in and for PIKE County, Mississippi, the CLERK of the McCOMB ENTERPRISE-JOURNAL, a newspaper published in the City of McComb, Pike County, in said state who being duly sworn, deposes and says that the McCOMB ENTERPRISE-JOURNAL is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy in the

matter of _____
Town of Liberty 2013 Consumer Confidence Report

has been made in said paper 1 times consecutively, to wit:
On the 11 day of June, 20 14
On the _____ day of _____, 20 _____
On the _____ day of _____, 20 _____

SWORN TO and subscribed before me, this


_____ day of _____, 20 _____
Ken Balda Notary Public
John A. ... Clerk



My Commission Expires: 6/19/17
_____ McComb, Miss., _____, 20 _____
To McComb Enterprise-Journal

TO PUBLISHING _____
case of _____
_____ words space _____
_____ times and making proof, \$ _____

RECEIVED OF _____
payment in full of the above account.
_____, 20 _____



www.entrpris-journal.com

2013 Town of Liberty Water System Consumer Confidence Report

Is my water safe?
We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed consumers are our best allies.

Do I need to take special precautions?
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC has developed (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?
The Town of Liberty draws water from two wells in the Micores Sinter Aquifer. Source water assessment and its availability.

Why are there contaminants in my drinking water?
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. All water travels over the surface of the land or through the ground. It does not come from clouds. It does not come from the ground. It does not come from the sky. It does not come from the earth. It does not come from the sun. It does not come from the moon. It does not come from the stars. It does not come from the planets. It does not come from the galaxies. It does not come from the universe. It does not come from anywhere else.

How can I get involved?
The Town of Liberty Mayor and Board of Aldermen meet the first Tuesday of each month at 8:00 pm at Liberty Town Hall.

Description of Water Treatment Process
Four wells are used for drinking water. Disinfection involves the addition of chlorine or other disinfectants to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the most important public health advances of the 20th century.

Additional Information for Lead
If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Liberty is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead/>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful to our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The SDWA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year or the systems were considered vulnerable to this type of contamination. At which point of our data, although representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided our definitions below the table.

Contaminant	MCLG or MRL (ppm)	MCL or MRL (ppm)	Your Water	Range Low/High	Sample Date	Violation	Typical Sources
Disinfectants & Disinfection By-Products							
There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.							
Halocetic Acids (HAA5) (ppb)	NA	60	2	NA	2011	No	By-product of drinking water chlorination
Chlorine (as Cl2) (ppm)	4	4	1.2	0.94-1.2	2013	No	Water additive used to control microbes
THMs (Total Trihalomethanes) (ppb)	NA	80	4	NA	2011	No	By-product of drinking water disinfection
Inorganic Contaminants							
Barium (ppm)	2	2	0.01757	NA	2011	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.1	NA	2011	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (measured as Nitrogen) (ppm)	10	10	0.54	NA	2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite (measured as Nitrogen) (ppm)	1	1	0.02	NA	2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Antimony (ppb)	6	6	0.5	NA	2011	No	Discharge from petroleum refineries; Fire retardants; ceramics; electronics; solder; car
Arsenic (ppb)	0	10	0.5	NA	2011	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production
Beryllium (ppb)	4	4	0.5	NA	2011	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.5	NA	2011	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	0.5	NA	2011	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (as Free CN) (ppb)	200	200	15	NA	2011	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Mercury (Inorganic) (ppb)	2	2	0.05	NA	2011	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland

Contaminant	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Sources
Selenium (ppb)	50	50	2.5	NA	2011	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	NA	2011	No	Discharge from electronics, glass, and leaching from ore-processing sites; drug factories
Volatile Organic Compounds							
Toluene (ppm)	1	1	0.0005	NA	2013	No	Discharge from petroleum factories
Xylenes (ppm)	16	16	0.5	NA	2013	No	Discharge from petroleum factories; Discharge from chemical factories
Benzene (ppb)	0	5	0.5	NA	2013	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	0.5	NA	2013	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	NA	2013	No	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	NA	2013	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	NA	2013	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	NA	2013	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	0.5	NA	2013	No	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	NA	2013	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	NA	2013	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	0.5	NA	2013	No	Discharge from pharmaceutical and chemical factories
2,2-Dichloropropane (ppb)	0	5	0.5	NA	2013	No	Discharge from industrial chemical factories
Ethylbenzene (ppb)	700	700	0.5	NA	2013	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	NA	2013	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	0.5	NA	2013	No	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	NA	2013	No	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	NA	2013	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	NA	2013	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	NA	2013	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	0.5	NA	2013	No	Leaching from PVC piping; Discharge from plastics factories
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Zinc - action level at consumer taps (ppb)	0	15	0.002	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Unit Definitions							
Term	Definition						
ppm	ppm: parts per million, or milligrams per liter (mg/L)						
ppb	ppb: parts per billion, or micrograms per liter (µg/L)						
NA	NA: not applicable						
ND	ND: Not detected						
NR	NR: Monitoring not required, but recommended.						
Important Drinking Water Definitions							
Term	Definition						
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.						
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.						
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.						
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.						
Variances and Exemptions	Variances and Exemptions: State or BPA permission not to meet an MCL or a treatment technique under certain conditions.						
MRDLG	MRDLG: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.						
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.						
MNR	MNR: Monitored Not Regulated						
MPL	MPL: State Assigned Maximum Permissible Level						

For more information please contact: Shawn B. Felder, Address: P.O. Box 301, Liberty, MS 39645
 Phone: 601-657-8071 or 601-657-8078 Email: townoflibertyms@yahoo.com