

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

New Liberty Water Assoc.
Public Water Supply Name
0070012

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 6/18/14

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 6/18/14

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: 6/18/14
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Calhoun County Journal
Date Published: 6/18/14

CCR was posted in public places. *(Attach list of locations)* Date Posted: 6/28/14

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**: _____

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Grover Edgington Pres. 6-31-14
Name/Title (President, Mayor, Owner, etc.) Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)376-7800
May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2013 Annual Drinking Water Quality Report
 New Liberty Water Association
 PWS#: 0070012
 June 2014

2014 JUN 25 PM 2: 23

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Gordo Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the New Liberty Water Association have received lower rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Charles Mahan at 662.682.7747. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meeting. Held on the 4th Friday in Jan., April, August & November at 7:00 PM at the New Liberty Community Bldg..

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2011*	3	1.6 - 3	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2011*	.19	.18 - .19	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

14. Copper	N	2009/11*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
15. Cyanide	N	2011*	48.9	No Range	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
16. Fluoride	N	2011*	.19	.17 - .18	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	6	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2011*	4.4	3.7 - 4.4	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2011*	1.37	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	.7	.3 - 1	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The New Liberty Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Proof Of Publication


STATE OF MISSISSIPPI,
COUNTY OF CALHOUN

Personally came before me, the undersigned, a Notary Public, in and for Calhoun County, Mississippi, Joel McNeece, Publisher of The Calhoun County Journal, a newspaper published in Bruce, Calhoun County, in said state, who being duly sworn, deposes and says that The Calhoun County Journal is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858 of the Mississippi Code of 1942, and the publication of a notice, of which annexed copy, in the matter of

NEW LIBERTY WATER ASSOCIATION WATER QUALITY REPORT


has been made in said newspaper one time, to-wit:

On the 18 day of JUNE 2014



Joel McNeece
Publisher

Sworn to and subscribed before me, this 18 day of JUNE, 2014.



Lisa Denley McNeece,
Notary Public

My commission expires March 28, 2018



New Liberty Water System Water Quality Report

2014 Annual Report

This report provides information on the water quality of the New Liberty Water System. The water quality is monitored on a regular basis and the results are reported to the public. The water quality is generally good, but there are some areas where the water quality is not as good as it could be. The water quality is affected by many factors, including the weather, the amount of rainfall, and the amount of water used. The water quality is also affected by the amount of water that is treated. The water quality is generally good, but there are some areas where the water quality is not as good as it could be. The water quality is affected by many factors, including the weather, the amount of rainfall, and the amount of water used. The water quality is also affected by the amount of water that is treated.

Parameter	Unit	Value	Standard
Chlorine	mg/L	1.5	4.0
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L	0.01	0.05
Barium	mg/L	0.01	0.05
Cadmium	mg/L	0.001	0.01
Mercury	mg/L	0.001	0.01
Selenium	mg/L	0.01	0.05
Chloride	mg/L	100	250
Sulfate	mg/L	100	250
Total Solids	mg/L	200	500
Phosphate	mg/L	0.1	0.1
Ammonium	mg/L	0.1	0.1
Nitrogen	mg/L	0.1	0.1
Phosphorus	mg/L	0.1	0.1
Calcium Hardness	mg/L	80	300
Magnesium Hardness	mg/L	70	300
Total Hardness	mg/L	150	300
Total Dissolved Solids	mg/L	100	500
Calcium	mg/L	80	300
Magnesium	mg/L	70	300
Iron	mg/L	0.1	0.3
Manganese	mg/L	0.05	0.1
Nitrate	mg/L	10	10
Nitrite	mg/L	0.1	0.1
Ammonia	mg/L	0.1	0.1
Fluoride	mg/L	1.0	1.5
Lead	mg/L	0.01	0.05
Copper	mg/L	0.01	0.05
Zinc	mg/L		

CCR Report
New Liberty Water Assoc.

Posted Public Places -

Vandaman Post Office

Vandaman Library

Calhoun County Court House
Pittsboro MS.