

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

MISSISSIPPI STATE DEPARTMENT OF HEALTH
2014 JUN 16 AM 11:58

Walls Water Association, Inc.
Public Water Supply Name

0170019 & 0170043
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 5/20/14, _____, _____, _____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: _____ / _____ / _____
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: DeSoto Times-Tribune

Date Published: 5/20/14

CCR was posted in public places. *(Attach list of locations)* Date Posted: _____ / _____ / _____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Heather Thomas / Bookkeeper
Name/Title (President, Mayor, Owner, etc.)

6/9/14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

MLW

AFFP

PN: WATER QUALITY REPORT

Affidavit of Publication

DESOTO TIMES-TRIBUNE

STATE OF MS }
COUNTY OF DESOTO } SS

DIANE SMITH, being duly sworn, says:

That she is a Clerk of the DESOTO TIMES-TRIBUNE, a newspaper of general circulation in said county, published in Hernando, DeSoto County, MS; that the publication, a copy of which is printed hereon, was published in the said newspaper on the following dates:

May 20, 2014

That said newspaper was regularly issued and circulated on those dates.

SIGNED:

Diane Smith
Clerk

Subscribed to and sworn to me this 20th day of May 2014.

Judy Hayes
JUDY HAYES, Notary, DeSoto County, MS

My commission expires: October 01, 2017

0003070 00029378 662-781-1122

Heather Clinger
Walls Water Association
6200 Goodman Road
Walls, MS 38680



2014 JUN 16 AM 11:58

2013 Annual Drinking Water Quality Report
Walls Water Association, Inc.
PWS#: 0170019 & 0170043
May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Lower Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Walls Water Association have received lower to moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Wade Carter, Manager at 662.781.3722. We want our valued customers to be informed about their water utility. If you have a concern, you can meet with the board, by request at our regularly scheduled meetings. They are held on the fourth Tuesday of the month at 4:00 PM at the Walls Water Office located at 6200 Goodman Road Walls, MS 38680.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

PWS ID # 0170019		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG/MRDL	Unit Measure	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	N	June	Positive	1	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Inorganic Contaminants								
10. Barium	N	2011*	.036	01 - .030	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2008*	.001	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2012*	14	No Range	ppb	0	00	By-product of drinking water disinfection.
82. THM (Total Trihalomethanes)	N	2012*	37.3	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	3.1	1 - 1.20	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 0170043		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG/MRDL	Unit Measure	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2011*	.032	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011/13	4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2011*	.30	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products								
01. HAA5	N	2012*	19	No Range	ppb	0	00	By-product of drinking water disinfection.
82. THM (Total trihalomethanes)	N	2012*	5.91	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	1.4	1.3 - 1.8	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2013.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/L.

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

SIGNED:

Viana Smith
Clerk

Subscribed to and sworn to me this 20th day of May 2014.

Judy Hayes
JUDY HAYES, Notary, DeSoto County, MS

My commission expires: October 01, 2017

00003070 00029378 662-781-1122

Heather Clolinger
Walls Water Association
6200 Goodman Road
Walls, MS 38680



units per volume (ppb) or micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

PWS ID # 0170019		TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AQL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination			
Microbiological Contaminants											
1. Total Coliform Bacteria	N	June	Positive	1	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment			
Inorganic Contaminants											
10. Barium	N	2011*	030	01 - .030	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits			
14. Copper	N	2008*	001	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives			
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits			
Disinfection By-Products											
81. HAA5	N	2012*	14	No Range	ppb	0	60	By-Product of drinking water disinfection.			
82. THM4 (Total trihalomethanes)	N	2012*	17.3	No Range	ppb	0	80	By-product of drinking water disinfection.			
Chlorine	N	2013	1.1	1 - 1.20	mg/l	0	MRDL = 4	Water additive used to control microbes			

PWS ID # 0170043		TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AQL/MRDL	Unit Measurement	MCLG	MCL	Likely Source of Contamination			
Inorganic Contaminants											
10. Barium	N	2011*	032	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits			
14. Copper	N	2011/13	4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives			
16. Fluoride**	N	2011*	30	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories			
17. Lead	N	2011/13	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits			
Disinfection By-Products											
81. HAA5	N	2012*	19	No Range	ppb	0	60	By-Product of drinking water disinfection.			
82. THM4 (Total trihalomethanes)	N	2012*	5.91	No Range	ppb	0	80	By-product of drinking water disinfection.			
Chlorine	N	2013	1.4	1.3 - 1.6	mg/l	0	MRDL = 4	Water additive used to control microbes			

* Most recent sample. No sample required for 2013.
 ** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.
 Microbiological Contaminant:
 (1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Walls Water Association # 0170019 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride samples results were within the optimal range of 0.7 - 1.3 ppm was 6. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 - 1.3 ppm was 48%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Walls Water Association - Lake Forest # 0170043 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride samples results were within the optimal range of 0.7 - 1.3 ppm was 6. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 - 1.3 ppm was 67%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Walls Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.