

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

2014 JUN -2 AM 11:19

Tineville Water Association
Public Water Supply Name

065006, 065007, 065008
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 6/1/2014 / / , 5/17/2014

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 6/1/2014

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Smith Co. Reformer

Date Published: 5/17/2014

CCR was posted in public places. *(Attach list of locations)* Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Wanda Craft
Name/Title (President, Mayor, Owner, etc.)

6-1-14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2014 MAY -5 PM 12:30

2013 Annual Drinking Water Quality Report
Pineville Water Association, Inc.
PWS#: 0650006, 0650017 & 0650018
April 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Meridian Upper Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Pineville Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Wanda Craft at 601-789-5005. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 7:00 PM at the office located at 8305 HWY 501.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| PWS ID#: 0650006 | | TEST RESULTS | | | | | | |
|-------------------------------|---------------|---------------------|----------------|--|------------------|------|--------|--|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2013 | .033 | .012 - .033 | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2013 | 2.1 | 1.8 - 2.1 | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2009/11* | .3 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

| | | | | | | | | |
|--------------------------------------|---|----------|-------|----------|-----|----|----------|---|
| 17. Lead | N | 2009/11* | 5 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Volatile Organic Contaminants | | | | | | | | |
| 76. Xylenes | N | 2013 | .0007 | No Range | ppm | 10 | 10 | Discharge from petroleum factories; discharge from chemical factories |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2013 | 2 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2013 | 3.46 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2013 | .5 | No Range | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

| PWS ID#: 0650017 TEST RESULTS | | | | | | | | |
|--------------------------------------|---------------|----------------|----------------|--|-------------------|------|----------|---|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure-ment | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2013 | .0025 | No Range | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2013 | 1.8 | No Range | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |
| 14. Copper | N | 2009/11* | .3 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2013 | .136 | No Range | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2009/11* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2013 | 14 | No Range | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2013 | 23.8 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2013 | .5 | No Range | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

| PWS ID#: 0650018 TEST RESULTS | | | | | | | | |
|--------------------------------------|---------------|----------------|----------------|--|-------------------|------|-----|--|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measure-ment | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2013 | .0013 | No Range | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 13. Chromium | N | 2013 | 2 | No Range | ppb | 100 | 100 | Discharge from steel and pulp mills; erosion of natural deposits |

| | | | | | | | | |
|--------------|---|----------|-----|----------|-----|-----|--------|---|
| 14. Copper | N | 2009/11* | .1 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2013 | .18 | No Range | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead | N | 2009/11* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems, erosion of natural deposits |

Disinfection By-Products

| | | | | | | | | |
|-------------------------------------|---|------|----|-----------|-----|---|----------|--|
| 81. HAA5 | N | 2013 | 14 | 8 - 14 | ppb | 0 | 60 | By-Product of drinking water disinfection. |
| 82. TTHM [Total trihalomethanes] | N | 2013 | 23 | 6.34 - 23 | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2013 | .5 | No Range | ppm | 0 | MDRL = 4 | Water additive used to control microbes |

* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Pineville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed to customers, however, copies are available upon request by calling 601-789-5005.

2013 ANNUAL DRINKING WATER QUALITY REPORT
PINEVILLE WATER ASSOCIATION

PWS#: 0650006, 065

April 2014

Legal

IN THE CHANCERY COURT OF SMITH COUNTY, MISSISSIPPI
IN THE MATTER OF THE ESTATE OF MARY LOU KEYES, DECEASED
CAUSE NO. 2013-253-A2

NOTICE TO CREDITORS

We're pleased to present to you this year's Annual Quality Water Report. We've provided you with information on the quality water and services we deliver to you every day. Our commitment is to provide you with a safe and reliable supply of drinking water. We want you to understand the effort we make to protect our water resources. We are committed to ensuring that our water supply is safe and reliable. The source water assessment has been completed for our public drinking water supply to identify potential sources of contamination. The susceptibility determinations were made and have been furnished upon request. The wells for the Pineville Water Association have been tested for contamination.

If you have any questions about this report or concerning your water supply, please contact us. We want our valued customers to be informed about their water supply. Our regularly scheduled meetings are held on the first Monday of each month at 8305 Hwy. 501.

We routinely monitor for constituents in your drinking water. The following table lists all of the drinking water contaminants that we detected during the 2013 monitoring. In cases where monitoring wasn't required in 2013, the table reflects the surface of land or underground, it dissolves naturally occurring substances or contaminants from the presence of animals, viruses and bacteria, that may come from sewage treatment plants, wildlife, inorganic contaminants, such as salts and metals, which can be found in water runoff, industrial or domestic wastewater.

Letters of Administration have been granted on the 30th day of April, 2014, to the undersigned Administrator of the Estate of Mary Lou Keyes. Notice is hereby given to all persons having claims against said estate to file the same with the Clerk of this Court within ninety (90) days from the first publication of this notice, or they will be forever barred. THIS 24th day of April, 2014.

Jean Keyes
Jean Keyes
Administratrix of the Estate of
Mary Lou Keyes, Deceased

OF COUNSEL
William R. Ruffin
Attorney at Law
Post Office Box 565
Bay Springs, MS 39422
Telephone No. (601) 764-4555
Facsimile No. (601) 764-2234
MSB# 5724

(3884)
May 7, 14, 21

NOTICE OF INTENTION TO
OR WITHDRAW FOR BENEFICIAL
USE THE PUBLIC WATERS
STATE OF MISSISSIPPI

Notice is hereby given that on the 7th day of May, 2014, the Town of Pineville, Mississippi, has renewed application No. MS-GW-14744 for a permit to continue to divert or use the public waters of the State of Mississippi for beneficial use from the Aquifer, in the county of Smith, Mississippi, for trial purposes, subject to existing laws, rules and regulations, and the following amount of water at the location:

PERMIT # - MS-GW-14744
VOLUME - 0.55MG/D
RATE - 513 GPM
LOCATION - NE SE S13, T10N

Any person, firm, association, or corporation deeming that the granting of this application will be truly detrimental to their interests may protest in writing to the Permit Administrator, Office of Land and Water Resources, 139225, setting forth all reasons why the application should not be approved. A protest must be received with the Permit Administrator within 10 days following publication date.

If protested, the application will be considered by the Permit Administrator in its offices at 139225, Amite Street, Jackson, Mississippi, on Tuesday, the 10th day of May, 2014, at which time all interested persons may appear and be heard by the Permit Administrator.

OFFICE OF LAND AND WATER RESOURCES
Lisa A. May, RPG
Permitting Branch Chief

(3883)
May 7

The State of Mississippi, County of Smith
PERSONALLY CAME before me and undersigned a Notary Public in and for the County of Smith, Mississippi, Office Clerk of the Smith County Reformer, a newspaper published in the Town of Raleigh, Smith County, in said State, who being sworn, deposes and says that the Smith County Reformer is a newspaper as defined and prescribed in §13-3-1 of the Mississippi Code 1972 Annotated and that the publication of a notice in which the annexed is a copy, in the matter of

2013 Annual Drinking Water Quality Report

has been made in said paper _____ consecutively, to-wit:

On the 7 day of May 2014

On the ___ day of ___ 20__

On the ___ day of ___ 20__

On the ___ day of ___ 20__

April Tussner
OFFICE CLERK

SWORN to and subscribed before me, this the _____ day of _____ 20__

day of _____ 20__


NOTARY PUBLIC

As you can see by the table, our system had no violations of Federal and State requirements. We have learned through our testing that your water is safe to drink. We are required to monitor your drinking water for specific contaminants. Testing is an indicator of whether or not our drinking water meets all monitoring requirements. MSDH now notifies systems of violations.

If present, elevated levels of lead can cause serious health problems. Lead in drinking water is primarily from materials and components used in plumbing. Our Water Association is responsible for providing high quality water. When your water has been tested for lead exposure by flushing your tap for 30 seconds to 2 minutes, you may wish to have your water tested. Steps you can take to minimize exposure are listed on the EPA website at www.epa.gov/safewater/lead. The Mississippi State Department of Health Please contact 601.576.7582 if you wish to have your water tested. All sources of drinking water are subject to potential contamination. These substances can be microbes, inorganic or organic, including bottled water, may reasonably be expected to contribute to the overall health effects can be obtained by calling the Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than others. People with cancer, undergoing chemotherapy, pregnant women, people with HIV/AIDS or other immune system disorders, some infants and young children, and the elderly are more vulnerable. These people should seek advice about drinking water from their health care provider. The Pineville Water Association, Inc. works around the clock to help our customers help us protect our water sources, which are our future.

Notice: This report will not be mailed to customers, 601.789.5005.



to the highest bidder for
described vehicles:
924 Chevy, 1500
CD142209971
nd registered to
oppler Roomsaville
STORE

R

2013 ANNUAL DRINKING WATER QUALITY REPORT PINEVILLE WATER ASSOCIATION, INC.

PWS#: 0650006, 0650017 & 0650018

April 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Meridian Upper Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Pineville Water Association have received a lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Wanda Craft at 601.789.5005. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 7:00 PM at the office located at 8305 Hwy. 501.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000.00.

PWS ID # 0650006

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
|--------------------------------------|---------------|----------------|----------------|--|------------------|------|--------|--|
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2013 | 033 | .012 - .033 | ppm | 2 | 2 | Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits |
| 13. Chromium | N | 2013 | 2.1 | 1.8 - 2.1 | ppb | 100 | 100 | Discharge from steel & pulp mills; erosion of natural deposits |
| 14. Copper | N | 2009-11* | 3 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 17. Lead | N | 2009-11* | 5 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |
| Volatile Organic Contaminants | | | | | | | | |
| 76. Xylenes | N | 2013 | 0007 | No Range | ppm | 10 | 10 | Discharge from petroleum factories; discharge from chemical factories |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2013 | 2 | No Range | ppb | 0 | 60 | By-product of drinking water disinfection |
| 82. THM (Total trihalomethanes) | N | 2013 | 3.46 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination |
| Chlorine | N | 2013 | 5 | No Range | ppm | 0 | MORL=4 | Water additive used to control microbes |

PWS ID # 0650017

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
|---------------------------------|---------------|----------------|----------------|--|------------------|------|--------|---|
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2013 | 0025 | No Range | ppm | 2 | 2 | Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits |
| 13. Chromium | N | 2013 | 1.8 | No Range | ppb | 100 | 100 | Discharge from steel & pulp mills; erosion of natural deposits |
| 14. Copper | N | 2009-11* | .3 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2013 | .136 | No Range | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| 17. Lead | N | 2009-11* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2013 | 14 | No Range | ppb | 0 | 60 | By-product of drinking water disinfection |
| 82. THM (Total trihalomethanes) | N | 2013 | 23.8 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination |
| Chlorine | N | 2013 | 5 | No Range | ppm | 0 | MORL=4 | Water additive used to control microbes |

PWS ID # 0650018

TEST RESULTS

| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
|---------------------------------|---------------|----------------|----------------|--|------------------|------|--------|---|
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2013 | 0013 | No Range | ppm | 2 | 2 | Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits |
| 13. Chromium | N | 2013 | 2 | No Range | ppb | 100 | 100 | Discharge from steel & pulp mills; erosion of natural deposits |
| 14. Copper | N | 2009-11* | 1 | 0 | ppm | 1.3 | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| 16. Fluoride | N | 2013 | .18 | No Range | ppm | 4 | 4 | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer & aluminum factories |
| 17. Lead | N | 2009-11* | 1 | 0 | ppb | 0 | AL=15 | Corrosion of household plumbing systems; erosion of natural deposits |
| Disinfection By-Products | | | | | | | | |
| 81. HAA5 | N | 2012 | 25 RAA | No Range | ppb | 0 | 60 | By-product of drinking water disinfection |
| 82. THM (Total trihalomethanes) | N | 2012 | 26 RAA | No Range | ppb | 0 | 80 | By-product of drinking water chlorination |
| Chlorine | N | 2012 | 5 | No Range | ppm | 0 | MORL=4 | Water additive used to control microbes |

*Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people are more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, infants, and the elderly are more vulnerable to contaminants in drinking water than the general population. Immunocompromised people should consult their health care providers about drinking water. Some infants and young children are also more vulnerable to contaminants in drinking water than the general population. Immunocompromised people should consult their health care providers about drinking water.

made. These substances, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Pineville Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed to customers, however, copies are available upon request by calling 601.789.5005.

ry
he
ill,
an,
he

| ACCOUNT NO. | SERVICE FROM | SERVICE TO |
|-------------|--------------|------------|
| 010001000 | 04/25 | 05/25 |

SERVICE ADDRESS
10994 HWY 501

| CURRENT | METER READINGS | | USED |
|---------|----------------|--|------|
| | PREVIOUS | | |
| 7636 | 7624 | | 12 |

CHARGE FOR SERVICES

WTR 18.00
NET DUE >>> 18.00
SAVE THIS >> 20.00
GROSS DUE >> 38.00

RETURN THIS STUB WITH PAYMENT TO:

PINEVILLE WATER ASSN
P.O. BOX 37
RALEIGH, MS 39153
601-789-5005

FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 15
RALEIGH, MS

| AMOUNT DUE ON OR BEFORE DUE DATE | DUE DATE | AMOUNT DUE PLUS LATE FEE |
|----------------------------------|------------|--------------------------|
| | 06/16/2014 | |
| AMOUNT DUE | AFTER 26TH | PAST DUE AMOUNT |
| 18.00 | 20.00 | 38.00 |

2014 CCR REPORT AVAILABLE
UPON REQUEST

RETURN SERVICE REQUESTED

010001000
WILLIS R. VAUGHN
10994 HWY 501
FOREST, MS 39074

2014 JUN -2 AM 11:19