

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

DRinking WATER SUPPLY
2014 JUN 10 AM 10:29

City of Meridian Public Water Supply Name

PWS ID #0380005
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 06 / 01 / 14 /thru/ 06 / 30 / 14

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 06 / 03 / 14

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____


Date Published: / /

CCR was posted in public places. *(Attach list of locations)* Date Posted: 05 / 23 / 14

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):
www.meridianms.org/ccr2013/ccr_report_fy_2013.pdf

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


Name/Title (President, Mayor, Owner, etc.)

6/3/14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yankowski@msdh.state.ms.us

2014 JUN 11 AM 10:29

MERIDIAN

City of Meridian

Further longitude on life.

2013 Annual Drinking Water Quality Report May 15, 2014 PWS ID # 0380005

The City of Meridian is pleased to present to you this year's Annual Water Quality report. This report is intended to inform you about the quality of the water we provide and the services we deliver to you everyday. Our goal is to provide you with a safe and reliable supply of drinking water. We want you to know about the efforts we make to continually improve our treatment process and to protect our water resources. We are committed to insuring the quality of drinking water.

The water source consists of eight wells pumping from the WILCOX AQUIFER. The depth of these wells range from 747' to 948'. A source water assessment has been completed by the Mississippi State Department of Health and can be reviewed in the utility billing office at 7th Ave.

CITY IS PLEASED TO REPORT THAT OUR DRINKING WATER MEETS OR EXCEEDS ALL FEDERAL AND STATE REQUIREMENTS.

The City of Meridian routinely monitors for 154 inorganic and organic contaminants in your drinking water according to Federal and State Laws. Of these 154 contaminants, we had 0 detects in 2013. The table on the following page shows the results of our monitoring for the

Fluoride. To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF MERIDIAN is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that the average fluoride sample results were within the optimal range of 0.7—1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7—1.3 ppm was 96%.

Important Information Regarding Your Drinking Water

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

VULNERABILITY:

Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These

health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead. Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your tap water, you may wish to have your water tested. You may also want to flush your tap for at least 30 seconds before consumption. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

QUESTIONS:

We at the City of Meridian work around the clock to provide top quality water to every tap. If you have any questions about this report or concerning your water utility, please contact Jimmy Eckman, Chief Utility Plant Operator, at 1598 B-Street or call 601-485-1975. We want our valued customers to be informed about their water utility. **If you want to learn more please attend our scheduled meeting on Tuesday, June 17, 2014 at 4:00 PM, in the Auditorium on the 3rd floor of City Hall at 601 23rd Avenue.** We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Sincerely,
Hugh Smith, Public Works Director

WATER QUALITY TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level or Range of Level Detected	Your Water	# of Samples Taken	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants									
Total Coliform	N	Jan—Dec	0		50/month	N/A	0	Presence in 5% of monthly samples	Naturally present in the environment
Fecal Coliform and E. coli	N	Jan—Dec	0		50/month	N/A	0	0	Human and animal fecal waste
Inorganic Contaminants:									
Barium *	N	2009	.029458		2	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Chromium *	N	2009	.000753		2	ppm	1	1	Discharge from steel and pulp mills; erosion of natural deposits.
Copper	N	2011-2013	.0121		32	ppm	1.3	AL 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservative
Cyanide	N	2013	<0.015		2	Ppm	0.2	0.2	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Lead	N	2011-2013	.002		32	ppm	0	AL 15	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate (as Nitrogen)	N	Feb	< 0.08		2	ppm	10	10	By product of drinking water chlorination.
Nitrite (as Nitrogen)	N	Feb	< 0.02		2	ppm	1	1	By product of drinking water chlorination.
Nitrate + Nitrite (as Nitrogen)	N	Feb	<0.1		2	ppm	10	10	By product of drinking water chlorination.
Volatile Organic Contaminants:									
TTHM (Total trihalomethanes)	N	Nov	Low - High 1.4 - 11.65		4	ppb	NA	80	By-product of drinking water chlorination.
HAA5 Haloacetic Acids	N	Nov	Low - High 1.0 - < 6.0		4	ppb	NA	60	By product of drinking water chlorination
Chlorine (as Cl ₂) (ppm)	N	Jan.—Dec	Low - High 0.50 - 3.60	Highest QTR RAA 1.90mg/L	50/month	ppm	4	4	Water additive used to control microbes
Radionuclides									
Uranium	N	2013	<0.5		2	ppb	0	30	Erosion of natural deposits

* No Samples required in 2012.

TERMINOLOGY:

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (Ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per Billion (Ppb) or Micrograms per liter (ug/L) - one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - (MCLG) - The "Goal" - the level of a contaminant in drinking water below, which there is no known or expected risk of health. MCLGs allow for a margin of safety.

Quarterly (QTR) - occurring once every quarter of a year

Running Annual Average (RAA) - an annual average that is continuously calculated

MERIDIAN

City of Meridian

Water and Sewerage
P.O. Box 231
Meridian, MS 39302

PHONE (601)485-1960

EMERGENCY (601)485-1975

www.meridianms.org

OFFICE HOURS
8:15AM-5:00PM
OPEN: MON-FRI

CLOSED: Weekends
& Holidays

Account Number	Service Address			Service Period	Due Date	Bill Date	
514505-104047	5904 2ND ST			04/23/2014-05/19/2014	06/06/2014	05/22/2014	
Service	Meter #	Read Type	Curr Read	Prev Read	Amt Used		
					CU FT.	GAL	
Previous Balance						Amount	
Payment - Thank you!						163.58	
						-130.00	
Water	043650005	Actual	293.00	288.00	5	3750	16.53
Sewerage							16.53
Garbage							12.00
METER OFF Charge							30.00

REFUND DUE 86.36


Should your bill reflect a previous balance, payment of the previous balance is due immediately. Failure to pay the previous balance may result in an interruption of service. **Due date and cut-off date apply only to current charges.** Failure to receive a bill does not release customer from obligation to pay.

Payment Options

- By Bank draft. Please call and a customer representative will help you.
- By Mail. Make checks payable to: City of Meridian. Use the envelope provided for your mail-in. Do not send cash.
- At Trustmark Bank Drive-Thru, 700 23rd Ave. (All payments received here will be posted the following business day)
- At Night Drop. Located on the sidewalk at the 6th Street entrance of City Hall.
- In Person at City Hall, 601 23rd Ave.

All charges are due by the due date. Any previous balance is subject to disconnection.

Monthly Water Usage - Last 13 Months (Gallons)



Important information, about your drinking water, is available in the "2012 Consumer Confidence Report, and can be seen at the following link : www.meridianms.org/ccr2012/ccr_report_fy_2012.pdf You may request a hard copy by calling our office Monday-Friday 7am-3pm at 601-484-6836 or 601-485-1975

NO OTHER NOTICE WILL BE SENT.

PLEASE BRING ENTIRE BILL IF PAYING IN PERSON.

PLEASE DETACH AND RETURN BOTTOM PORTION IF PAYING BY MAIL.

MERIDIAN

City of Meridian
P.O. Box 231
Meridian, MS 39302-0231
Return Service Requested

A better longitude on life.

Check here to receive a hard copy of CCR.

*AUTO UTO**SCH 5-DIGIT 39304

MELISSA L JOHNSON
301 63rRD PL
MERIDIAN MS 39307-6171


566
3



MS27959R

Statement Number	455415
Due Date	06/06/2014
Cut Off Date	06/09/2014
Amount Due On/Before	0.00
Please Enter Amount Paid	Refund Due

City of Meridian
P.O. Box 231
Meridian, MS 39302-0231



Customer Number: 104047

Location Number: 514505

CITY OF MERIDIAN - PWS ID #0380005

2014 CCR REPORT POSTINGS/MAILINGS BASED ON 2013 TESTING RESULTS

POSTED:

APARTMENT COMPLEX NAME:	ADDRESS	DATE
CEDAR BEND APTS	7100 HWY 80 W	5/23/2014
COLLEGE CROSSING	1100 PERIMETER DR	5/23/2014
COLLEGE PARK APTS	4901 14TH	5/23/2014
COLONIAL APARTMENTS	4100 40TH ST	5/23/2014
DEVILLE APARTMENTS	1914 11TH	5/23/2014
EAST GATE APARTMENTS	3500 HWY 39 N	5/23/2014
FOUR FOUNTAINS APTS	2705-1/2 45TH	5/23/2014
J.T. DAVIS COURTS	3715 VALLEY ST	5/23/2014
LANDMARK APARTMENTS	211 NORTH HILLS ST	5/23/2014
LAUDERDALE CO PROPERTIES	HWY 19 SOUTH	5/23/2014
MAR RAY APARTMENTS	4609 BROADMOOR DR	5/23/2014
MARION RD APTS	OLD MARION RD	5/23/2014
THE MARK APTS	3315 NORTH HILLS ST	5/23/2014
MARK VILLA APTS	4907 SHUMATE RD	5/23/2014
MEADOWBROOK APTS	4313 5TH	5/23/2014
MERIDIAN MANOR APTS	815 33RD ST	5/23/2014
NORTH HILLS MANOR	4401 40TH AVE	5/23/2014
NORTHWOODS PLACE	4315 HWY 39 NORTH	5/23/2014
OAK MANOR APTS	200 NORTH HILLS ST	5/23/2014
OKATIBBEE RIDGE APTS	1719 HWY 19 N	5/23/2014
PINE CREEK APTS	4524 HWY 39N	5/23/2014
REGENCY APTS	4320 36TH APT	5/23/2014
ROLLING HILLS APTS	1312-B 22ND AVE	5/23/2014
ST FRANCIS APTS	2427 4TH AVE	5/23/2014
STRAFORD MANOR	4640 POPLAR SPRINGS DR	5/23/2014
VILLAGE APTS	2015 MOSBY RD	5/23/2014
WALKER HILLS APTS	615 21ST PLACE	5/23/2014
WILLOW RIDGE APTS	2701 WILLOW BEND DR	5/23/2014
WOODLANDS APTS	4501 HWY 39 N	5/23/2014
US POST OFFICE MAIN BRANCH	2100 9th St	5/23/2014
US POST OFFICE NORTH BRANCH	5008 GREAT RIVER DR	5/23/2014
US POST OFFICE WEST STATION	708 45TH AVE	5/23/2014

CITY OF MERIDIAN - PWS ID #0380005

2014 CCR REPORT POSTINGS/MAILINGS BASED ON 2013 TESTING RESULTS

MAILED:

MS PUBLIC SERVICE COMMISSION P.O. BOX 1174, JACKSON, MS 39215-1174 6/9/2014
CERTIFIED MAIL

CERTIFICATION FORM TO: P.O. BOX 1700 JACKSON MS 39215-1700
MS DEPT OF HEALTH, DIVISION OF WATER SUPPLY - CERTIFIED MAIL) 6/9/2014

TOWN OF MARION	P O BOX 35 MARION, MS 39342	<u>6/3/2014</u>
LONG CREEK WATER ASSN.	4695 LONGCREEK WATER RD 39301	<u>6/3/2014</u>
SOUTHWEST LAUDERDALE WATER	P.O. BOX 4266 MDN MS 39304	<u>6/3/2014</u>
NORTH LAUDERDALE WATER ASSN	P.O. BOX 143 BAILEY, MS 39320	<u>6/3/2014</u>
CLARKDALE WATER ASSN.	5160 HWY 145 MDN, MS 39301	<u>6/3/2014</u>
NTS WATER ASSOCIATION	8802 WHIPPOORWILL RD MDN, 39307	<u>6/3/2014</u>
TOOMSUBA WATER ASSN.	P.O. BOX 520 TOOMSUBA 39364	<u>6/3/2014</u>
COLLINSVILLE WATER ASSN	P.O. BOX 67 COLLINSVILLE 39325	<u>6/3/2014</u>
RUSSELL UTILITIES	1767 WILLOW LAKE RD, RUSSELL, MS 39364	<u>6/3/2014</u>

POSTED ON WEB SITE 5/15/2014

http://www.meridianms.org/ccr2012/ccr_report_fy_2012.pdf

MESSAGE ON WATER BILLS: Running for full month of June June 2014

