

MISSISSIPPI STATE DEPARTMENT OF HEALTH 2014 JUN 23 AM 10:26
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION
CALENDAR YEAR 2013

West Jackson County Utility District
Public Water Supply Name

0300156 + 0300143
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: _____ / _____ / _____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used Enclosed in the bill.

Date Mailed/Distributed: 6/13/14 + 6/18/14

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: _____ / _____ / _____

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: _____ / _____ / _____

CCR was posted in public places. *(Attach list of locations)* Date Posted: _____ / _____ / _____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

www.wjcod.com / Consumer Confidence Report

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

John J. Brumby / GENERAL MANAGER 6/19/2014
Name/Title (President, Mayor, Owner, etc.) Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

60M

2013 Annual Drinking Water Quality Report
West Jackson County Utility District
PWS#: 0300156 & 0300143
May 2014

2014 JUN 23 AM 10:26

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Pascagoula & Graham Ferry Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the West Jackson Utility District have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact John T. Hannah, Legal Responsible Official at 228.872.3898. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second & fourth Tuesdays of the month at 9:00 AM at the District Office located at 7312 Rose Farm Rd.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCL G	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Gross Alpha	N	2012*	1.2	.4 – 1.2	pCi/L	0	15	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2012*	.008	.001 - .008	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	1	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2010/12*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012*	.437	.301 - .437	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2010/12*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Volatile Organic Contaminants								
56. Carbon tetrachloride	N	2013	1.41	No Range	ppb	0	5	Discharge from chemical plants and other industrial activities
64. Dichloromethane	N	2013	.61	No Range	ppb	0	5	Discharge from pharmaceutical and chemical factories
Disinfection By-Products								
81. HAA5	N	2013	.05	.03 - .05	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	43.3	24.2 – 43.3	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	1.3	.58 – 2.55	mg/l	0	MDRL = 4	Water additive used to control microbes

Westwick PWS ID # 0300143

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Disinfection By-Products								
81. HAA5	N	2013	16	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	51.9	No Range	ppb	0	80	By-product of drinking water chlorination.

* Most recent sample. No sample required for 2012.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

Significant Deficiencies

During a sanitary survey conducted on 3/17/10, the Mississippi State Department of Health cited the following deficiency:

1.) Well in flood zone (100year)

Corrective actions: The system is in a Bilateral Compliance Agreement with the Mississippi State Department of Health to correct this deficiency by 1/01/14.

2.) Improperly constructed well

Corrective actions: The system is in a Bilateral Compliance Agreement with the Mississippi State Department of Health to correct this deficiency by 1/01/14.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Westwick Utility #0300143 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 7. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 44%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

WJCUD would like to thank our customers who participated in the lead and copper sampling program. Thanks for doing your part to keep our water safe.

The West Jackson County Utility District works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2014 JUN 23 AM 10:26

Company Detail	
Company Name	DMS MAIL MANAGEMENT
Address	10541 OUTDOOR WAY STE A GULFPORT, MS 39503-4625
Contact Name	TRACEY ANDREWS
Phone Number	(228)369-4869
Profit Indicator	P
PS Form 3607R - Mailing Transaction Receipt	
Account Holder Account Number	992114
Account Holder Permit Number	354
Account Holder Permit Type	MT
Account Holder CRID	4964214
Post Office of Permit	GULFPORT MS 39503-9651
Post Office of Mailing	GULFPORT MS 39503-9651
Post Office of Permit Cost Center	273146-0515
Post Office of Mailing Cost Center	273146-0515
Mailing Agent Name	DMS MAIL MANAGMENT
Mailing Agent CRID	4964214
Mail Owner Name	WEST JACKSON COUNTY UTILITY DISTRICT
Mail Owner CRID	3341195
JOB ID	
Customer Reference ID	WJW0529, 05/30/2014
CAPS Transaction Number	N/A
Class of Mail	First-Class Mail and First-Class Package Service
Processing Category	Letters (may include Postcards)
Postage Statement ID	188058345
Mailing Group ID	135055830
Mailer's Mailing Date	05/30/2014
Total Pieces	2,530 pcs.
Weight of a single-piece	0.0625 lbs.
Total Weight	158.1250 lbs.
Total Number of Containers	10
Additional Postage for Postage Affixed Mailings	\$ 8.05
Account Number of Additional Postage for Postage Affixed Mailings	
Permit Type of Additional Postage for Postage Affixed Mailings	Postage Affixed to statement
Permit Number of Additional Postage for Postage Affixed Mailings	
Total Adjusted Postage	\$ 971.96
Payment Date and Time	05/30/2014 18:37
Payment Transaction Number	201415018372385M0
Mailer Figures Adjusted?	No
Person authorizing adjustment	
Name	
Phone Number	
Acceptance Site Mailer ID	
Clerk Initials	JGS
Mail Arrival Date and Time	05/30/2014 18:35

Company Detail	
Company Name	DMS MAIL MANAGEMENT
Address	10541 OUTDOOR WAY STE A GULFPORT, MS 39503-4625
Contact Name	TRACEY ANDREWS
Phone Number	(228)369-4869
Profit Indicator	P
PS Form 3607R - Mailing Transaction Receipt	
Account Holder Account Number	992114
Account Holder Permit Number	354
Account Holder Permit Type	MT
Account Holder CRID	4964214
Post Office of Permit	GULFPORT MS 39503-9651
Post Office of Mailing	GULFPORT MS 39503-9651
Post Office of Permit Cost Center	273146-0515
Post Office of Mailing Cost Center	273146-0515
Mailing Agent Name	DMS MAIL MANAGMENT
Mailing Agent CRID	4964214
Mail Owner Name	WEST JACKSON COUNTY UTILITY DISTRICT
Mail Owner CRID	3341195
JOB ID	
Customer Reference ID	WEST JACKSON CTY MAILING, 06/16/2014.
CAPS Transaction Number	N/A
Class of Mail	First-Class Mail and First-Class Package Service
Processing Category	Letters (may include Postcards)
Postage Statement ID	189024976
Mailing Group ID	135635007
Mailer's Mailing Date	06/16/2014
Total Pieces	4,775 pcs.
Weight of a single-piece	0.0500 lbs.
Total Weight	238.7500 lbs.
Total Number of Containers	19
Additional Postage for Postage Affixed Mailings	\$ 13.40
Account Number of Additional Postage for Postage Affixed Mailings	
Permit Type of Additional Postage for Postage Affixed Mailings	Postage Affixed to statement
Permit Number of Additional Postage for Postage Affixed Mailings	
Total Adjusted Postage	\$ 1,832.68
Payment Date and Time	06/16/2014 15:54
Payment Transaction Number	201416715544013M0
Mailer Figures Adjusted?	No
Person authorizing adjustment Name	
Phone Number	
Acceptance Site Mailer ID	
Clerk Initials	JGS
Mail Arrival Date and Time	06/16/2014 15:07