

2014 MAY 28 PM 12:42

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION
CALENDAR YEAR 2013

CITY OF D'IBERVILLE
Public Water Supply Name

0240002 0240255

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: ___ / ___ / ___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___ / ___ / ___

As a URL (Provide URL _____)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: _____

Date Published: ___ / ___ / ___

CCR was posted in public places. (Attach list of locations) Date Posted: 5/27/14

D'Iberville Public Library / Water Dept.

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):

<http://www.msdrwa.org/2013CCR/D'IbervilleCityof.pdf>

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Ruth Quave MAYOR
Name/Title (President, Mayor, Owner, etc.)

5/27/14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2013 Annual Drinking Water Quality Report
 City of D'Iberville
 PWS#: 0240002 & 0240255
 April 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene, Pascagoula Formation, Graham Ferry Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of D'Iberville have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Thomas Burrows at 228.323.5524. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first & third Tuesdays of the month at 5:30 PM at the City Hall located at 10383 Auto Mall Parkway.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID #: 0240002		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								

1. Total Coliform Bacteria	Y	October	Positive	2	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
----------------------------	---	---------	----------	---	----	---	--	--------------------------------------

Radioactive Contaminants

5. Gross Alpha	N	2013	.8	.4 - .8	pCi/L	0	15	Erosion of natural deposits
----------------	---	------	----	---------	-------	---	----	-----------------------------

Inorganic Contaminants

10. Barium	N	2011*	.006	.001 - .006	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011/13	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	.463	.261 - .463	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Volatile Organic Contaminants

66. Ethylbenzene	N	2013	1	No Range	ppb	700	700	Discharge from petroleum refineries
76. Xylenes	N	2013	3.72	No Range	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories

Disinfection By-Products

81. HAA5	N	2013	20	8 - 20	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	34.5	8.96 - 34.5	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	1.60	.1 - 3	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 0240255

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2011*	.009	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011*	.7	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2011*	.41	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

17. Lead	N	2011*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2013	33	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	55	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	2.6	.2 - 3	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2013.

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During October 2013, 2 routine bacteriological sample tested positive for total coliform. This was a violation for the Total Coliform Rule. All resample were clear. All corrective actions were taken and system was returned to compliance

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.


Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of D'Iberville works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

DIBERVILLE

CUSTOMER SERVICE: 228-392-3111 (24/7)
Emergency After Hours & Weekends:
228-392-2310

GRAPH OF MONTHLY WATER USAGE



SPECIAL MESSAGE

Garbage collection by Waste Pro: 1-800-901-7072
South of I-10: Tuesday & Friday - Garbage Pickup/Yard Waste/Trash
 Friday - Recycle
North of I-10: Wednesday & Saturday - Garbage Pickup/Yard Waste/Trash
 Wednesday - Recycle

CHARGES ARE DUE BY DUE DATE
No other notice will be sent.
Past Due Amount Is Subject to Disconnection of Service

ACCOUNT INFORMATION

Customer Name: TAMMIE JOHNSON
 Account Number: 01-036101-04
 Service Address: 3210 RACETRACK RD
 Service Period: 04/14/14 to 05/14/14
 Last Payment Received: 04/22/14 -\$40.74
 Billing Date: 05/23/14
 Due Date: 06/10/14

METER READING

	# of Days	Prev Read	Cur Read	Usage
Water:	30	101	101	0

CURRENT CHARGES

Water: \$6.82
 Sewer: \$19.22
 Garbage: \$11.00
Total Current Charge: \$37.04

AMOUNT DUE

Unpaid Balance: \$40.74
 Current Charges: \$37.04
Total Due If Paid By Due Date: \$77.78

Total Due If Paid After Due Date: \$85.18

Fees: Late Charge: 10% of amount due;
 Returned Check Fee: \$50; Reconnect Fee: \$50;
 Cut Lock/Tampering Fee: up to \$1000

MESSAGE CENTER

Important information about your drinking water is available in the 2013 Consumer Confidence Report at www.msrrwa.org/2013ccr/DibervilleCityof.pdf. Hard copies are also available at Diberville City Hall in the Water Department.

City of
DIBERVILLE
 Water & Sewer Department
 P.O. Box 6519
 Diberville, MS 39540

RETURN SERVICE REQUESTED

AUTOMIXED AADC 750 16 MAAD 87216AA22-A-1
 3615 1 MB 0.435



TAMMIE JOHNSON
 PO BOX 160
 SEAL ROCK OR 97376-0160



PAYMENT COUPON

AMOUNT DUE

Account Number: 01-036101-04
 Current Charges: \$37.04
 Due Date: 06/10/14
Balance Due Upon Receipt of Bill: \$77.78

Please Remit & Make Checks Payable To:



CITY OF DIBERVILLE
 WATER & SEWER DEPARTMENT
 PO BOX 6519
 DIBERVILLE MS 39540-6519

010361010400000777&0000&51&4