

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2013

Mississippi State University  
Public Water Supply Name

PWS# MS 0530012

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other Report on MSU website. Link on MSU homepage

Date(s) customers were informed: 6/20/14 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

As a URL (Provide URL \_\_\_\_\_)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

linked from (www.msstate.edu) - available year-round on (www.msstate.edu/web/water)

**CERTIFICATION**

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

John D. Havel / Assoc. Director, Utilities  
Name/Title (President, Mayor, Owner, etc.)

6/20/14  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
Melanie.Yankowski@msdh.state.ms.us

MM



**MISSISSIPPI STATE**  
UNIVERSITY®

---

# 2013 ANNUAL DRINKING WATER QUALITY REPORT

**MISSISSIPPI STATE UNIVERSITY**  
**PUBLIC WATER SYSTEM ID NO. 0530012**  
**May 2014**

## Consumer Notice Regarding Drinking Water

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Mississippi State University have received moderate to higher susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact J. D. Hardy at 662.325.5899. We want our valued customers to be informed about their water utility. This report will be published on the Mississippi State University Website: <http://www.msstate.edu/web/water/>

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

#### TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or No. of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
1. Total Coliform Bacteria		January	Positive	2	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
<b>Inorganic Contaminants</b>								
10. Barium	N	2013	0.07	.04 - .07	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013	1.1	0.8 - 1.1	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011/13	0.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Flouride	N	2013	0.11	0.10-0.11	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13	6	0	ppb	0	AL=15	Corrosion of household plumbing systems,

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or No. of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
								erosion of natural deposits
<b>Disinfection Byproducts</b>								
81. HAA5	N	2013	3	No Range	ppb	0	60	By-Product of drinking water disinfection
82. TTHM [Total trihalomethanes]	N	2013	8.06	No Range	ppb	0	80	By-Product of drinking water chlorination
Chlorine	N	2012	.9	.8 - 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2013.

#### Microbiological Contaminants

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Mississippi State University works around the clock to provide top quality water to every tap. We ask that all our students help us protect our water sources, which are the heart of our community, our way of life and our children's future.

MISSISSIPPI  
2014 JUN 24 AM 10:10




myState | Calendars | Contact

GO

A-Z Index | Directories | Maps | News

- ABOUT MSU
- ACADEMICS
- ATHLETICS
- GIVING
- LIBRARIES
- OUTREACH
- RESEARCH



Apply Online

- Prospective Students
- Current Students
- Alumni and Friends
- Visitors
- Employees [Maroon MEMO News](#)

[Distance Education](#)   [MSU Meridian](#)   [Multimedia](#)

### CAMPUS ANNOUNCEMENTS

Summer Undergrad Research Symposium entries wanted  
Reduce stress, get fit with Yoga Moves at MSU  
SEC Symposium now taking abstracts

[More](#)

### MISSISSIPPI STATE HEADLINES

Interim MSU dean named prestigious ASEE Fellow  
Mississippi State growing international opportunities  
Old Waverly to become new home for MSU golf  
MSU reports annual 'Drinking Water Quality Report'  
ExxonMobil donations to MSU earn \$288K 'match'  
MEDIA ADVISORY: Bagley College to host Maker Faire  
MSU Alumni Association names new student delegates

[Archive](#)

[Less](#)

### COMING EVENTS

Today:   [Freshman Orientation](#)  
          [EndNote 201: Writing and Citing](#)

[More](#)



SMILE!

### MSU Featured Websites

[Summer Camps at State](#)  
[MSU Daily News Digest](#)



WATER SUPPLY

2014 JUN 24 AM 10: 10



**MISSISSIPPI STATE**  
UNIVERSITY®

---

## MSU reports annual 'Drinking Water Quality Report'

Office of Public Affairs  
News Bureau (662) 325-3442  
Contact: **Allison Matthews**  
June 19, 2014

Mississippi State University officials announced findings in this year's Annual Water Quality Report.

"Again this year, we are pleased to report that the university has met all the requirements of the Mississippi State Department of Health in our efforts to provide a safe water supply," said J.D. Hardy, university energy and mechanical engineer.

Hardy said that a water quality report, also referred to as a Consumer Confidence Report, must be provided to customers. The annual testing is administered by the Mississippi Department of Health.

The 2014 full report is available online at [www.msstate.edu/web/water/](http://www.msstate.edu/web/water/)

For additional information about the report, contact Hardy at 662-325-5899.

For more information about Mississippi State University, see [www.msstate.edu](http://www.msstate.edu).

---