

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY

JUN -9 AM 9:45

CCR CERTIFICATION  
CALENDAR YEAR 2013

Town of Chunky Water Dept  
Public Water Supply Name

0510002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 06/04/2014 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /

As a URL (Provide URL \_\_\_\_\_)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: \_\_\_\_\_

Date Published: / /

CCR was posted in public places. (Attach list of locations) Date Posted: 06/01/2014

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

**CERTIFICATION**

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Ann Clark  
Name/Title (President, Mayor, Owner, etc.)

6/6/2014  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
Melanie.Yanklowski@msdh.state.ms.us



## Inorganic Contaminants

10. Barium	N	2013	.017	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2011*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

## Disinfection By-Products

Chlorine	N	2013	1	.5 – 1.5	ppm	0	MRDL = 4	Water additive used to control microbes
----------	---	------	---	----------	-----	---	----------	---

\* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Town of Chunky Water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2014 JUN -9 AM 9:45

# TOWN OF CHUNKY

24 N Commerce St.  
P.O. Box 86  
Chunky, MS 39323  
[Chunkytownhall@att.net](mailto:Chunkytownhall@att.net)

Mayor  
Aaron Clark


Town Clerk  
Joyce Reynolds

Board of Alderman  
Travis Thompson  
Jacky Johnson  
Eric Gilbert  
Jeremy Luke  
Dwayne Reynolds

06/06/2014

The Consumer Confidence Report was posted for public viewing on 06/01/2014 at the Chunky Town Hall and the Chunky Post Office.

ACCOUNT NO. 010142000	SERVICE FROM 05/01	SERVICE TO 05/31	RETURN THIS STUB WITH PAYMENT TO:			
SERVICE ADDRESS			CHUNKY WATER DEPARTMENT P.O. BOX 36 CHUNKY, MS 39323			
METER READINGS						
CURRENT PREVIOUS USED	530640	525210	5430	PAY NET AMOUNT ON OR BEFORE DUE DATE NET AMOUNT	DUE DATE 06/15/2014 SAVE THIS	PAY GROSS AMOUNT AFTER DUE DATE GROSS AMOUNT
CHARGE FOR SERVICES			26.10	2.90	29.0	
WTR		29.00	BILLS NOT PAID BY 15TH WILL BE DISCONNECTED WITH \$50 RECONNEC			
CREDIT BALANC		2.90-				
NET DUE >>>		26.10				
SAVE THIS >>		2.90				
GROSS DUE >>		29.00				



010142000  
RUSTY KASTLA  
P.O. BOX 233  
CHUNKY, MS 39323

The Consumer Confidence Report is available for viewing at the Chunky Post Office or the Town Hall. Office Hrs Friday 8:00-12:00