

5/2/14

2014 MAY 12 AM 9:02

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION
CALENDAR YEAR 2013

Sardis Lake Community Water Assn.
Public Water Supply Name

540063

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 5/2/2014 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /

As a URL (Provide URL _____)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: The Panolian

Date Published: 5/2/14

CCR was posted in public places. (Attach list of locations) Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Melanie Brown Board Secretary
Name/Title (President, Mayor, Owner, etc.)

5-8-14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

Inorganic Contaminants									
10. Barium	N	2011*	.006	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
17. Lead	N	2009/11*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
Disinfection By-Products									
Chlorine	N	2013	1.1	.9 – 1.2	mg/l	0	MDRL = 4	Water additive used to control microbes	

* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Sardis Lake Community Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Panola County's Largest Print Advertising Medium

662-563-4591
1-800-310-4591
Fax: 662-563-5610
website: www.panolian.com
email: legals@panolian.com

PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI COUNTY OF PANOLA

JOHN H. HOWELL SR., personally appeared before me, the undersigned authority in and for said County and State, and states on oath that he is the CLERK of The Panolian, a newspaper published in the City of Batesville, State and County aforesaid, and having a general circulation in said county, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 consecutive times, to wit:

- Volume No. 134 on the 2 day of May, 2014.
- Volume No. 134 on the _____ day of _____, 2014.
- Volume No. 134 on the _____ day of _____, 2014.
- Volume No. 134 on the _____ day of _____, 2014.

John H. Howell Sr.

AFFIANT

Sworn and subscribed before me, this the 2 day of May, 2014.

By Cassie White
My Commission Expires Oct. 29, 2017

Billing Information

A. Single first insertion of _____ words @ .12	\$ _____
B. Week 2 _____ words @ .10	\$ _____
C. Week 3 _____ words @ .10	\$ _____
D. Week 4 _____ words @ .10	\$ _____
DISPLAY LEGAL <u>36</u> COL. INCHES X 8.00 =	\$ <u>288</u>
Proof of Publication _____ @ \$3.00 ea.	\$ <u>3⁰⁰</u>
TOTAL LEGAL BILLING FEE	\$ <u>291</u>

BILL TO:
Sardis Lake Community Water
P.O. Box 1115
Batesville, MS 38606



Tuesdays months at Western Sizzlin' in Batesville from 1 p.m. - 2 Call 662-234-8585 for information.

Now available, free at The Panolian!
Batesville THE MAGAZINE

SPRING FEST
 BATESVILLE, MS
 May 16-17
 MUSIC • RIDES • FOOD • FUN
 MAY 17 LONESTAR

MAY 16
 5PM - 11PM
 DAVID ASHLEY
 HONKY TONK HEROES
 JAMIE BAKER + THE VIP'S

MAY 17
 TALENT SHOW 10AM - 2PM / MUSIC BEGINS @ 2PM
 MISSISSIPPI PO FOLKS
 FEATURING KEITH SANDERS
 GRACE ASKEW
 KERN PRATT - THE ACCUSED
 JIMBO MATHUS

MIGHTY SOULS
BRASS BAND
BUSH HAWK
LONESTAR

ON THE SQUARE
 DOWNTOWN
 BATESVILLE, MS

888.872.6652 FOR MORE INFO
 ALL PROCEEDS GO TO THE RESTORATION AND REVITALIZATION OF DOWNTOWN BATESVILLE

cspire **BATESVILLE** **MS**

TECHNOLOGIES SOUTH, LLC • BATESVILLE CASSETT • BATESVILLE REHABILITATION • ENERGY MISSISSIPPI, INC.
 HIGHWAY 191 • SERVICE CENTER • GUARANTY BANK & TRUST CO. • KENTUCKY-TENNESSEE CLAY • REGIONS BANK • SAVE-A-LOT
 MATHEWS PRINTING LLC • STUBBS ON THE SQUARE • TG MISSISSIPPI • WELLS FUNERAL HOME & CREATION SERVICE • THE PANOLIAN
 WILLIAM H. FORK & CO., CPAS • BUDWEISER • CLARK INSURANCE AGENCY • DIRECT AUTO INSURANCE • FIRST SECURITY BANK • MI PUEBLO
 GROUPS ONE COMPANY • TALLAHATCHIE VALLEY ELECTRIC POWER ASSOCIATION • HILLIARDS MEDICAL CENTER • Q17
 ALL BUILDING SYSTEMS, LLC • COMPLETE COMPUTERS • CABLE ONE, INC. • PERFORMANCE FOOD SERVICE • PAPER CO., INC.

2013 Annual Drinking Water Quality Report
 Sardis Lake Community Water Association
 PWS# 0540063
 April 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Middle Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how these susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The assessment report is available at the following link: [http://www.sardislakewater.com/assessments](#)

If you have any questions about this report or concerning your water utility, please contact M. Earlene Brewer at 662-563-2700. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regular scheduled meetings. They are held on the first Monday of each month at 7:00 PM at the Coles Point Fire Department.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it can pick up naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the ground or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plant effluent, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be natural or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, farming, pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, a residential use, organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems, radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA's procedures require that limit the amount of certain contaminants in water provided by public water systems. All drinking water (including bottled drinking water) may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Micrograms per liter (µg/l) - one part per million corresponds to one minute in two years or a single penny \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny \$10,000,000.

TEST RESULTS

Contaminant	Violation	Date Collected	Level Detected	Range of Disinfectant or # of Exceeding MCL/Gs	DRM Measure	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10 Barium	N	2011*	006	No Range	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits.
17 Lead	N	2008/11	1	0	ppb	0	AL+10	Corrosion of household plumbing systems, erosion of natural deposits.
Disinfection By-Products								
Chlorine	N	2013	1.1	0-1.2	mg/l	0	MDRL +4	Water additive used to control microbes.

* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal or State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are a indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. Why? Lead water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadinwater>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-878-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection in immunocompromised and other vulnerable consumers are available from the Safe Drinking Water Hotline, 1-800-426-4791.

The Sardis Lake Community Water Association works around the clock to provide top quality water to every tap. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

54/63