

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

2014 JUN 23 AM 10:08

CCR CERTIFICATION
CALENDAR YEAR 2013

Mud Creek Water Assn.
Public Water Supply Name

#0580020 #0580021 #0730026
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other posted in lobby 5/30/14

Date(s) customers were informed: 5/30/14, 6/4/14, / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Pontotoc Progress / New Albany Gazette
Date Published: 5/30/14 6/4/14

CCR was posted in public places. *(Attach list of locations)* Date Posted: 5/30/14

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**:

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Janice Russell
Name/Title (President, Mayor, Owner, etc.)

6/13/14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

720

2013 Annual Drinking Water Quality Report
Mud Creek Water Association
PWS#: 0580020, 0580021 & 0730026
May 2014

2014 JUN 23 AM 10:08

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Ripley Formation & Etaw - McShan Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Mud Creek Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Janice Russell at 662.489.6851. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our annual meeting scheduled for the second Saturday of October at 8:00 AM at 7360 HWY 346, Pontotoc.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS IS # 580020		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2013	1.2	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2013	.0149	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013	4	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011/13	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride	N	2013	1.79	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
--------------	---	------	------	----------	-----	---	---	---------------------------------------------------------------------------------------------------------------------------

Disinfection By-Products

Chlorine	N	2013	.9	.61 – 1.02	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	----	------------	------	---	----------	-----------------------------------------

PWS ID # 580021

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	--------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2012*	3.2	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2012*	.172	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2009/11*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2009/11*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2012*	3.8	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2013	2.04	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	.7	.25 – 1.25	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID # 730026

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	----------------------------------------------------	--------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2013	.01	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2011/13	.6	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2013	.934	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13	4	0	ppb	0	AL=15	Corrosion of household plumbing

									systems, erosion of natural deposits
Disinfection By-Products									
Chlorine	N	2013	.7	.32 – .91	mg/l	0	MDRL = 4	Water additive used to control microbes	

* *Most recent sample. No sample required for 2013.*

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Mud Creek Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

STATE OF MISSISSIPPI
2014 JUN 23 AM 10:08

STATE OF MISSISSIPPI
PONTOTOC COUNTY

Personally appeared before me, the undersigned Notary Public in and for the State and County aforesaid, Lisa Bryant who being duly sworn, states on oath that he was publisher of THE PONTOTOC PROGRESS, published at Pontotoc, Pontotoc County, Mississippi, at the time the attached:

2013 Annual Drinking Water Quality Report

was published and that said notice was published in said paper _____ consecutive times, as follows:

Volume 86 Number 23, on the 4th day of June, 2014

Volume _____, Number _____, on the _____ day of _____, 2014

Volume _____, Number _____, on the _____ day of _____, 2014

Volume _____, Number _____, on the _____ day of _____, 2014

Volume _____, Number _____, on the _____ day of _____, 2014

Volume _____, Number _____, on the _____ day of _____, 2014

Affiant further deposed and said that said newspaper, THE PONTOTOC PROGRESS, has been established for at least twelve months in Pontotoc County, State of Mississippi, next prior to the date of the first publication on the foregoing notice hereto attached, as required of newspapers publishing legal notices by Chapter 313 of the Acts of the Legislature at the State of Mississippi, enacted in regular session in the year 1935.

Lisa Bryant _____, Publisher

Sworn to and subscribed before me, this 4th day of June, 2014

Joyce Ann Brock Jolly
Notary Public



Printers fee \$ 287

Proof of Publication

State of Mississippi,
County of Union

PERSONALLY APPEARED Before me, the undersigned, a notary public in and for UNION County,
Mud Creek water

Mississippi, the Publisher of The New Albany Gazette, a newspaper published in the City of New Albany, Union County, in said state, who, being duly sworn, deposes and says that the NEW ALBANY GAZETTE is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy, in the matter of Cause No. _____

has been made in said newspaper _____ times consecutively, to-wit:

On the 30 day of May, 2014
On the _____ day of _____, 20____
On the _____ day of _____, 20____
On the _____ day of _____, 20____


SWORN TO and subscribed before me, this

30 day of May, 2014

Arnette M. Hutch
Chy S. Salinas
Notary Public

Chancy Clew
Title

RECEIVED OF _____
Payment in full of the above account.



THE NEW ALBANY GAZETTE

By T. Wayne Mitchell

New Albany, Miss. May 30, 2014

To THE NEW ALBANY GAZETTE Dr.

Re: Publishing _____

case of _____

Cause No. _____

Amt. Due \$ _____

2013 Annual Drinking Water Quality Report
 City of Chicago Water Association
 PWS# 1800026 680026 67070026
 May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water you receive in your area. The information is provided to you so you can make informed decisions about your water. We are committed to ensuring the safety of your water. Our water source is from Lake Michigan, which is a natural source of clean water.

The water quality assessment has been completed for your public water system. The overall quality of your water supply is excellent. The water quality assessment is based on the results of the annual monitoring program. The water quality assessment is based on the results of the annual monitoring program. The water quality assessment is based on the results of the annual monitoring program.

If you have any questions about the report or concerning your water utility, please contact us at 312.488.8881. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our annual meetings scheduled for the second Tuesday of October at 8:00 AM at 2300 N. Halsted Street.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The table below lists all of the drinking water contaminants that were detected during the period of January 19 to December 31, 2013. In some cases, you may find a contaminant in your water that is not listed in the table. This is because the table only lists the most common contaminants. As water travels from the surface of land or underground, it picks up naturally occurring minerals and, in some cases, radioactive materials. As water travels from the surface of land or underground, it picks up naturally occurring minerals and, in some cases, radioactive materials. As water travels from the surface of land or underground, it picks up naturally occurring minerals and, in some cases, radioactive materials.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL):** The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set by the MCLG as health-protective maximum contaminant levels.
- Maximum Contaminant Level Goal (MCLG):** The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are for a maximum of 100.
- Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is conclusive evidence that addition of a disinfectant is necessary to control microbial contamination.
- Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- Pesticide (in million parts per billion):** one part per billion (ppb) is one millionth of one percent or one part in a billion parts (1:100,000,000).
- Pesticide (in micrograms per liter):** one microgram per liter (microgram/L) is one millionth of one percent or one part in a billion parts (1:100,000,000).

PWS IS # 580020 TEST RESULTS										
Contaminant	Number of Tests	Date Analyzed	Unit Detected	Range of Detected Values (MCLG, MCL)	MRDL	MCLG	MCL	Unit of Measure	Excess of MCLG or MCL	Excess of MRDL
Inorganic Contaminants										
Asbestos	18	2013	1.2	No Range	ppb	0.8	1.0	10	Excess of MCLG detected, trace levels of asbestos (asbestos fibers) were detected in the water supply.	None
Barium	18	2013	10148	No Range	ppm	2	2	1	Excess of MCLG detected, trace levels of barium were detected in the water supply.	None
Cadmium	18	2013	2	No Range	ppm	100	100	100	Excess of MCLG detected, trace levels of cadmium were detected in the water supply.	None
Copper	18	2013/15	0	0	ppm	1.3	1.3	1.3	Excess of MCLG detected, trace levels of copper were detected in the water supply.	None
Fluoride	18	2013	1.0	No Range	ppm	1.0	1.0	1.0	Excess of MCLG detected, trace levels of fluoride were detected in the water supply.	None
Disinfection By-Products										
Chlorine	18	2013	2	1.0 - 2.0	mg/L	2	2	MDRL = 2.0	None	None

PWS ID # 580021 TEST RESULTS										
Contaminant	Number of Tests	Date Analyzed	Unit Detected	Range of Detected Values (MCLG, MCL)	MRDL	MCLG	MCL	Unit of Measure	Excess of MCLG or MCL	Excess of MRDL
Inorganic Contaminants										
Asbestos	18	2013	1.2	No Range	ppb	0.8	1.0	10	Excess of MCLG detected, trace levels of asbestos (asbestos fibers) were detected in the water supply.	None
Barium	18	2013	172	No Range	ppm	2	2	1	Excess of MCLG detected, trace levels of barium were detected in the water supply.	None
Copper	18	2013/15	0	0	ppm	1.3	1.3	1.3	Excess of MCLG detected, trace levels of copper were detected in the water supply.	None
Lead	18	2013/15	1	0	ppm	0.05	0.05	0.05	Excess of MCLG detected, trace levels of lead were detected in the water supply.	None
Manganese	18	2013	0.4	No Range	ppm	0.3	0.3	0.3	Excess of MCLG detected, trace levels of manganese were detected in the water supply.	None
Disinfection By-Products										
Chlorine	18	2013	2	1.0 - 2.0	mg/L	2	2	MDRL = 2.0	None	None

We are required to monitor your drinking water for specific contaminants which are listed in the table above. The table above lists all of the drinking water contaminants that were detected during the period of January 19 to December 31, 2013. In some cases, you may find a contaminant in your water that is not listed in the table. This is because the table only lists the most common contaminants.

If you have any questions about the report or concerning your water utility, please contact us at 312.488.8881. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our annual meetings scheduled for the second Tuesday of October at 8:00 AM at 2300 N. Halsted Street.

All kinds of drinking water are subject to natural contamination by substances that are naturally occurring in the water. These substances are not added to the water. The natural occurrence of these substances is not controlled by the water utility. The natural occurrence of these substances is not controlled by the water utility.

2013 Annual Drinking Water Quality Report
 City of Chicago Water Association
 PWS# 1800026 680026 67070026
 May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water you receive in your area. The information is provided to you so you can make informed decisions about your water. We are committed to ensuring the safety of your water. Our water source is from Lake Michigan, which is a natural source of clean water.

The water quality assessment has been completed for your public water system. The overall quality of your water supply is excellent. The water quality assessment is based on the results of the annual monitoring program. The water quality assessment is based on the results of the annual monitoring program.

If you have any questions about the report or concerning your water utility, please contact us at 312.488.8881. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our annual meetings scheduled for the second Tuesday of October at 8:00 AM at 2300 N. Halsted Street.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The table below lists all of the drinking water contaminants that were detected during the period of January 19 to December 31, 2013. In some cases, you may find a contaminant in your water that is not listed in the table. This is because the table only lists the most common contaminants. As water travels from the surface of land or underground, it picks up naturally occurring minerals and, in some cases, radioactive materials. As water travels from the surface of land or underground, it picks up naturally occurring minerals and, in some cases, radioactive materials.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL):** The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set by the MCLG as health-protective maximum contaminant levels.
- Maximum Contaminant Level Goal (MCLG):** The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are for a maximum of 100.
- Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is conclusive evidence that addition of a disinfectant is necessary to control microbial contamination.
- Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- Pesticide (in million parts per billion):** one part per billion (ppb) is one millionth of one percent or one part in a billion parts (1:100,000,000).
- Pesticide (in micrograms per liter):** one microgram per liter (microgram/L) is one millionth of one percent or one part in a billion parts (1:100,000,000).

PWS ID # 730026 TEST RESULTS										
Contaminant	Number of Tests	Date Analyzed	Unit Detected	Range of Detected Values (MCLG, MCL)	MRDL	MCLG	MCL	Unit of Measure	Excess of MCLG or MCL	Excess of MRDL
Inorganic Contaminants										
Asbestos	18	2013	1.2	No Range	ppb	0.8	1.0	10	Excess of MCLG detected, trace levels of asbestos (asbestos fibers) were detected in the water supply.	None
Copper	18	2013/15	0	0	ppm	1.3	1.3	1.3	Excess of MCLG detected, trace levels of copper were detected in the water supply.	None
Fluoride	18	2013	1.0	No Range	ppm	1.0	1.0	1.0	Excess of MCLG detected, trace levels of fluoride were detected in the water supply.	None
Lead	18	2013/15	1	0	ppm	0.05	0.05	0.05	Excess of MCLG detected, trace levels of lead were detected in the water supply.	None
Disinfection By-Products										
Chlorine	18	2013	2	1.0 - 2.0	mg/L	2	2	MDRL = 2.0	None	None

We are required to monitor your drinking water for specific contaminants which are listed in the table above. The table above lists all of the drinking water contaminants that were detected during the period of January 19 to December 31, 2013. In some cases, you may find a contaminant in your water that is not listed in the table. This is because the table only lists the most common contaminants.

If you have any questions about the report or concerning your water utility, please contact us at 312.488.8881. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our annual meetings scheduled for the second Tuesday of October at 8:00 AM at 2300 N. Halsted Street.

All kinds of drinking water are subject to natural contamination by substances that are naturally occurring in the water. These substances are not added to the water. The natural occurrence of these substances is not controlled by the water utility. The natural occurrence of these substances is not controlled by the water utility.

If you're worried about lead in your water, you can take steps to reduce lead in your water. Lead in your water is a concern because it can cause health problems, especially for young children and pregnant women. Lead in your water is a concern because it can cause health problems, especially for young children and pregnant women. Lead in your water is a concern because it can cause health problems, especially for young children and pregnant women.

All kinds of drinking water are subject to natural contamination by substances that are naturally occurring in the water. These substances are not added to the water. The natural occurrence of these substances is not controlled by the water utility. The natural occurrence of these substances is not controlled by the water utility.

We are required to monitor your drinking water for specific contaminants which are listed in the table above. The table above lists all of the drinking water contaminants that were detected during the period of January 19 to December 31, 2013. In some cases, you may find a contaminant in your water that is not listed in the table. This is because the table only lists the most common contaminants.

The City of Chicago Water Association is committed to providing you with the highest quality water possible. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our annual meetings scheduled for the second Tuesday of October at 8:00 AM at 2300 N. Halsted Street.

55/20