

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2013

2014 MAY 29 AM 9:23

EAST LOWNDES WATER ASSOCIATION, Inc.  
Public Water Supply Name

PWS#s: 440005 (A10001809), 440080, 440081, 440100, 440103

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other Four Billing Cycles

Date(s) customers were informed: 05/08/14, 05/15/14, 05/22/14, 05/29/14

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_ / \_\_\_ / \_\_\_  
As a URL (Provide URL \_\_\_\_\_)  
As an attachment  
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_ / \_\_\_ / \_\_\_ EAST LOWNDES WATER ASSOC. BUSINESS OFFICE  
1325 RIDGE ROAD COLUMBUS, MS 39705

CCR was posted in public places. *(Attach list of locations)* Date Posted: 04/26/2014

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

<http://www.eastlowndes.com/ELWA-2013CCR.pdf>

**CERTIFICATION**

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Arant Mitchell, GENERAL MANAGER  
Name/Title (President, Mayor, Owner, etc.)

MAY 29, 2014  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
Melanie.Yanklowski@msdh.state.ms.us



### Inorganic Contaminants

10. Barium	N	2012*	.075	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	.86	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
16. Fluoride	N	2012*	.866	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

81. HAA5	N	2013	2	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	1.96	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	1.3	1 - 1.6	mg/l	0	MRDL = 4	Water additive used to control microbes

### PWS ID # 0440080 Plant Two - Huckleberry Lane - TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

### Radioactive Contaminants

5. Gross Alpha	N	2012*	3.3	No Range	pCi/L	0	15	Erosion of natural deposits
----------------	---	-------	-----	----------	-------	---	----	-----------------------------

### Inorganic Contaminants

10. Barium	N	2012*	.06	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	1.3	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011/13	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012*	.394	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

Chlorine	N	2013	1.2	1 - 1.5	mg/l	0	MRDL = 4	Water additive used to control microbes
----------	---	------	-----	---------	------	---	----------	---

### PWS ID # 0440081 Plant Three A - Old Yorkville Rd - TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

Inorganic Contaminants								
10. Barium	N	2012*	.09	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride	N	2012*	.168	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2011*	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2013	1.3	1 – 1.50	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 0440103 – Plant 3B West Old Yorkville Road - TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2012*	.08	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
16. Fluoride	N	2012*	.168	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2010/12*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2013	1.4	1.1 – 1.6	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 0440100 – Herman Vaughn Road - TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2012*	.009	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	1.2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
16. Fluoride	N	2012*	.521	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Disinfection By-Products								
81. HAA5	N	2013	1	No Range	ppb	0	60	By-Product of drinking water disinfection.

82. TTHM [Total trihalomethanes]	N	2013	1.62	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	1.3	1 – 1.4	ppm	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2013.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system.

#### **East Lowndes #1 – Lee Stokes Road**

The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 92%.

#### **East Lowndes #2 – Huckleberry Lane**

The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 100%.

#### **East Lowndes #3A – East Old Yorkville Road**

The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 100%.

#### **East Lowndes #3B – West Old Yorkville Road**

The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 100%.

#### **East Lowndes #4 – Herman Vaughn Road**

The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 100%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The East Lowndes Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. The Association has received a rating of 5.0 through the Mississippi State Department of Health's Capacity Assessment Program on all five systems.



# EAST LOWNDES WATER ASSOCIATION

1325 RIDGE ROAD  
(662) 328-1065

P.O. BOX 9190  
Office Hours: 8:00 a.m. - 4:30 p.m. Monday - Friday

COLUMBUS, MS 39705-0023


CUSTOMER NUMBER	ACCOUNT NUMBER	SERVICE PERIOD	DAYS	PIN #
30291	63\5045-4	04/17/2014 - 05/16/2014	29	0094
SERVICE	PREVIOUS READING	PRESENT READING	USAGE	AMOUNT DUE
PREVIOUS BALANCE DUE WATER SRVC	528944	542724	13780	0.00 68.90

WATER SUPPLY  
 2014 MAY 29 AM 9:23

**WILL BE PAID BY BANK DRAFT**

<b>TOTAL DUE NOW</b>	68.90
<b>AFTER 06/04/2014 PAY</b>	\$75.79

**Your 2013 Annual Drinking Water Quality Report is posted at:** <http://www.eastlowndes.com/ELWA-2013CCR.pdf>  
**If you prefer to have a copy mailed to you, please call 662-328-1065.**



**OUR NIGHT DEPOSITORY IS LOCATED AT THE BUSINESS OFFICE. 1325 RIDGE ROAD.**

Automatic Bank Draft is available.

**TO REPORT WATER OUTAGE OR EMERGENCY AFTER HOURS 662-327-1651**

Retain This Copy For Your Records

Please Detach And Return This Portion With Payment



**East Lowndes Water Association**  
 P.O. BOX 9190  
 COLUMBUS, MS 39705-0023  
**Address Service Requested**

SERVICE ADDRESS	2005 CHOCTAW ROAD	
CUSTOMER NO.	PAST DUE AFTER	PREVIOUS BALANCE
30291	06/04/2014	0.00
ACCOUNT NUMBER	<b>NET AMOUNT DUE</b>	TOTAL DUE IF PAID LATE
63\5045-4	68.90	75.79

49136-21A\*4\*01192 \*AUTO\*\*SCH 5-DIGIT 39705  
 MARTHA HOPE IMES  
 2005 CHOCTAW RD  
 COLUMBUS MS 39705-1434

01192



**East Lowndes Water Association**  
 P.O. Box 9190  
 Columbus, MS 39705-0023