

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2013

# 65001

Public Water Supply Name

Center Ridge Water Assoc.  
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 6/14/14, 15/22/14, 1/1

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /  
As a URL (Provide URL \_\_\_\_\_)  
As an attachment  
As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: \_\_\_\_\_

Date Published: / /

CCR was posted in public places. (Attach list of locations) Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):  
\_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

  
Name/Title (President, Mayor, Owner, etc.)

7/1/14  
Date

CCR Report

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to: (601) 576-7800 1601 576-7551  
May be emailed to: Melanie.Yanklowski@msdh.state.ms.us

Rec 5/31/14

2013 Annual Drinking Water Quality Report  
Center Ridge Water Association  
PWS ID#: 0650001  
May 2014

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Center Ridge Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Pete Bruce at 601.278.6430. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at 6:00 PM at the Center Ridge Water office.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2013. In cases where monitoring wasn't required in 2013, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								

10. Barium	N	2013	.009	.008 - .009	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013	1	.6 - 1	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2009/11*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2013	.87	.40 – .87	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2009/11*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

81. HAA5	N	2013	8	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2013	14.14	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2013	2	1-2.5	Mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2013.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 80%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Center Ridge Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

# 2013 ANNUAL CENTE

We're pleased to present to you this year's A services we deliver to you every day. Our con understand the efforts we make to continually i the quality of your water. Our water source

**McDONALD T**  
Grain & Feed Ingre  
1-800-71  
NOW HIRING OWN

**OTT & THE FC**  
201 FRANKS, FORTUNE, N  
601-669-3912  
OTHER LOCATION  
4501 W. WINDY  
5610 W. WINDY  
SKYWAY ROOM

**SISTRUNK'S SALES & SERVICE**  
819 B WEST 8TH ST HWY 80  
FOREST MS 39074  
Foreign & Domestic Repairs  
Tune-Ups • Exhaust & A/C Repair  
James Sistrunk 601-468-3588  
Owner

**Baptist Bible & Book House**  
605 Commerce St., Laurel, MS  
649-7682  
The Bible's Largest Christian Bookstore  
14 P. M. - 5:30 P. M. Sat. 10 A.M. - 2 P.M.

**Independent Car Dealer**  
28E. Taylorville, Ms.  
1-786-4924

**your ad could be THIS**

**Walmart**  
Save money. Live better.  
1625 Simpson Hwy. 49 S  
Magee, MS  
Tom Hagg, Manager  
601-849-2628

**American Cancer Society**  
For information call the  
event organizer, Karen Ware  
601-452-0359

This event will take place every other Tuesday night at 8:15 p.m. This is a free family event. Drinks and snacks will be available for purchase on site.

Dates and movies are May 27, The Sandlot; June 10, Despicable Me; June 24, Frozen; July 8, Cars and July 22, Little Giants. Dates and movies are subject to change.

### Raleigh Basketball Booster Club hamburger plate sale

The Raleigh Basketball booster club will have a hamburger fundraiser Thursday, June 5, from 10 a.m.- 5 p.m. at the school.

All the proceeds will go to the Raleigh basketball booster club to help send our players to camp.

The plates are \$7 each and will include burger, chips and a drink. Walk-ups are welcome or you can see any Raleigh Lady Lions basketball player for an advanced ticket.

There will also be a cash drawing on the same day. Chances for the cash prize are \$5 each and can be purchased at the school on June 5. This will be a "half the pot" giveaway so the more tickets we sell, the more money we give away.

For questions e-mail Matt Wallace at matt.wallace@smithcountyschools.net.

### Gospel sing

There will be a gospel sing Saturday, June 14, at 6:30 p.m. at the Sanford Community Center, 663 Old Hwy. 49, featuring Southern Heritage, Trusty's of Davo Crossing and the Faithway Singers.

Admission is free, a love-offering will be taken.

### Shady Grove Baptist Church Revival

Shady Grove Baptist Church will hold revival services June 1-4 with Bro. Trent Sullivan as the speaker. Sunday, June 1, services will be at 11:00

is located Mize and 733-5586 East Side VBS

Vacat East Side be June 4 grades K-

Saturday VBS Blow parents an awards ce followed will end w an waters Children about Jesu ble Sea Ac

Walker Fa The ann will be hel the Depot, behind Tri lottesville 1 at 12:00 nc

Please well-filled family mer Tinkers Ca A sumn would not l Hol-Mac kers Camp will mark t ing class si 2008. The huge succe grow in nur At the wa 2-June 6, s ker with sus engines, re a drill pree electronics. The cam dents enter 9th grades. tion about 764-4121 Carmen Cle

Legal educ The Mis Legal Corp County Ce Agency wil w national w legal matter

the State of Mississippi, County of Smith PERSONALLY CAME before me, th undersigned a Notary Public in and fo SMITH COUNTY, MISSISSIPPI th OFFICE CLERK of the SMIT COUNTY REFORMER, a newspap published in the Town of Raleigh, Smit County, in said State, who being dul sworn, deposes and says that the SMIT COUNTY REFORMER is a newspap as defined and prescribed in §13-3-31 c the Mississippi Code 1972 Annotate and that the publication of a notice, c which the annexed is a copy, in th matter of

*2013 Annual Drinking Water Quality Report*  
4x18

has been made in said paper 1 time consecutively, to-wit:

- On the 28 day of May 2014
- On the \_\_\_ day of \_\_\_ 20\_\_
- On the \_\_\_ day of \_\_\_ 20\_\_
- On the \_\_\_ day of \_\_\_ 20\_\_

*Phil Turner*  
OFFICE CLERK

SWORN to and subscribed before me,  
this the 3rd day of June 2014  
*Carmen Cle*  
NOTARY PUBLIC

Words  
Cost