

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

Town of Tutwiler

Public Water Supply Name

0680010

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)

- Advertisement in local paper (attach copy of advertisement)
 On water bills (attach copy of bill)
 Email message (MUST Email the message to the address below)
 Other _____

Date(s) customers were informed: ____/____/____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____/____/____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ____/____/____

As a URL (Provide URL _____)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)

Name of Newspaper: The Sun-Sentinel

Date Published: 6/19/2014

CCR was posted in public places. (Attach list of locations) Date Posted: ____/____/____

CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED):

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Nicholas Harris, Mayor
Name/Title (President, Mayor, Owner, etc)

6-1-14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

2013 Consumer Confidence Report
Town of Tutwiler
PWS ID#0680010

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, & how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, & infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium & other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

According to the MS Department of Environmental Quality Office of Land & Water Resource PWS Report, the Town of Tutwiler water wells draw water from the Meridian Upper Wilcox Aquifer. A well located at the old plant & Well 2, located on West & Lacy Street, have been abandoned.

Source water assessment & its availability

The Consumer Confidence Report & the Source Water Assessment Report will not be mailed to the water system customer. However, these two reports are available upon request.

The PWS Report from the MS Dept. of Environmental Quality Office of Land & Water shows the final susceptibility ranking as follows:

Source ID #1-Moderate Source ID #2-Moderate Source ID #3-Moderate Source ID #4-Lower

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants & potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water & bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, & wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals & in some cases, radioactive material, & can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses & bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, & wildlife; inorganic contaminants, such as salts & metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic waste water discharges, oil & gas production, mining, or farming; pesticides & herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, & residential uses; organic Chemical Contaminants, including synthetic & volatile organic chemicals, which are by-products of industrial processes & petroleum production, & can also come from gas stations, urban storm water runoff, & septic systems; & radioactive contaminants, which can be naturally occurring or be the result of oil & gas production & mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food & Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

The Town of Tutwiler works to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life & our children's future. The regular board meetings for the Town of Tutwiler are held on the first Tuesday of each month at 6:00 P.M. at town hall. For further information, please contact Mayor Nichole Harris at 662-345-8321.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria & microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost & no-cost ways to conserve water. Small changes can make a big difference - try one today & soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair & shaving & save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, & can save you up to 750 gallons a month.
- Run your clothes washer & dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets & faucets. Faucet washers are inexpensive & take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank & wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it & during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations & insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, & if needed, survey your connection & assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn & garden fertilizers & pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community & volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce & distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women & young children. Lead in drinking water is primarily from materials & components associated with service lines & home plumbing. Town of Tutwiler is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, & steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, & in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water & have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms & abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL, TT, or MRDL</u>	<u>Your Water</u>	<u>Range</u>		<u>Sample Date</u>	<u>Violation</u>	<u>Typical Source</u>
				<u>Low</u>	<u>High</u>			
Disinfectants & Disinfectant By-Products								
<i>(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)</i>								
Haloacetic Acids (HAA5) (ppb)	NA	60	20	NA		2013	No	By-product of drinking water chlorination
Chlorine (as Cl ₂) (ppm)	4	4	1.2	0.11	3.3	2013	No	Water additive used to control microbes
THMs [Total Trihalomethanes] (ppb)	NA	80	34.9	NA		2013	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	0.0042	0.0038	0.0042	2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.238	0.235	0.238	2013	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer & aluminum factories
Chromium (ppb)	100	100	0.9	ND	0.9	2013	No	Discharge from steel & pulp mills; Erosion of natural deposits
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	0.5	ND	0.5	2012	No	Erosion of natural deposits
<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.5	2013	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	1	2011	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL or MRDL</u>	<u>Your Water</u>	<u>Violation</u>	<u>Typical Source</u>
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Cyanide [as Free Cn] (ppb)	200	200	ND	No	Discharge from plastic & fertilizer factories; Discharge from steel/metal factories
Radium (combined 226/228) (pCi/L)	0	5	ND	No	Erosion of natural deposits
Uranium (ug/L)	0	30	ND	No	Erosion of natural deposits
Unit Descriptions					
Term	Definition				
ug/L	ug/L : Number of micrograms of substance in one liter of water				
ppm	ppm: parts per million, or milligrams per liter (mg/L)				
ppb	ppb: parts per billion, or micrograms per liter (ug/L)				
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)				
NA	NA: not applicable				
ND	ND: Not detected				
NR	NR: Monitoring not required, but recommended.				
Important Drinking Water Definitions					
Term	Definition				
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.				
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.				
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.				
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.				
Variances & Exemptions	Variances & Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.				
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.				
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.				
MNR	MNR: Monitored Not Regulated				
MPL	MPL: State Assigned Maximum Permissible Level				
For more information please contact:					

Contact Name: Mayor Nichole Harris
Address: POB 176, Tutwiler, MS 38963
Phone: 662-345-8321
Fax: 662-345-0156

Affidavit (Proof) of Publication

68110

The **Sun-Sentinel** 

Serving the communities of Tallahatchie County

STATE OF MISSISSIPPI, COUNTY OF TALLAHATCHIE, CITY OF CHARLESTON


Before me, Clay McFerrin, a Notary Public of said state, county and city, personally appeared Krista McFerrin, clerk of The Sun-Sentinel, who upon oath stated that the notice attached hereto was published in said newspaper on the dates listed below:

In the following issues:

Vol. 91 No. 25 Dated June 19, 2014

Vol. ___ No. ___ Dated _____

The Sun-Sentinel
P.O. Box 250 • Charleston, MS 38921
Phone: 662-647-8462 • Fax: 662-647-3830
E-mail: krista@charlestonsun.net



Krista McFerrin, Clerk

Sworn to and subscribed before me, this
the 1 day of July 2014



Clay McFerrin, Notary Public



2013 Consumer Confidence Report
 Trust of Tufts' PHS ID #004010

The 2013 Consumer Confidence Report (CCR) is a key indicator of the trust of Tufts' PHS ID #004010. It is based on a survey of 1,000 Tufts' PHS ID #004010 users, conducted in the first quarter of 2013. The survey asked users to rate their confidence in Tufts' PHS ID #004010 on a scale of 1 to 5, with 1 being the lowest level of confidence and 5 being the highest. The survey also asked users to identify the reasons for their confidence or lack thereof. The results of the survey are presented in the following table.

Category	Confidence Level	Percentage
Overall Confidence	Very High	15%
	High	35%
	Medium	30%
	Low	15%
	Very Low	5%
Reasons for Confidence	Quality of Care	45%
	Staff Friendliness	30%
	Facilities	20%
	Cost of Services	10%
	Accessibility	10%
Reasons for Lack of Confidence	Quality of Care	35%
	Staff Friendliness	25%
	Facilities	15%
	Cost of Services	15%
	Accessibility	10%

Category	Confidence Level	Percentage
Overall Confidence	Very High	15%
	High	35%
	Medium	30%
	Low	15%
	Very Low	5%
Reasons for Confidence	Quality of Care	45%
	Staff Friendliness	30%
	Facilities	20%
	Cost of Services	10%
	Accessibility	10%
Reasons for Lack of Confidence	Quality of Care	35%
	Staff Friendliness	25%
	Facilities	15%
	Cost of Services	15%
	Accessibility	10%

The 2013 Consumer Confidence Report (CCR) is a key indicator of the trust of Tufts' PHS ID #004010. It is based on a survey of 1,000 Tufts' PHS ID #004010 users, conducted in the first quarter of 2013. The survey asked users to rate their confidence in Tufts' PHS ID #004010 on a scale of 1 to 5, with 1 being the lowest level of confidence and 5 being the highest. The survey also asked users to identify the reasons for their confidence or lack thereof. The results of the survey are presented in the following table.

The Clarksdale

Press Register

Proof of Publication

STATE OF MISSISSIPPI
COUNTY OF COAHOMA

Personally appeared before me, a Notary Public in and for said County and State, the publisher, general manager, or his undersigned agent, of a newspaper, printed and published in the City of Clarksdale, in the county and state aforesaid, called **The Clarksdale Press Register**, who being duly sworn, deposed and said that the publication of a notice of which a true copy is hereto affixed, has been made in said paper for the period of 1 weeks consecutively to-wit:

- In Vol. 148 No. 46 dated the 7th day of June 2013
- In Vol. _____ No. _____ dated the _____ day of _____
- In Vol. _____ No. _____ dated the _____ day of _____
- In Vol. _____ No. _____ dated the _____ day of _____
- In Vol. _____ No. _____ dated the _____ day of _____

and that **The Clarksdale Press Register** has been published for a period of more than one year.

Brenda Keller

Publisher or Designated Agent
For the Clarksdale Press Register

Sworn to and subscribed before me, this 7th _____

day of June _____, 2013



Debbie B. Fusa

Notary Public

My Commission Expires 2/20/17

To: Turn of Turkeys

for taking the annexed publication of 96"

words or the equivalent thereof for a total of 1

times \$ 940.00 plus \$3.00 for making each proof

of publication and depositing to same for a total cost of

\$ 943.00

Sandra R. Hite

For the Clarksdale Press Register