

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2013

2014 JUL 23 AM 9:56

East Pike Water Association, Inc.
Public Water Supply Name

MS0570051

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 05/30/14, / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
As a URL (Provide URL _____)
As an attachment
As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Enterprise Journal


Date Published: 06 / 01 / 14

CCR was posted in public places. *(Attach list of locations)* Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2013 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


Name/Title (President, Mayor, Owner, etc.)

6-20-14
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
Melanie.Yanklowski@msdh.state.ms.us

Annual Drinking Water Quality Report

East Pike Water Association, Inc
PWS # MS0570051
September 9, 2014

CORRECTED CCR

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is from 2 wells using water from the Miocene Aquifer.

Source water assessment and its availability

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the East Pike Water Association have received a moderate susceptibility ranking to contamination.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have questions about this report or concerning your water utility, please contact Charles Schilling, Certified Water Operator, at 601-249-3502. We want our valued customers to be informed about their water utility. If you want to learn more, please attend our monthly board meeting, which is held on the second Monday of each month at 5:30pm at the fellowship Hall of Calvary Baptist Church, 1013 Pricedale Dr., Summit, MS.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. East Pike Water Association, Inc is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TT, or		Low	High			
	MRDLG	MRDL	Water					
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	6	6	6	2013	No	By-product of drinking water chlorination
Chlorine (as Cl ₂) (ppm)	4	4	1.8	0.52	2.2	2013	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	3.44	3.44	3.44	2013	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	0.0226	0.0226	0.0226	2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	0.1	0.1	0.1	2013	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Nitrate [measured as Nitrogen] (ppm)	10	10	0.94	0.94	0.94	2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	0.02	0.02	2013	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Antimony (ppb)	6	6	0.5	0.5	0.5	2013	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	0.5	0.5	2013	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Beryllium (ppb)	4	4	0.5	0.5	0.5	2013	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	0.5	0.5	0.5	2013	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	0.5	0.5	0.5	2013	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	15	15	15	2013	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Mercury [Inorganic] (ppb)	2	2	0.5	0.5	0.5	2013	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppb)	50	50	2.5	2.5	2.5	2013	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	0.5	0.5	2013	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
Radioactive Contaminants								
Uranium (ug/L)	0	30	0.5	0.5	0.5	2012	No	Erosion of natural deposits
Volatile Organic Contaminants								
Toluene (ppm)	1	1	0.0005	0.0005	0.0005	2010	No	Discharge from petroleum factories
Xylenes (ppm)	10	10	0.0005	0.0005	0.0005	2010	No	Discharge from petroleum factories; Discharge from chemical factories

Benzene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Ethylbenzene (ppb)	700	700	0.5	0.5	0.5	2010	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	0.5	0.5	2010	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	0.5	0.5	2010	No	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	200	200	0.5	0.5	0.5	2010	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	0.5	0.5	2010	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	0.5	0.5	2010	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	0.5	0.5	0.5	2010	No	Leaching from PVC piping; Discharge from plastics factories
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	

Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.4	2012	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2	2012	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: O. R. Gunther
Address:
612 Delaware Ave., Suite 4
McComb, MS 39648
Phone: (601) 249-3502
Fax: (601) 684-8230

2014 JUN 23 AM 9:57

STATE OF MISSISSIPPI,
COUNTY OF PIKE

PERSONALLY CAME before me, the undersigned, a notary public in and for PIKE County, Mississippi, the CLERK of the McCOMB ENTERPRISE-JOURNAL, a newspaper published in the City of McComb, Pike County, in said state who being duly sworn, deposes and says that the McCOMB ENTERPRISE-JOURNAL is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy in the

matter of 2013 Annual Drinking Water Quality Report
East Pike Water Association

has been made in said paper 1 times consecutively, to wit:

On the 1 day of June, 20 14

On the _____ day of _____, 20 _____


SWORN TO and subscribed before me, this

12 day of June, 20 14

Kim Molder
Notary Public

Korey McAnson
Clerk

My Commission Expires: 6/19/17



McComb, Miss. June 12, 20 14

To McComb Enterprise-Journal

TO PUBLISHING _____

case of _____

_____ words space _____

_____ times and making proof, \$ 1,350.00

RECEIVED OF _____

payment in full of the above account.

Release payment to

East Pike Water Association
P.O. Box 592
McComb, MS 39649
601-249-3502

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID 2014 JUN 23 AM 9:55
ZIP CODE 39649
PERMIT # 459

This institution is an equal opportunity provider and employer.

	Previous Balance:	24.64
*HOME	598680-596180=2500	20.00
LATE CHARGE		2.46

Return this portion with payment.

After 06/20/14 pay 51.56
47.10 is due by 06/20/14

47.10 is due by 06/20/14

Acct# 67510 After 06/20/14 pay 51.56
Last Pmt \$27.42 05/14/14

EARNEST JAMES HOLMES
SVC:04/25/14-05/23/14 (28 days)
263 ELLIOTT CEMETERY ROAD
**IN LIEU OF MAILING, CCR WILL BE PUBLISHED IN
THE ENTERPRISE JOURNAL ON JUNE 01, 2014**

Acct# 67510
263 ELLIOTT CEMETERY ROAD

Forwarding Service Requested
EARNEST JAMES HOLMES
263 ELLIOTT CEMETERY ROAD
TYLERTOWN MS 39667

