WATER SUPPLY

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY 2015 APR 30 AM 8:09
CCR CERTIFICATION
CALENDAR YEAR 2014

Rocky Creek Utilities, Inc.
Public Water Supply Name

0200006
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☒ Advertisement in local paper (attach copy of advertisement)
- ☐ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other_____

Date(s) customers were informed: 04 / 23 / 15 , / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used_____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: George County Times

Date Published: 04 / 23 / 2015

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

_____

CERTIFICATION
I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

LaJune Welford, Mgr. / Operator
Name/Title (President, Mayor, Owner, etc.)

April 28th, 2015
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

WATER SUPPLY
2015 MAY -1 PM 2:08

2014 Annual Drinking Water Quality Report
Rocky Creek Utilities, Inc.
PWS#: 0200006
April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from two wells drawing from the Miocene Series Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Rocky Creek Utilities, Inc. have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact LaJune Welford at 601.508.6387. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Thursday of each month at 6:00 PM at the office building located at 1197 Rocky Creek Road.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st , 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk..

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
Fecal coliform and E.coli	N	September	Positive	1	NA	0		Human and animal fecal waste

Inorganic Contaminants

10. Barium	N	2014	.009	.002 - .009	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	4.4	3.9 – 4.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.215	.139 - .215	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2014	7	6 - 7	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	16.99	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1.20	.60 – 1.8	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014.*

Microbiological Contaminants:

(2) Fecal coliform/E.Coli. Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.

In September 2014 our system had one sample that contained E-Coli, the resamples were clear of bacteria.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Rocky Creek Utilities, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION OF NOTICE

...WATER SUPPLY
2015 APR 30 AM 8:09

Newspaper Clipping of Notice Must Be Securely Pasted In This Column



STATE OF MISSISSIPPI
COUNTY OF GEORGE

Before me, the undersigned authority in and for the County and State aforesaid, this day personally appeared **O.G. SELLERS**, who being dually sworn, states on oath that he is the **EDITOR** of the George County Times, a newspaper published in the City (or Town) of Lucedale, State and County aforesaid, and with a general circulation in said county, and that the publication of the notice, a copy of which is hereby attached, has been made in said paper **One** times, at weekly intervals, and in the regular entire issue of said newspaper for the numbers and dates hereinafter named for **One** consecutive weeks, immediately proceeding the date of sale named in said notice, to-wit:

Vol. **111** No. **17** on the **23rd** day of **April** 2015

Vol. _____ No. _____ on the _____ day of _____ 2015

Vol. _____ No. _____ on the _____ day of _____ 2015

Vol. _____ No. _____ on the _____ day of _____ 2015

Sworn to and subscribed before me, this the **23rd** day of **April**, **2015**

2006

2014 Annual Drinking Water Quality Report
Rocky Creek Utilities, Inc.
PWS#: 0200006
April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the
and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinkir
want you to understand the efforts we make to continually improve the water treatment process and protect our water re
are committed to ensuring the quality of your water. Our water source is from two wells drawing from the Miocene Series A

The source water assessment has been completed for our public water system to determine the overall susceptibility c
water supply to identified potential sources of contamination. A report containing detailed information on how the
determinations were made has been furnished to our public water system and is available for viewing upon request. The
Rocky Creek Utilities, Inc. have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact LaJune Welford at 601.508.63
our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regula
meetings. They are held on the first Thursday of each month at 6:00 PM at the office building located at 1197 Rocky Creel

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below l
drinking water contaminants that we detected during for the period of January 1st to December 31st , 2014. In cases whe
wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or undergroun
naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from
of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage trea
septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which ca
occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas producti
farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-wat
residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-produc
processes and petroleum production, and can also come from gas stations and septic systems; radioactive contamina
be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is
EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All c
including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It
remember that the presence of these constituents does not necessarily indicate that the water poses a health risk..

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand thes
provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a
must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contamin
water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allo
water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below wh
known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There
evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there
expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contam

2006

Microbiological Contaminants

Fecal coliform and E.coli	N	September	Positive	1	NA	0		Human and animal fecal waste

Inorganic Contaminants

10. Barium	N	2014	.009	.002 - .009	ppm	2	2	Discharge of drilling wastes; dis from metal refineries; erosion of deposits
13. Chromium	N	2014	4.4	3.9 – 4.4	ppb	100	100	Discharge from steel and pulp m erosion of natural deposits
14. Copper	N	2012/14*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural depo leaching from wood preservative
16. Fluoride	N	2014	.215	.139 - .215	ppm	4	4	Erosion of natural deposits; wate additive which promotes strong t discharge from fertilizer and alum factories
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural depo

Disinfection By-Products

81. HAA5	N	2014	7	6 - 7	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	16.99	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1.20	.60 – 1.8	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014.*

Microbiological Contaminants:

(2) Fecal coliform/E.Coli. Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nauses, headaches, or other symptoms. They may pose a special health risk for young children, and people with severely compromised immune systems.

In September 2014 our system had one sample that contained E-Coli, the resamples were clear of bacteria.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacterio sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now r systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. L drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Associa responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 second minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Labo offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants doe necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects ca obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised pe such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AID other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek a about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infectio cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Rocky Creek Utilities, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers he protect our water sources, which are the heart of our community, our way of life and our children's future.