

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2014

MISSISSIPPI WATER SUPPLY

2015 MAY 11 AM 8:32

NORTH HAVEN WATER ASSOCIATION, INC.  
Public Water Supply Name

MS 073008

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)  
 On water bills (attach copy of bill)  
 Email message (MUST Email the message to the address below)  
 Other \_\_\_\_\_

Date(s) customers were informed: 5/1/15 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: \_\_\_ / \_\_\_ / \_\_\_

- As a URL (Provide URL \_\_\_\_\_)  
 As an attachment  
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: NEW ALBANY GAZETTE

Date Published: 5/1/15

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_ / \_\_\_ / \_\_\_

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):  
\_\_\_\_\_

**CERTIFICATION**

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Ken Ramey  
Name/Title (President, Mayor, Owner, etc.)  
PRESIDENT

5-7-15  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:  
[water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

2014 Annual Drinking Water Quality Report  
 North Haven Water Association, Inc.  
 PWS#:0730008  
 April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Coffee Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the North Haven Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Ken Owen, President at 662.534.7309. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for Monday, June 15, 2015 at 7:00 PM at the Union County Supervisors Maintenance Office on HWY 15 North, New Albany, MS 38652.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination

<b>Inorganic Contaminants</b>									
10. Barium	N	2013*	.039	.026 - .039	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N	2013*	.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
14. Copper	N	2012/14	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
15. Cyanide	N	2013*	18	No Range	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories	
16. Fluoride	N	2013*	.2	.176 - .2	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2012/14	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
<b>Disinfection By-Products</b>									
Chlorine	N	2014	1.4	.6 - 1.8	Mg/l	0	MDRL = 4	Water additive used to control microbes	

\* Most recent sample. No sample required for 2014.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The North Haven Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Proof of Publication

State of Mississippi  
County of Union  
PERSONALLY APPEARED  
Northaven


before me, the undersigned, a notary public in and for UNION County, Mississippi, the Publisher of The New Albany Gazette, a newspaper published in the City of New Albany, Union County, in said state, who, being duly sworn, deposes and says that the NEW ALBANY GAZETTE is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy, in the matter of Cause No. \_\_\_\_\_

has been made in said newspaper \_\_\_\_\_ times consecutively, to-wit:

- On the 1 day of May, 2015
- On the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_
- On the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_
- On the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_

SWORN TO and signed before me, this

1st day of May  
Annelle M. H.



Avery Clerk  
Title

RECEIVED OF \_\_\_\_\_  
payment in full of the above account.

THE NEW ALBANY GAZETTE

By K. Wayne Thitchell

New Albany, Miss., May 1, 2015

Re: Publishing \_\_\_\_\_  
case of \_\_\_\_\_

TO THE NEW ALBANY GAZETTE Dr.

Cause No. \_\_\_\_\_

Amt. Due \$ \_\_\_\_\_

73/08

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our primary goal is to provide you with a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Colter Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall resiliency of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the resiliency of our public water system has been assessed and is available for viewing upon request. The wells for the North Haven Water Association have received a "low" susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Matt Owen, President at 862.334.1500. We offer our related programs just as informed about your water, if you would like to learn more.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2014. In cases where monitoring naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic chemicals, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, and residential uses; organic chemicals, including pesticides and herbicides, which may come from a variety of sources such as agricultural, urban storm-water runoff, and processes and petroleum production, and can also come from gas stations and auto repair shops; radon, a naturally occurring radioactive gas that can be found in some wells; and disinfection by-products, which can be the result of the production and mixing activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL)** - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - The "Clear" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contamination.
- Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- Parts per million (ppm) or kilograms per liter (kg/L)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or kilograms per liter (kg/L)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$100,000,000.

Contaminant	Violation	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measure	MCL	MCLG	MRDL	MRDLG	Level	Source of Contamination
<b>Inorganic Contaminants</b>											
10. Boron	N	2014	0.00	0.00 - 0.20	ppm	2	2				Discharge of mining waste; discharge from metal refineries; discharge from glass manufacturing.
13. Chromium	N	2014	0	No Range	ppm	100	100				Discharge from steel and chrome plating; discharge from electroplating; discharge from metal refineries; discharge from metal processing.
14. Copper	N	2014	0	0	ppm	1.5	1.5				Discharge from metal refineries; discharge from metal processing; discharge from metal plating.
15. Cyanide	N	2014	0	No Range	ppm	200	200				Discharge from metal refineries; discharge from metal processing; discharge from metal plating.
16. Fluoride	N	2014	0	0.0 - 0.3	ppm	4	4				Discharge from metal refineries; discharge from metal processing; discharge from metal plating.
17. Lead	N	2014	0	0	ppm	0.01	0.01				Corrosion of lead-based plumbing; discharge from metal refineries; discharge from metal processing.

<b>Disinfection By-Products</b>											
Contaminant	Violation	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/MCLG	Unit Measure	MCL	MCLG	MRDL	MRDLG	Level	Source of Contamination
Chloroform	N	2014	1.4	1.4 - 1.8	ppm	0	0	0	0	0	Water exists and is treated through.

As you can see by the table, our system has no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water is safe to drink at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We do compare the monitoring requirements to epidemiological systems of any existing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested for lead. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the State Drinking Water Hotline at 800-426-6272. The Washington State Department of Health Public Health Laboratory offers lead testing. Please call 509.487.7282 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic chemicals and radioactive substances. All drinking water including bottled water, necessarily contains some level of these contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 800-426-6272.

Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, the elderly, and those with compromised immune systems are particularly at risk from lead. These people should seek advice from their health care providers. EPA's Lead Action Plan provides information on appropriate measures to reduce the risk of lead in drinking water. Information on other microbiological contaminants is available from the Safe Drinking Water Hotline at 800-426-6272.

The North Haven Water Association, Inc. works around the clock to provide top quality water in every tap. We ask that all our customers help us protect our water source, which is the heart of our community, our way of life and our children's future.