MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

WATER SUPPLY
2015 MAY 14 AM 10: 12

LEXIE WATER ASSOCIATION INC.
Public Water Supply Name

0740004
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☑ Advertisement in local paper (attach copy of advertisement)
- ☐ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other _____

Date(s) customers were informed: ___/___/___, ___/___/___, ___/___/___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___/___/___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___/___/___

- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: Tylertown Times

Date Published: ___/___/___

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: ___/___/___

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

_____

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Cathy Vaughn
Name/Title (President, Mayor, Owner, etc.)

5/14/15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

2014 Annual Drinking Water Quality Report
Lexie Water Association, Inc.
PWS#: 0740004
April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Lexie Water Association have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Cathy Van Dan at 601.876.5157. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on Tuesday 3/17/15 at 5:30 PM at Lexie Water.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st , 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Microbiological Contaminants								
1. Total Coliform Bacteria	N	October	Positive	1	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Inorganic Contaminants								
10. Barium	N	2013*	.0569	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013*	.5	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
17. Lead	N	2011/13*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2014	1.3	1.2 – 1.5	ppm	0	MRDL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014.*

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We routinely monitor for the presence of drinking water contaminants. We took five samples for coliform bacteria during October 2014.One of the routine samples showed the presence of coliform bacteria. We did not find any bacteria in our subsequent testing which shows that this problem has been resolved

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Lexie Water Association works hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Vater Quality Report
ociation, Inc.
'40004
015

port. This report is designed to inform you about the quality water
vide you with a safe and dependable supply of drinking water. We
he water treatment process and protect our water resources. We
customers are our best allies. Our water source is from wells

ater system to determine the overall susceptibility of its drinking
eport containing detailed information on how the susceptibility
stem and is available for viewing upon request. The wells for the
sceptibility to contamination.

utility, please contact Cathy Van Dan at 601.876.5157. We want
ant to learn more, please join us at any of our regularly scheduled
er.

ling to Federal and State laws. This table below lists all of the
January 1st to December 31st, 2014. In cases where monitoring
water travels over the surface of land or underground, it dissolves
s and can pick up substances or contaminants from the presence
uses and bacteria, that may come from sewage treatment plants,
ic contaminants, such as salts and metals, which can be naturally
estic wastewater discharges, oil and gas production, mining, or
of sources such as agriculture, urban storm-water runoff, and
and volatile organic chemicals, which are by-products of industrial
tations and septic systems; radioactive contaminants, which can
ining activities. In order to ensure that tap water is safe to drink,
ints in water provided by public water systems. All drinking water,
ain at least small amounts of some constituents. It's important to
ly indicate that the water poses a health risk.

be familiar with. To help you better understand these terms we've

l, triggers treatment or other requirements which a water system

) is the highest level of a contaminant that is allowed in drinking
it available treatment technology.

e level of a contaminant in drinking water below which there is no

of a disinfectant allowed in drinking water. There is convincing
bial contaminants.

a drinking water disinfectant below which there is no known or
e of disinfectants to control microbial contaminants.

llion corresponds to one minute in two years or a single penny in

corresponds to one minute in 2,000 years, or a single penny in

SULTS

or	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
L				
	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment

PROOF OF PUBLICATION

STATE OF MISSISSIPPI,
COUNTY OF WALTHALL

Personally appeared before me, the undersigned authority in and for the county and state aforesaid Carolyn Dillon who is Editor-Publisher of The Tylertown Times, a newspaper printed and published in the Town of Tylertown, Walthall County, Mississippi, who being by me first duly sworn, states on oath that The Tylertown Times, a newspaper as aforesaid, has been a duly established newspaper published in and having a general circulation in the Town of Tylertown, Walthall County, Mississippi for more than twelve months prior to the date of the first publication of the notice herein below specified and that in said paper a certain notice, a printed copy of which is hereto attached, has been made and published in said newspaper for 1 weeks, consecutive, as follows, to-wit:

On the 14th day of May 20 15

On the _____ day of _____ 20 _____

On the _____ day of _____ 20 _____

On the _____ day of _____ 20 _____

On the _____ day of _____ 20 _____

On the _____ day of _____ 20 _____

Carolyn Dillon Editor-Publisher,
The Tylertown Times

Sworn to and subscribed before me, on this the 14th day of May, 20 15

Doug Walker-Notary

STATE OF MISSISSIPPI DOUG WALKER ID No 61387 NOTARY PUBLIC Comm Expires May 31, 2018 WALTHALL COUNTY

The Tylertown Times

727 Beulah Ave.
Box 72, Tylertown, MS 39667
E-mail: tylertowntimes@bellsouth.net
(601) 876-5111 • (601) 876-5280 (FAX)