WATER SUPPLY
2015 MAY 20 AM 8: 33

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

Town of Gloster
Public Water Supply Name

0030003
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☑ Advertisement in local paper (attach copy of advertisement)
- ☐ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other_____

Date(s) customers were informed: __/__/__, __/__/__, __/__/__

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used_____

Date Mailed/Distributed:__/__/__

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed:__/__/__

- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: The Southern Herald

Date Published: 5/14/15

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: 5/14/15

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

_____

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Billy Johnson, Mayor
Name/Title (President, Mayor, Owner, etc)

05/18/15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

WATER SUPPLY
2015 MAY 13 PM 12: 21

2014 Annual Drinking Water Quality Report
Town of Gloster
PWS#: 0030003
May 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from three wells drawing from the Miocene Series Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Gloster have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Gary Sterling at 601.657.0478. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 5:30 PM at the Gloster Town Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st , 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014	.0385	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	.5	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2012/14	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2012/14	.2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2014	.49	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2014	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2014	1.2	.7 – 1.3	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Town of Gloster works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

WATER SUPPL

2015 MAY 20 AM 8:33

PROOF OF PUBLICATION 0030003

STATE OF MISSISSIPPI

COUNTY OF AMITE

PERSONALLY CAME before me, the undersigned, a notary public in and for the state aforesaid, the undersigned agent of THE SOUTHERN HERALD, a newspaper published in the Town of Liberty, Amite County, Mississippi, who, being duly sworn, deposes and says that THE SOUTHERN HERALD is a newspaper as defined and prescribed in Section 13-3-3, Mississippi Code of 1972, and that the publication of

2014 ANNUAL DRINKING WATER QUALITY REPORT
TOWN OF GLOSTER
PWS ID# 0030003
MAY 2015

of which the annexed is a copy, has been made in said paper 1 times consecutively, to-wit:

On the 14 day of MAY, 2015

On the _____ day of _____, 2015

On the _____ day of _____, 2015

On the _____ day of _____, 2015

Publisher

SWORN TO and subscribed before me, this

day of APRIL, 2015

STATE OF MISSISSIPPI NOTARY PUBLIC ID # 84400 COYETTE STUART My Commission Expires March 6, 2019 AMITE COUNTY

Notary Public

My Commission Expires MARCH 6, 2019

PUBLISHER'S FEE

1,728 Words @ 12 ¢ ----- $207.36

Making Proof of Publication --- 0.00

TOTAL ---------- $207.36

2014 Annual Drinking Water Quality Report
Town of Gloster
PWS ID# 0030003
May 2015

you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process s. We are committed to ensuring the quality of your water. Our water source is from three wells from the Miocene Series Aquifers.
rt has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of con detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon own of Gloster have received a moderate susceptibility ranking to contamination.
bout this report or concerning your water utility, please contact Gary Sterling at 601-657-0478. We want our valued customers to be informed about their r more, please attend any of our regular scheduled meetings. They are held on the first Tuesday of each month at 6:30 PM at the Gloster Town Hall.
nstituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminates that we detected during December 31st, 2014, in cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of s naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from nminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inor- ds and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas produc- des and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical con- and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic nts, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA t the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably all amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a

ny terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:
ation of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
el (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as e treatment technology.
el Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow

tant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary nts.
tant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the nts to control microbial contaminants.
illigrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.
icrograms per liter - one part per billion corresponds to one in minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely source of Contamination
2014	0385	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
2014	5	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
2012/14	1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2012/14	2	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits.
2014	49	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
2014	3	No Range	ppb	0	60	By-product of drinking water disinfection.
2014	1.2	7-1.3	ppm	0	MDRL=4	Water additive used to control microbes

t for 2014.
le, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned sting that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.
r your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets to ensure systems complete all monitoring requirements. MSDH now notifies systems of any missing samples prior to the end of the compliance period.
of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and com- ce lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used en your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before oking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and e exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.
ter are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic bstances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of ssarily indicate that the water poses a health risk. More information about contaminants and potential healtlh effects can be obtained by calling the ency's Safe Drinking Water Hotline at 1-800-426-4791.
re vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infec- eek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidi- contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.
s around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our com- r children's future.