WATER SUPPLY
2015 JUN 22 AM 8:45

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

Combined Utilities Inc.
Public Water Supply Name

200001
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☒ Advertisement in local paper (attach copy of advertisement)
- ☐ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other _____

Date(s) customers were informed: ___/___/___, ___/___/___, ___/___/___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___/___/___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___/___/___

- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: George County Times

Date Published: 5/11/2015

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: 5/08/2015

George County Public Library

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

_____

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Roy Caldwell (President)
Name/Title (President, Mayor, Owner, etc.)

6/16/2015
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

WATER SUPPL
2015 JUN 22 AM 8:45

014 Annual Drinking Water Quality Report
Combined Utilities
PWS ID#: 0200001
April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Tipper Catahoula Formation and the Miocene Series Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Combined Utilities have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Dale Keel at 601.508.9716. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 5:00 PM at 9147 Old Hwy 63 South.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st , 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2014	1.3	.6 – 1.3	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014	.0322	.0092 - .0322	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2014	3	.5 - 3	ppb	100		Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011/13*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.735	.302 – .735	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2014	4.8	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
81. HAA5	N	2014	23	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	51	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1	.50 – 2	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014.*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the Combined Utilities is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 6. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 54%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Combined Utilities works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION OF NOTICE

Newspaper Clipping of Notice Must Be
Securely Pasted In This Column

g Water Quality Report
ed Utilities
#: 0200001
il 2015

Report. This report is designed to inform you about the quality water
provide you with a safe and dependable supply of drinking water. We
ve the water treatment process and protect our water resources. We
ource is from wells drawing from the Tipper Catahoula Formation and

lic water system to determine the overall susceptibility of its drinking
A report containing detailed information on how the susceptibility
ter system and is available for viewing upon request. The wells for the
contamination.

water utility, please contact Dale Keel at 601.508.9716. We want our
ou want to learn more, please attend any of our regularly scheduled
at 5:00 PM at 9147 Old Hwy 63 South.

according to Federal and State laws. This table below lists all of the
iod of January 1st to December 31st, 2014. In cases where monitoring
lts. As water travels over the surface of land or underground, it dissolves
aterials and can pick up substances or contaminants from the presence
h as viruses and bacteria, that may come from sewage treatment plants,
norganic contaminants, such as salts and metals, which can be naturally
or domestic wastewater discharges, oil and gas production, mining, or
variety of sources such as agriculture, urban storm-water runoff, and
nthetic and volatile organic chemicals, which are by-products of industrial
m gas stations and septic systems; radioactive contaminants, which can
on and mining activities. In order to ensure that tap water is safe to drink,
ontaminants in water provided by public water systems. All drinking water,
d to contain at least small amounts of some constituents. It's important to
necessarily indicate that the water poses a health risk.

might not be familiar with. To help you better understand these terms we've

exceeded, triggers treatment or other requirements which a water system

equired process intended to reduce the level of a contaminant in drinking

wed" (MCL) is the highest level of a contaminant that is allowed in drinking
ing the best available treatment technology.

ICLG) is the level of a contaminant in drinking water below which there is no
in of safety.

ghest level of a disinfectant allowed in drinking water. There is convincing
ntrol microbial contaminants.

The level of a drinking water disinfectant below which there is no known or
its of the use of disinfectants to control microbial contaminants.

EST RESULTS

of Detects f Samples ceeding CL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

WATER SUPPL
2015 JUN 22 AM 8:45

STATE OF MISSISSIPPI
COUNTY OF GEORGE

Before me, the undersigned authority in and for the County and State aforesaid, this day personally appeared O.G. SELLERS, who being dually sworn, states on oath that he is the EDITOR of the George County Times, a newspaper published in the City (or Town) of Lucedale, State and County aforesaid, and with a general circulation in said county, and that the publication of the notice, a copy of which is hereby attached, has been made in said paper One times, at weekly intervals, and in the regular entire issue of said newspaper for the numbers and dates hereinafter named for One consecutive weeks, immediately proceeding the date of sale named in said notice, to-wit:

Vol. 111 No. 24 on the 11th day of May 2015

Vol.____ No. ____ on the ____ day of ____ 2015

Vol.____ No. ____ on the ____ day of ____ 2015

Vol.____ No. ____ on the ____ day of ____ 2015

[signature]

Sworn to and subscribed before me, this the 11th day of June, 2015

Joanne Harvison

STATE OF MISSISSIPPI
JOANNE HARVISON
ID number 4048
NOTARY PUBLIC
Comm. Expires June 28, 2015
GEORGE COUNTY