WATER SUPPLY

2015 JUN -3 AM 10: 14

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

City of Grenada
Public Water Supply Name

0220003 - 0220004 - 0220007 - 0220005 - 0220036 - 0220062
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☐ Advertisement in local paper (attach copy of advertisement)
- ☑ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other _____

Date(s) customers were informed: ___/___/___, ___/___/___, ___/___/___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 05 / 19 / 2015

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___/___/___

- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: _____

Date Published: ___/___/___

CCR was posted in public places. ***(Attach list of locations)*** City of Grenada Water Billing Office, City of Grenada Water Plant Date Posted: 05 / 19 / 2015

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

_____

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Billy F. Collins - Mayor
Name/Title (President, Mayor, Owner, etc.)

05 - 22 - 2015
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

WATER SUPPLY
2015 APR 27 PM 4: 15

2014 Annual Drinking Water Quality Report
City of Grenada
PWS#: 220003, 220004, 220005, 220007, 220036 & 220062
April 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Wilcox, Middle Wilcox and Lower Wilcox Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Grenada have received lower to higher susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Dale Ratliff at 662-227-3415. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at 6:00 PM at City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st , 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

PWS ID#:0220003				**TEST RESULTS**				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2014	.5	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass

								and electronics production wastes
10. Barium	N	2014	.176	.076 – .176	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	5.6	4 – 5.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011/13*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.157	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011/13*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2014	9	1 - 9	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	6.53	.5 – 6.53	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1	.60- 1.30	ppm	0	MDRL = 4	Water additive used to control microbes
Unregulated Contaminants								
Strontium	N	2013*	.507	.194-.507	UG/L	0.3	MRL 0.3	Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formerly used in medicines and as a germicide

PWS ID#: 220004 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014	.0195	.0148- .0195	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	7.4	6.7 – 7.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.172	.143 – 1.72	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2014	13	10 - 13	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	4.49	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1.2	1 – 1.3	ppm	0	MDRL = 4	Water additive used to control

								microbes

PWS ID#: 220005 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014	.0268	.0258 - .0268	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	1.2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
17. Lead	N	2012/14	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2014	1.1	1 – 1.1	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 220007 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	N	December	Positive	2	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Inorganic Contaminants								
8. Arsenic	N	2014	1	.6 - 1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014	.0295	.0282 - .0295	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	10.8	7.1 – 10.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.231	.223 - .231	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2014	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014	6.51	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1	.8 – 1.2	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 220036 TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants								
8. Arsenic	N	2014	1.5	1.2 – 1.5	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014	.0264	.0208 - .0264	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	9.4	8.7 – 9.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.19	.176 - .19	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2014	5.5	4.2 – 5.5	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
Chlorine	N	2014	1.1	1 – 1.2	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 220062				TEST RESULTS				
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014	.0104	.0043 - .0104	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	5.3	4.8 – 5.3	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.132	.127 - .132	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2014	2.64	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2014	1.2	1 – 1.3	ppm	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014.*

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We routinely monitor for the presence of drinking water contaminants. On system #220007 we took two samples for coliform bacteria during December 2014. Both of the routine samples showed the presence of coliform bacteria. The standard is that no more than 1 sample per month of our samples may do so. We did not find any bacteria in our subsequent testing which shows that this problem has been resolved.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of Grenada works around the clock to provide top quality water to every tap. We have four certified operators on staff, who would be pleased to answer any and all customer questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

City of Grenada

116 Main St.
Grenada, Mississippi 38901

JOE MILLS
305 AIR INDUSTRIAL PK #8
GRENADA, MS 38901

DAYS OF OPERATION MON-FRI 8:00 AM- 5:00 PM
PHONE: 662-227-3400
FAX: 662-226-0561
AFTER HOURS/EMERGENCIES: 662-227-3415
QUESTIONS: WATERBILLING@CITYOFGRENADA.MS

ACCOUNT NUMBER	00013419
BILLING DATE	05/19/15
PREVIOUS BILL	$60.90
PAYMENTS	$0.00
BALANCE FORWARD	$60.90
CURRENT CHARGES	$120.42
TOTAL DUE	$181.32
DATE DUE	06/01/15
AMOUNT DUE IF PAID AFTER DUE DATE Includes $5.00 Penalty	$186.32
CUT OFF DATE Account subject to disconnection and $35 Admin Fee	06/09/2015

SERVICE ADDRES: 305 AIR INDUSTRIAL PK #8

SERVICE	PREVIOUS READING	CURRENT READING	READ DATE	CONSUMPTION
WATER	24720	38650	05/08/2015	13930

DETAIL OF CHARGES

SERVICE PERIOD 04/10 - 05/08

SERVICE DESCRIPTION	AMOUNT
WATER	$70.59
SEWER	$36.83
GARBAGE	$13.00
TOTAL CURRENT CHARGES	$120.42

IMPORTANT INFORMATION

FAILURE TO RECEIVE THE BILL DOES NOT EXCUSE SERVICE DISCONNECTION

PAYMENT OPTIONS

- **BY MAIL (ONLY SEND CHECK OR MONEY ORDER)**
- **AFTER HOURS BOX LOCATED AT CITY HALL (ONLY CHECK OR MONEY ORDER - DO NOT PAY IN CASH). CITY IS NOT RESPONSIBLE FOR LOST CASH. PAYMENTS ARE APPLIED TO YOUR ACCOUNT THE NEXT BUSINESS DAY.**

IMPORTANT MESSAGE

Visit us on the web at – www.cityofgrenada.ms

PLEASE DETACH AND RETURN BOTTOM PORTION IF PAYING BY MAIL. PLEASE DO NOT STAPLE OR FOLD. PLEASE WRITE YOUR ACCOUNT NUMBER ON YOUR CHECK. TO BETTER ASSIST YOU, PLEASE BRING YOUR COMPLETE BILL WHEN PAYING IN PERSON.

☐ Check here for E-Billing Form on Reverse side

BILL DATE	ACCOUNT NUMBER	DATE DUE
05/19/15	00013419	06/01/15
PREVIOUS BALANCE	BALANCE FORWARD	TOTAL DUE
$60.90	$60.90	$181.32
AMOUNT DUE IF PAID AFTER DUE DATE Includes $5.00 Penalty		$186.32
CUT OFF DATE Account subject to disconnection and $35 Admin Fee		06/09/2015

116 Main St.
Grenada, Mississippi 38901

RETURN SERVICE REQUESTED

1223 1 AV 0.381

Joe Mills
305 Air Ind Pk Rd Trlr 8
Grenada MS 38901-8811

Amount Enclosed $ _____

Please remit and make checks in US funds payable to:

CITY OF GRENADA - WATER DEPT
116 MAIN ST
GRENADA MS 38901-2622