CALENDAR YEAR 2014 CONSUMER CONFIDENCE REPORT
CERTIFICATION REPORT
SOUTH NEWTON RURAL WATER ASSOCIATION #2
PWS ID #: 0510019

WATER SUPPL
2015 MAY 29 AM 8: 18

The Federal Safe Drinking Water Act requires each ***community*** public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

☒ Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill, or other)***

- ☐ Advertisement in local paper
- ☒ On water bills
- ☐ Other _____

Date customers were informed: 5-26-2015

☐ CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed: _____

☐ CCR was published in local newspaper. ***(Attach copy of published CCR and proof of publication)***
Name of Newspaper: _____
Date Published: _____

☐ CCR was posted in public places. ***(Attach list of locations)***

Date posted: _____

☐ CCR was posted on a publicly accessible internet site at the address: www:_____

CERTIFICATION:

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Wayne Clanton mgr — 5-18-2015
Name/Title (President, Mayer, Owner, etc.) — *Date*

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susan Bayliff — 4-10-15
Signature — *Date*

Mail completed form along with a copy of your CCR Report(s) before JULY 1, 2015 to:
MS State Department of Health
Division of Public Water Supply
P O Box 1700
Jackson, MS 39215
Phone: 601-576-7518

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2013*	0.0277	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013*	14	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2011*	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2013*	0.633	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2011*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	2013*	0.0017	No Range	ppm	0.1	0.1	Discharge from chemical factories, metal refineries and petroleum refineries
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl2)	N	1/1/14 to 12/31/14	1.00	0.90 to 1.00	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri-halomethanes]	N	~~2013*~~ 2014	~~14.2~~ 13.5	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5	N	~~2013*~~ 2014	~~6~~ 5	No Range	ppb	0	60	By-product of drinking water chlorination

*** Most recent sample results available**

To comply with the "*Regulation Governing Fluoridation of Community Water Supplies*", CITY OF NEWTON is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 100%.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. South Newton Rural Water Association #2 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing for $10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions.

ACCOUNT NO.	SERVICE FROM	SERVICE TO
03-0001000	04/15	05/15

SERVICE ADDRESS

631 NEW IRELAND RD

METER READINGS		
CURRENT	PREVIOUS	USED
1313600	1303800	9800

CHARGE FOR SERVICES

WTR	59.00
NET DUE >>>	59.00
SAVE THIS >>	5.90
GROSS DUE >>	64.90

RETURN THIS STUB WITH PAYMENT TO:

SOUTH NEWTON RURAL WATER ASSOC.
P.O. BOX 82 • NEWTON, MS 39345

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 44
NEWTON, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/10/2015	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
59.00	5.90	64.90

CONSUMER CONFIDENCE REPORT
FOR 2015 AVAILABLE IN OFFICE

RETURN SERVICE REQUESTED

03-0001000
CHRIS CRAVEN

631 NEW IRELAND RD
NEWTON MS 39345-9350

2015 MAY 29 AM 8:
WATER SUPPL