WATER SUPPLY

2015 JUN 22 AM 9:02

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

College Hill Water Assoc.
Public Water Supply Name

0360004
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- [X] Advertisement in local paper (attach copy of advertisement)
- [ ] On water bills (attach copy of bill)
- [ ] Email message (MUST Email the message to the address below)
- [X] Other letter

Date(s) customers were informed: 06/05/15, / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /

- [ ] As a URL (Provide URL)
- [ ] As an attachment
- [ ] As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: The Oxford Eagle

Date Published: 06/18/15

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[signature] - operator
Name/Title (President, Mayor, Owner, etc.)

6/18/15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

2014 Annual Drinking Water Quality Report
College Hill Water Association
PWS#: 360004
June 2015

WATER SUPPLY
2015 JUN 22 AM 9: 02

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Upper Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination.. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for College Hill Water have received moderate to higher ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Steve Hollowell at 662.832.3883. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the fourth Thursday of the month at 6:30 PM at the College Hill Fire Station.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st , 2014. In cases where monitoring wasn't required in 2014 the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2012*	.01468	No Range	ppm	2	2	Discharge of drilling wastes;

								discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	.57	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2012/14	.003	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2014	.38	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

Chlorine	N	2014	2.3	1.7 – 2.4	ppm	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2014.*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing for $10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

College Hill works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

2015 JUN 22 AM 9:02

PRINTER'S FEE $ 315.15

THE STATE OF MISSISSIPPI
LAFAYETTE COUNTY

Personally appeared before me, a notary public in and for said county and State, the undersigned

Don Whitten

Who, after being duly sworn, deposes and says that he is the General Manager of the Oxford Eagle, a newspaper published daily in the City of Oxford, in said county and State, and that the said newspaper has been published for more than one year and that

OE College Water

a true copy of which is hereto attached was published for 1 consecutive weeks in said newspaper as follows:

VOLUME	NO.	DATE
147	223	6/18/15

Don Whitten

Sworn to and subscribed before me this 18th day of June, 20 15

Jessica Harwell

Notary Public, Lafayette County, Mississippi

My commission expires

STATE OF MISSISSIPPI
JESSICA HARWELL
ID No 108871
NOTARY PUBLIC
Comm Expires May 7, 2018
LAFAYETTE COUNTY



for name and address, grantee name and address, deed reference and date, sectiontownshirange, type change code, parcel number, and legal description.

Contractor shall electronically update the land ownership date in the WS/400. No data entry shall be required on the part of the County. The approach to updating this data must be demonstrated and approved by the Tax assessor prior to contract

Reach 2.2 Million

Classes-Training

AVIATION Grads work with JetBlue, Boeing, NASA and others - start here with hands on training for FAA certification. Financial aid if qualified. Call Aviation Institute of Maintenance **866-357-2510.**

Employment-Sales

EARN $500 A DAY! Insurance Agents Needed; Leads, No Cold Calls; Commissions Paid Daily; Lifetime Renewals; Complete Training; Health & Dental Insurance; Life License Required. Call 1-888-713-6020.

Employment-Trucking

AVERITT EXPRESS Start Pay: 40 to 43.5 CPM + Fuel Bonus! Get Home EVERY Week + Excellent Benefits. CDL-A Required. Recent Tractor Trailer Grads Welcome. Call: 888-602-7440 Or Apply @ AverittCareers.com. Equal Opportunity Employer - Females, Minorities, Protected Veterans and Individuals With Disabilities Are Encouraged To Apply.

DRIVER - CDL/A
NEW PAY INCREASE
CLASSES STARTING
EVERY MONDAY!

- No out of pocket tuition cost!
- Earn Your CDL-A in 22 Days and start driving with KLLM!

WE PAY YOU WHILE YOU TRAIN!

- Refresher Course Available.

Must Be 21 Years of Age
855-378-9335 EOE
www.kllmdrivingacademy.com

25 DRIVER TRAINEES NEEDED NOW!
Learn to drive for USXpress
Earn $800 per week.
Local 15-day CDL training.
Immediate Openings!
1-800-350-7364
U.S. XPRESS
SERVICE THAT MATTERS
DRIVEN BY INNOVATION

WATER SUPPL
2015 JUN 22 AM 9:02

DATE: June 5, 2015

TO: College Hill Water Association Customers

FROM: Dana McKibben, President, College Hill Water Association Board
Steve Hollowell, Operator

A Consumer Confidence Report (CCR) for the College Hill Water Association has been developed and a copy is available upon request to any College Hill Water Association customer. A copy of this report has been provided to the Mississippi State Department of Health-Division of Water Supply.

If you are interested in obtaining a copy of this report, please call Steve Hollowell at (662) 832-3883.

Steve Hollowell

Dana McKibben

WATER SUPPLY
2015 JUN 22 AM 9:02

Mississippi State Department of Health
Division of Water Supply
570 East Woodrow Wilson
Post Office Box 1700
Jackson, Mississippi 39212-1700

RE: CCR Report
College Hill Water Association

Dear Sir/Madam:

This is to inform you that the customers of the College Hill Water Association were notified regarding the CCR report that was completed for their system and that a copy of the report would be available to them by contacting any board member or Steve Hollowell at (662) 832-3883.

If you need additional information, please contact me.

Sincerely,

Steve Hollowell

Steve Hollowell - Operator

Dana McKibben

Dana McKibben - President