2015 JUL -1 AM 8:41 WATER SUPPL

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

Lincoln Rural WA Pleasant Ridge
Public Water Supply Name

43003
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☒ Advertisement in local paper (attach copy of advertisement)
- ☒ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other _____

Date(s) customers were informed: ___/___/___, ___/___/___, ___/___/___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___/___/___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___/___/___
- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: Daily Leader – Capitol Courier

Date Published: 6/19/15 6/24/15

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: ___/___/___

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

Posted @ Office

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Tommy Cupit
Name/Title (President, Mayor, Owner, etc.)

6/25/15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

2015 JUL -1 AM 8:41

QUALITY ON TAP REPORT
LINCOLN RURAL WATER ASSOCIATION
Pleasant Ridge
PWS ID# 430003

June 01, 2015

Lincoln Rural Water is pleased to present to you, this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells pumping from the Miocene Aquifer.

We are pleased to report that our drinking water meets all federal and state requirements. The following reports show our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact **our office at 1536 Monticello Street, Brookhaven, MS 39602, 601-833-6449.** We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on **the 3rd Tuesday of each month at the above location at 7:00 P.M. and our annual meeting is held on the 2nd Monday of March at the Lincoln County Courthouse at 7:00 P.M.**

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detail information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Lincoln Rural Water have received a moderate and lower ranking in terms of susceptibility to contamination.

Lincoln Rural Water Association routinely monitors for many constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, **2014.** All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. . More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal (MCLG) is the level of a contaminant in drinking water below which there is no know or expected risk to health. MCLGs allow for a margin of safety.

Addition information for Lead

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about leak in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/sagewater/lead. The Mississippi State Department of Health Laboratory offers lead testing for $20.00 per sample. Please contact 601.576.7582 if you wish to have you water tested.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential source of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the LINCOLN RURAL ASSOCIATION have received lower rankings in terms of susceptibility to contamination.

Test Results

#0430003 Pleasant Ridge

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low	Range High	Sample Date	Violation	Typical Source
Disinfectants & Disinfection By-Products								
Chlorine (as Cl2) (ppm)	4	4	1.10	.90	1.30	2014	No	Water additive used to control microbes
Inorganic Contaminants								
Nitrate [measured as Nitrogen]	10	10	0.19	NA		2014	No	Runoff from fertilizer use: Leaching from septic tanks, Sewage: Erosion of natural deposit
Nitrite [Measured as Nitrogen]	10	10	0.19	NA		2014	No	Runoff from fertilizer use: Leaching from septic tanks. Sewage: Erosion of natural deposit
Fluoride (ppm)	4	4	0.153	NA		2014	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium(ppm)	2	2	.0191ppm	N/A		2014	No	Discharge of drilling wastes Discharge from metal refineries Of natural deposits
Chromium (ppb)	100	100	.0011	NA		2014	No	Discharge from steel and pulp Mills. Erosion of natural deposit

Inorganic Contaminants	MCLG	AL	Your Sample Water	Your Sample Date	#Samples Exceeding Al	Exceed Al	Typical Source
Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	2014	1	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (PPB)	0	2ppb	.015	2014	2	No	Corrosion of household plumbing systems; Erosion of natural deposits

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

Deliver payment to:

Lincoln Rural Water Assn.
PO Drawer 712
Brookhaven, MS 39602-0712
833-6449

This institution is an equal opportunity provider and employer

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39602
PERMIT # 104

Previous Balance:	0.00
WELL 3 RES W USED: 100 PREV: 6200 PRES: 6300	15.00
TOTAL NEW CHARGES	15.00

YOU OWE 15.00 by 07/10/15

After 07/10/15 pay 16.50

Last Pmt $18.00 06/15/15 SYLVESTER BUTLER
SVC:05/01/15-06/02/15 (32 days) Acct# 688100
2497 JACKSON LIBERTY
NO PARTIAL PAYMENTS ACCEPTED! LOCK OF
FOR 2 MONTHS BILLS 07/15/2015!

Return this portion with payment.

YOU OWE 15.00 by 07/10/15

After 07/10/15 pay 16.50

Acct# 688100
2497 JACKSON LIBERTY

SYLVESTER BUTLER
DR. IDA BUTLER
16 STONEY CREEEK DRIVE
EGG HARBOR TWP NJ 08234

2015 JUL 1 AM 8:

Deliver payment to:

Lincoln Rural Water Assn.
PO Drawer 712
Brookhaven, MS 39602-0712
833-6449

This institution is an equal opportunity provider and employer

FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39602
PERMIT # 104

Previous Balance:	0.00
WELL 3 RES W USED: 0 PREV: 0 PRES: 0	15.00
TOTAL NEW CHARGES	15.00

YOU OWE 15.00 by 07/10/15

After 07/10/15 pay 16.50

Last Pmt $15.00 06/05/15 CLARA WILLIAMS
SVC:05/04/15-06/02/15 (29 days) Acct# 712000
3605 OLD RED STAR DR
NO PARTIAL PAYMENTS ACCEPTED! LOCK OF
FOR 2 MONTHS BILLS 07/15/2015!

Return this portion with payment.

YOU OWE 15.00 by 07/10/15

After 07/10/15 pay 16.50

Acct# 712000
3605 OLD RED STAR DR

CLARA WILLIAMS
% ANN GASPARD
126 DEL MAURO ROAD
CANDOR NY 13743

2015 JUL - 1 AM 8: 40